



LAKE HAVASU CITY, ARIZONA
ADMINISTRATIVE SERVICES DEPARTMENT
◆ PROCUREMENT ◆

REQUEST FOR PROPOSALS
NORTH REGIONAL WWTP AERATION SYSTEM REPLACEMENT
P25-PW-500583
ADDENDUM NO. 7
DECEMBER 12, 2024

Attention is called to the following changes, additions, clarifications and/or deletions to the original solicitation and they shall be considered in preparing submissions:

There is no change in the opening date. **Submissions are due no later than 3:00 p.m., Arizona Time, DECEMBER 18, 2024**, at the City Clerk's Office, 2330 McCulloch Blvd. N., Lake Havasu City, AZ 86403.

ITEM ONE (1): QUESTIONS AND ANSWERS

Question 1: PVC deterioration aside, what other issues have been experienced in the past 12 months that have indicated that the system is at the end of its useful life?

Answer 1: No other issues have been observed beyond the PVC deterioration.

Question 2: We were hoping to receive a copy of the actual performance hazard assessment, not just a synopsis. Can the City produce that?

Answer 2: The City did not perform a formal written assessment, only an informal job walk assessment.

Question 3: The photos provided in Addendum 6 were not very legible. Can the City provide the complete plumbing as-builts?

Answer 3: Due to the large size of the plan set (close to 600 pages), the City is not able to provide the complete plan set electronically at this time. If you would like to schedule a time to come to the jobsite, where the as-builts are located, the plans are available to view in person.

Question 4: Can the City provide the original O&M manuals?

Answer 4: Due to the extremely large size of the requested manuals, the City is not able to provide them electronically at this time. As with the as-built plans, if you desire to view them in person please contact Wastewater staff to set up an appointment.

Question 5: Can the City share the original final drawings depicting: 1) Outline dimensions, foundation layout, or mounting information and other pertinent dimensions; 2) Field erection instructions, assembly drawings or diagrams; and 3) General bulletins and cut sheets describing complete apparatus (including operating principles and fundamentals)?

Answer 5: The only drawings the City has have already been provided.

Question 6: Can the City share the model number an, weight, and size of the original diffusers?

Answer 6: The diffusers installed are SANITAIRE® Disc Fine Bubble Aeration System 8” disks.

Question 7: Can the City share the original renewal parts list with diagrammatic or cross sections showing part identifications?

Answer 7: The intent of this RFP is for the proposing firms to provide this to the City as part of each firm’s submitted proposal. The City is not mandating a “like for like” replacement so if your firm has a better solution please illustrate it in your proposal submission.

Question 8: Can the City share the formal test protocol for use during performance testing?

Answer 8: This is dependent on which system solution your firm intends to submit as part of its proposal as the required performance testing will be determined by the submitted system specifications.

Question 9: Can the City share the original diffuser manufacturer’s complete signed report of results of the inspection, operation, adjustments, and test, including the manufacturer’s certificate from the original installation showing the system was ready for permanent operations and the original training verification for the owner’s personnel that were trained in accordance with Part 3 of the Specification?

Answer 9: As the City is asking for a complete replacement of the current aeration system, this is information the proposing firms should be providing to the City as part of their submission package based on which specific system solution each firm is proposing.

Question 10: Can the City confirm that this project’s installation will not render your current manufacturer’s warranty null and void?

Answer 10: The current system is not under warranty.

Question 11: Multiple responses in the previous Addenda have indicated the City is not requesting a like for like replacement. Is the City requesting that a contractor engineer, design, and install a system that meets performance criteria?

Answer 11: Yes

ITEM TWO (2): QUESTION DEADLINE.

The final question deadline has passed and this will be the final Addendum before the submission due date for this Request for Proposals.

Andrew Klos, CPPB
Senior Procurement Specialist