



LAKE HAVASU CITY
Water Conservation Program
Implementation
Package No. 2
SS2970

CONTRACT DOCUMENTS

AND

TECHNICAL SPECIFICATIONS

August 2016
Bid Set
Volume 1 of 2

REVISED 2/12/16

LAKE HAVASU CITY
CONTRACT DOCUMENTS
VOLUME 1 of 2

TABLE OF CONTENTS

DIVISION I – BID AND CONTRACT DOCUMENTS

SECTION 00020	-	NOTICE INVITING BIDS
SECTION 00100	-	INFORMATION FOR BIDDERS
SECTION 00300	-	BID PROPOSAL
SECTION 00310	-	BID SCHEDULE
SECTION 00400	-	ARIZONA STATUTORY BID BOND
SECTION 00420	-	BIDDER'S STATEMENT OF QUALIFICATIONS
SECTION 00430	-	AFFIDAVIT OF CONTRACTOR CERTIFYING NO COLLUSION IN BIDDING
SECTION 00450	-	HAZARD COMMUNICATION PROGRAM
SECTION 00460	-	EMPLOYMENT ELIGIBILITY VERIFICATION FORM
SECTION 00500	-	AGREEMENT
SECTION 00500A	-	INDEMNIFICATION & INSURANCE REQUIREMENTS
SECTION 00500B	-	CONTRACTOR CLAIM HANDLING PROCEDURE
SECTION 00510	-	ARIZONA STATUTORY PERFORMANCE BOND
SECTION 00520	-	ARIZONA STATUTORY PAYMENT BOND
SECTION 00670	-	NOTICE OF AWARD
SECTION 00680	-	NOTICE TO PROCEED
SECTION 00685	-	CERTIFICATE OF SUBSTANTIAL COMPLETION
SECTION 00690	-	CERTIFICATION OF COMPLETION

DIVISION II – GENERAL CONDITIONS

SECTION 00700	-	GENERAL CONDITIONS
---------------	---	--------------------

DIVISION III – SPECIAL PROVISIONS

SECTION 00800	-	SPECIAL PROVISIONS
---------------	---	--------------------

DIVISION IV – TECHNICAL SPECIFICATIONS

The following specifications are contained within this Invitation For Bids:

- SECTION 01110 - SUMMARY OF WORK
- SECTION 01210 - MEASUREMENT AND PAYMENT
- SECTION 11211 - PACKAGED BOOSTER PUMP STATION
- SECTION 13206G - HYDROPNEUMATIC PRESSURE CONTROL SYSTEM INCLUDING TANK
- SECTION 13447 - ELECTRIC ACTUATORS
- SECTION 15118 - PRESSURE REDUCING AND PRESSURE RELIEF VALVES
- SECTION 15120 - PIPING SPECIALTIES

The remaining applicable specifications can be accessed at:

<http://www.lhcaz.gov/community-investment/engineering/engineering-specifications>



EXPIRES 06-30-2017

SECTION 00020
NOTICE INVITING BIDS
Lake Havasu City

PROJECT NO.: SS2970

PROJECT NAME: Water Conservation Program Implementation Package No. 2

BID DUE DATE: September 28, 2016

BID DUE TIME: 3:00 p.m., ARIZONA TIME

PROJECT DESCRIPTION:

This project consists of converting the irrigation water source at various locations along Arizona Highway 95 and at Cypress Park, Jack Hardie Park, and the ASU Campus from potable water to reclaimed water. This will involve disconnecting the landscape irrigation connections along the highway, the parks, and ASU campus irrigation systems from potable water service and reconnecting them to reclaimed water lines. The project includes the installation of approximately 1,260 linear feet of 4-inch DR 18 PVC, approximately 1,140 linear feet of 4-inch Schedule 80 PVC, and approximately 670 linear feet of 2-inch Schedule 80 PVC, associated tapping saddles, gate valves, fittings and appurtenances, and landscaping and surface replacement for areas disturbed by the work, and associated electrical and instrumentation. The project also includes installation of new motorized valves in valve vaults at the intersection of Smoketree and Arizona Highway 95, modifications to an existing lift station, including a new hydropneumatic tank and associated appurtenances at the Mulberry Wastewater Treatment Plant, and a packaged reuse booster pump station at the Island Wastewater Treatment Plant.

Sealed bids for the project specified will be received by the **City Clerk's Office, 2330 N. McCulloch Boulevard, Lake Havasu City, Arizona, 86403** until the time and date stated. **Bids received by the correct time and date will be opened and read aloud immediately thereafter in Room 109 of Lake Havasu City Hall.**

Bids must be clearly addressed to the City Clerk's Office, 2330 McCulloch Blvd. N, Lake Havasu City, Arizona, 86403, and received no later than the exact time and date indicated above. Late bids will not be considered under any circumstances.

Bids must be submitted in a sealed envelope with the Project Number and the bidder's name and address clearly indicated on the envelope. All bids must be completed in ink or typewritten on a form to be obtained from the specifications and a complete Invitation for Bid returned along with the offer no later than the time and date cited above.

Bid documents and specifications are available on Lake Havasu City's website at www.lhcaz.gov or on DemandStar at www.demandstar.com. For documents obtained outside of DemandStar please contact Kim Fiumara, fiumarak@lhcaz.gov, to be added to the planholders' list.

For technical information, contact Jeremy Abbott, PE, at 928.855.0336.

BONDS:

Bid Bond:	<u>10%</u>
Labor and Material Bond:	<u>100%</u>
Faithful Performance Bond:	<u>100%</u>

Project Completion Date: 270 calendar days after Notice to Proceed.

Lake Havasu City reserves the right to accept or reject any or all bids or any part thereof and waive informalities deemed in the best interest of the City.

Pursuant to the Americans with Disabilities Act (ADA), Lake Havasu City endeavors to ensure the accessibility of all of its programs, facilities and services to all persons with disabilities. If you need an accommodation for this meeting, please contact the City Clerk's office at (928) 453-4142 at least 24 hours prior to the meeting so that an accommodation may be arranged.

Publication Dates:

September 1, 2016 – Today's News Herald
September 8, 2016 – Today's News Herald
September 8, 2016 – Arizona Business Gazette
September 15, 2016 – Arizona Business Gazette

** END OF SECTION **

SECTION 00100
INFORMATION FOR BIDDERS

1. RECEIPT AND OPENING OF BIDS

The City of Lake Havasu City, Arizona, (hereinafter called the "Owner") invites Bids on the form attached hereto. All blanks must be appropriately filled in. The Bidder shall also complete and submit a form listing proposed subcontractors as enclosed herein. Any subcontractors proposed to be used on the project but not listed on this form shall not be considered when evaluating the Contractor's qualifications and ability to perform the work. Bids for **Water Conservation Program Implementation Package No. 2, Project No. SS2970** will be received by the **City Clerk's office, 2330 N. McCulloch Boulevard, Lake Havasu City, Arizona 86403 no later than 3:00 P.M., Arizona Time, September 28, 2016**, where said Bids will be publicly opened and read aloud immediately thereafter in the Room 109 of Lake Havasu City Hall.

The Owner may consider informal any Bid not prepared and submitted in accordance with the provisions hereof and may waive any informalities or reject any and all Bids. Any Bid may be withdrawn prior to the above scheduled time for the opening of Bids or authorized postponement thereof. Any Bid received after the time and date specified shall not be considered. No Bidder may withdraw a Bid within ninety (90) days after the actual date of the opening thereof.

2. PREPARATION OF BID

Each Bid must be submitted on the prescribed Form. Each Document must be submitted with an original signature of the Bidder, as well as all witnesses indicated therein. All blank spaces for Bid prices must be filled in, in ink or typewritten, in both words and figures.

Each Bid must be submitted in a sealed envelope bearing on the outside the name of the Bidder, the Bidder's address, and the name and number of the project for which the Bid is submitted. If forwarded by mail, the sealed envelope containing the Bid must be enclosed in another envelope addressed as specified in the Bid form.

3. PRE-BID MEETING

A pre-bid conference will not be held for this project.

4. FACSIMILE BIDS OR MODIFICATIONS

No facsimile ("FAX") Bids or bid modifications will be accepted. Any modifications to the Bid shall be made by an authorized representative of the bidding company in person.

5. QUALIFICATIONS OF BIDDER

The Owner may make such investigations as he deems necessary to determine the qualifications of and the ability of the Bidder to perform the Work, and the Bidder shall furnish the Owner such information and data for this purpose as the Owner may request.

The Owner may request that the Bidder provide a list of key people for the project with their related work experience.

The Owner reserves the right to reject any Bid if the evidence submitted by or investigation of such Bidder fails to satisfy the Owner that such Bidder is properly qualified to carry out the obligations of the Contract and to complete the work contemplated therein in a timely manner. Conditional Bids will not be accepted.

All Bidders and listed subcontractors must be valid Arizona Licensed Contractors at the time of Bidding, approved by the Arizona State Registrar of Contractors to do the type and amount of work specified in these documents. In accordance with the Arizona State Registrar of Contractors, the Bidder must possess a minimum of a Class A Arizona Contractor's License to perform the type and amount of work specified in these documents. **Failure of any bidder to possess all contractors' licenses as listed in the bid packet, at the time of bidding, shall result in the bid being considered non-responsive and not in substantial compliance, and any such bid shall not be considered.** Refer to Section 00420, page 3, item 13.

6. ARITHMETIC DISCREPANCIES IN THE BID

- A. For the purpose of the evaluation of Bids, the following will be utilized in resolving arithmetic discrepancies found on the face of the Bid Schedule as submitted by Bidders:
1. Obviously misplaced decimal points will be corrected;
 2. In case of discrepancy between unit price and extended price, the unit price will govern;
 3. Apparent errors in extension of unit prices will be corrected;
 4. Apparent errors in addition of lump sums and extended prices will be corrected; and
 5. In case of discrepancy between words and figures in unit prices, the amount shown in words shall govern.

- B. For the purpose of Bid evaluation, the Owner will evaluate the bids on the basis of the unit prices, extensions, and totals arrived at by resolution of arithmetic discrepancies as provided above.

7. INCOMPLETE BIDS

Failure to submit a Bid on all items in the Schedule will result in an incomplete Bid and the Bid may be rejected. **UNIT OR LUMP SUM PRICES MUST BE SHOWN FOR EACH BID ITEM WITHIN THE SCHEDULE.**

NOTE: FAILURE TO INDICATE UNIT OR LUMP SUM PRICES IN THE APPROPRIATE COLUMN, WITH THE EXTENSION OF THE PRICES IN THE FAR RIGHT COLUMN, WILL CAUSE THE BID TO BE "NON-RESPONSIVE".

All forms indicated in the Bid Proposal, Section 00300, must be completely filled out, executed, and submitted with the Bid. Failure to do so will render the bid "non-responsive" and the bid will not be accepted.

8. BID SECURITY

Each Bid must be accompanied by certified check, cashier's check, or a Bid Bond prepared on the form attached hereto or on a similar form acceptable to the Owner, duly executed by the Bidder as principal and having as surety thereon a surety company approved by the Owner, in the amount of ten percent (10%) of the Bid. Bid Bonds shall be valid for at least ninety (90) days after the date of the receipt of Bids. Such cash, check, or Bid Bond will be returned to all except the three (3) lowest Bidders within fifteen (15) business days after the opening of Bids. The remaining checks, or Bid Bonds will be returned promptly after the Owner and the accepted Bidder have executed the Contract, or if no award has been made within ninety (90) days after the date of the opening of Bids, upon demand of the Bidder at any time thereafter, so long as he has not been notified of the acceptance of his Bid.

9. LIQUIDATED DAMAGES FOR FAILURE TO ENTER INTO CONTRACT

The successful Bidder, upon his failure or refusal to execute and deliver the Contract, Bonds, and certificates required within ten (10) calendar days from the date of the Notice of Award, shall forfeit to the Owner, as liquidated damages for such failure or refusal, the difference between his bid and the amount of the contract actually entered into with another party should he not enter into a contract at the bid price and provide the required payment and performance bonds and certificates of insurance. Liquidated damages for failure to enter into the contract shall not exceed the amount of the Bid Bond.

10. **SECURITY FOR FAITHFUL PERFORMANCE AND PAYMENT**

Simultaneously with his delivery of the executed Contract, the Bidder shall furnish **on the forms provided herein**, in 100% of the amount of this Contract, 1) a surety bond as security for faithful performance of this Contract, and 2) a surety bond as security for the payment of all persons performing labor on the project under this Contract and persons furnishing materials in connection with this Contract, and 3) a listing of all subcontractors who will be performing or providing more than one-half percent (0.50%) of the contract work, as specified in the General Conditions included herein. The surety on such bond or bonds shall be a duly authorized surety company satisfactory to the Owner, listed on the Treasury Department's most current list (Circular 570 as amended), and authorized to transact business in the State of Arizona.

11. **POWER OF ATTORNEY**

Attorneys-in-fact who sign Bid Bonds or Contract bonds must file with each bond a certified and effectively dated copy of their power-of-attorney.

12. **LAWS AND REGULATIONS**

The Bidder's attention is directed to the fact that all applicable Federal Laws, State Laws, municipal ordinances, and the rules and regulations of all authorities having jurisdiction over construction of the project shall apply to the Contract throughout, and they will be deemed to be included in the Contract the same as though herein written out in full.

13. **METHOD OF AWARD**

- A. The City will award the Contract on the basis of the Bid or Bids most advantageous to the City. In determining whether a Bid is most advantageous, in addition to price, the City may consider the following:
1. The ability, capacity, and skill of the Bidder to perform the Contract or provide the service indicated;
 2. Whether the Bidder can perform the Contract or provide the service promptly, and within the time specified without delay or interference;
 3. The character, integrity, reputation, judgment, experience, and efficiency of the Bidder;
 4. The quality of performance on previous contracts;
 5. The previous compliance with laws and ordinances by the Bidder;

6. The financial responsibility of the Bidder to perform under the Contract or provide the service;
7. The limitations of any license the Bidder may be required to possess;
8. The quality, availability, and adaptability of the product or service;
9. The ability of the Bidder to provide future maintenance and/or service;
10. The number and scope of any conditions attached to the Bid; and;
11. The life cycle, maintenance, and performance of the equipment or product being offered.

14. OBLIGATION OF THE BIDDER

At the time of the opening of Bids, each Bidder will be presumed to have inspected the site and to have read and to be thoroughly familiar with the Plans and Contract documents (including all Addenda, if applicable). The failure or omission of the Bidder to examine any form, instrument or document, or site changes due to natural causes, shall in no way relieve any Bidder from any obligation in respect to his Bid. Site changes due to natural causes prior to Bid opening shall not be cause for Bid alteration or withdrawal.

15. TIME OF COMPLETION AND LIQUIDATED DAMAGES

The Bidder must agree to commence work on or before a date to be specified in a written "Notice to Proceed" from the Owner, and to complete the work within **270 calendar days** of the date of the Notice to Proceed.

The Bidder further agrees to pay as liquidated damages, the sum indicated in the following Schedule of Liquidated Damages for each consecutive calendar day thereafter, plus any additional costs incurred by the Engineer as provided in Section 17 of the General Conditions, that the Contract remains incomplete. For the purposes of determining the Liquidated Damages for the project, the Original Contract Amount shall be that which is included in the Contract between the Owner and the Contractor for the project.

SCHEDULE OF LIQUIDATED DAMAGES		
Original Contract Amount		Daily Charges
From More Than	To and Including	Calendar Day or Fixed Rate
0	25,000	210
25,000	50,000	250
50,000	100,000	280
100,000	500,000	430
500,000	1,000,000	570
1,000,000	2,000,000	710
From More Than	To and Including	Calendar Day or Fixed Rate
2,000,000	5,000,000	1,070
5,000,000	10,000,000	1,420
10,000,000	---0---	1,780

16. CONDITIONS OF WORK

Each Bidder must inform himself fully of the conditions relating to the construction of the project and the employment of labor thereon. Failure to do so will not relieve a successful Bidder of his obligation to furnish all material and labor necessary to carry out the provisions of his Contract. Insofar as possible, the Contractor, in carrying out his work, must employ such methods or means as will not cause any interruption of or interference with the work of any other Contractor.

17. ADDENDA AND INTERPRETATIONS

All questions that arise relating to this solicitation shall be directed in writing to:

Kim Fiumara
fiumarak@lhcaz.gov
Community Investment Department
Lake Havasu City
2330 McCulloch Blvd. North
Lake Havasu City, AZ 86403

To be considered, written inquiries shall be received by the above-referenced contact by **September 21, 2016, 4:00 PM**, Arizona Time. Inquiries received will then be answered in an Addendum. Any and all such interpretations and any supplemental instructions will be in the form of written Addenda to the Specifications which, if

issued, will be available to all prospective Bidders, not later than five (5) calendar days prior to the date fixed for the opening of Bids. Failure of any Bidder to incorporate any such Addendum or interpretation shall not relieve such Bidder from any obligation under his/her Bid as submitted. All Addenda so issued shall become part of the Contract documents.

No informal contact initiated by offerors on this solicitation will be allowed with members of City staff from the date of distribution of this solicitation until after the closing date and time for the submissions of quotations. All questions or issues related to this solicitation shall be submitted in writing.

18. CONFLICT OF INTEREST

Pursuant to A.R.S. Section 38-511, this Contract is subject to cancellation by Buyer if any person significantly involved initiating, negotiating, securing, drafting or creating the Contract on behalf of Lake Havasu City is, at any time while the Contract is in effect, an employee of any other party to the Contract in any capacity or a consultant to any other party of the Contract with respect to the subject matter of the Contract.

19. NO COLLUSION

The bidder will be required to complete, notarize and submit as part of this bid package the "No Collusion Affidavit" form, as attached herein. Failure of the bidder to submit a properly executed affidavit may be grounds for rejection of the bid.

20. EMPLOYMENT ELIGIBILITY VERIFICATION

The bidder will be required to complete, notarize and submit as part of this bid package the "Employer Verification of Employment Eligibility" form, as attached herein. Failure of the bidder to submit a properly executed verification of eligibility form may be grounds for rejection of the bid.

21. EXAMINATION OF THE PLANS AND SPECIFICATIONS

Each Bid shall be made in accordance with the Plans and Specifications which may be examined at the following locations:

- A. Lake Havasu City, 2330 N. McCulloch Boulevard, Lake Havasu City, AZ 86403, 928.855.2116
- B. Dodge Data & Analytics, 3315 Central Avenue, Hot Springs, AR, 71913, 871.375.2946, FAX 501.625.3544, nancy_mckeehan@mcgraw-hill.com
- C. Colorado River Building Industry Association, 2182 McCulloch Blvd, Suite 3, Lake Havasu City AZ 86403, 928.453.7755, FAX 928.453.3175

- D. Northern AZ Home Builders, 1500 E. Cedar Avenue, Suite 86, Flagstaff AZ 86004, 928.779.3071, FAX 928.779.4211
- E. Performance Graphics Blueprinting, 4140 Lynn Drive, Suite 107, Fort Mohave, AZ, 86426, 928.763.6860, FAX 928.763.6835
- F. Reed Construction Data, 30 Technology Parkway South, Suite 500, Norcross, GA 30092-2912, 800.876.4045, FAX 800.303.8629
- G. ISqFt, 3301 N 24th Street, Phoenix, AZ, 85016, 800.364.2059, FAX 800.792.7508, arizonaplanroom@isqft.com
- H. Integrated Digital Technologies, LLC, 4633 E Broadway Blvd., Tucson, AZ 85711,
PO Box 13086, Tucson AZ 85732, 520.319.0988,
FAX, 520.319.1430, www.contractorsplanroom.com, content@idtplans.com
- I. Yuma/Southwest Contractors Association, 350 W. 16th Street, Suite 207, Yuma, AZ 85364, Phone: 928-539-9035, Fax: 928-539-9036
- J. Arizona Builders Exchange, 1700 N. McClintock Drive, Tempe, AZ, 85281, (480) 227-2620, www.azbex.com
- K. Construction Reports.com, 4110 N Scottsdale Road, Suite 335, Scottsdale, AZ, 85251, (480) 994-0020, FAX 480-994-0030
- L. Construction Reporter, 1609 2nd Street NW, Albuquerque, NM, 87102, 505-243-9793, FAX 505-242-4758, www.constructionreporter.com
- M. PlanRoom Central at A&E Reprographics, 1030 Sandretto Drive, Suite F, Prescott, AZ, 86305, 928.442.9116, planroom1@a-erepro.com

** END OF SECTION **

SECTION 00300
BID PROPOSAL

Lake Havasu City, Arizona

The undersigned, as bidder, declares that we have received and examined the documents entitled **Water Conservation Program Implementation Package No. 2, Project No. SS2970**" and will contract with the Owner, on the form of Contract provided herewith, to do everything required for the fulfillment of the contract for the construction of the **Water Conservation Program Implementation Package No. 2, Project No. SS2970** at the prices and on the terms and conditions herein contained.

We agree that the Contract Documents include Volumes I and II of the Contract Documents as well as the referenced documents.

We agree that the following shall form a part of this proposal and are included herein as our submittal:

<u>Section</u>	<u>Title</u>	<u>Enclosed</u>
00300	Bid Proposal	✓ _____
00310	Bid Schedule	_____
00400	Arizona Statutory Bid Bond	_____
00420	Bidder's Statement of Qualifications	_____
00430	Affidavit of Contractor Certifying That There Was No Collusion In Bidding For Contract	_____
00450	Hazard Communication Program	_____

We acknowledge that addenda numbers _____ through _____ have been received and have been examined as part of the Contract Documents.

We certify that our proposal is genuine, and not sham or collusive, nor made in the interest or behalf of any undisclosed person, organization, or corporation, and that we have not directly or indirectly induced or solicited any other bidder to put in a sham bid, or directly or indirectly induced or solicited any other potential bidder to refrain from bidding, and that we have not in any manner sought by collusion to secure an advantage over any other bidder.

The bidder agrees that this Bid shall be good and may not be withdrawn for a period of ninety (90) calendar days after the scheduled closing time for receiving Bids.

Upon receipt of written notice of the acceptance of this bid, Bidder shall execute the formal Contract attached within 10 days and deliver a Performance Bond, Payment Bond, and Certificates of Insurance as required by Paragraph 25 of the General Conditions and the Special Provisions.

We hereby declare that we have visited the site and have carefully examined the Contract Documents relating to the work covered by the above bid or bids.

Enclosed herewith is a certified or cashier's check or bid bond, payable to Lake Havasu City, Arizona, in the amount of ten percent (10%) of the total bid. This check or bond is submitted as a guarantee that we will enter into a Contract, and furnish the required bonds in the event a contract is awarded us. The bid security attached, without endorsement, is to become the property of Lake Havasu City, Arizona, in the event the Contract and Bonds are not executed within the time set forth, as liquidated damages for delay and additional work caused thereby.

We understand that Lake Havasu City, Arizona reserves the right to reject any and/or all bids, or to waive any informalities in any bid, deemed by them to be for the best interests of Lake Havasu City, Arizona.

Dated in _____ this _____ day of _____, ____.

Respectfully Submitted By:

By: _____

Title: _____

Name of Firm: _____

Address: _____

Phone: _____ FAX: _____

Seal - If bid by a Corporation:

Arizona Contractor's License No.: _____ Type: _____

** END OF SECTION **

SECTION 00310

BID SCHEDULE
LAKE HAVASU CITY

Water Conservation Program Implementation Package No. 2
Project No. SS2970

Lake Havasu City Council
Lake Havasu City
2330 N. McCulloch Boulevard
Lake Havasu City, AZ 86403

The City Council:

Pursuant to request for bids to be opened the 28th day of September, 2016 at 3:00 P.M., Arizona Time, at Room 109 of Lake Havasu City Hall, for the above project, the Contractor proposes to complete work, including furnishing all labor and materials, per the Specifications and Plans at the Following prices.

This Schedule of Items and Prices shall be completed in ink or typed by the Bidding Contractor. In case of discrepancy between the word and figure amount description, the word description shall control extensions.

Prices must be entered for each item and the appropriate subtotal and total blank shall be filled out. Bid prices shall include sales tax and all other applicable taxes and fees.

Bidder agrees to perform all the necessary work to complete the **Water Conservation Program Implementation Package No. 2, Project No. SS2970**. See Section 01210, Measurement and Payment, for descriptions of Bid Items listed in Section 00310.

Revised 3/14/12
Water Conservation Program Implementation, Package No. 2

00310-1

August 2016
Project SS2970

SECTION 00310

<u>ITEM NO.</u>	<u>DESCRIPTION</u>	<u>ESTIMATED QUANTITY</u>	<u>UNIT OF MEASURE</u>	<u>UNIT PRICE ¹ (Word & Figure Amount)</u>	<u>ITEM TOTAL COSTS ²</u>
BASE BID					
2.2.1	Mobilization, Demobilization, Bonds, and Insurance	1	L.S.	\$ _____	\$ _____
2.2.2	Construction Staking	1	L.S.	\$ _____	\$ _____
2.2.3	Location A Connections - W Acoma Blvd-Industrial Blvd	1	L.S.	\$ _____	\$ _____
2.2.4	Location B Connections - Paseo Del Sol	1	L.S.	\$ _____	\$ _____
2.2.5	Location C Connections - S Palo Verde Blvd	1	L.S.	\$ _____	\$ _____

¹ The "Unit Price" column shall indicate unit or lump sum prices for each bid item and shall be indicated in written and numerical form.

² The "Item Total Costs" column shall indicate the extension of the unit prices, which is obtained by multiplying the "Estimated Quantity" column by the "Unit Price" column.

SECTION 00310

2.2.6	Location D Connections - McCulloch Blvd N-Swanson Ave	1	L.S.	\$ _____	\$ _____
2.2.7	Location E Connection - S Smoketree Ave	1	L.S.	\$ _____	\$ _____
2.2.8	Location F Connection - Lake Havasu City Aquatic Center	1	L.S.	\$ _____	\$ _____
2.2.9	Location G Connection - Walnut Dr	1	L.S.	\$ _____	\$ _____
2.2.10	Location G Connection - Walnut Dr Electrical and Instrumentation	1	L.S.	\$ _____	\$ _____
2.2.11	Location H Connections - Cypress Park	1	L.S.	\$ _____	\$ _____
2.2.12	Location I Connections - ASU Campus	1	L.S.	\$ _____	\$ _____
2.2.13	Location J Connections - Jack Hardie Park	1	L.S.	\$ _____	\$ _____
2.2.14	Mulberry WWTP Hydropneumatic Tank	1	L.S.	\$ _____	\$ _____

SECTION 00310

2.2.15	Mulberry WWTP Hydropneumatic Tank Installation	1	L.S.	\$ _____	\$ _____
2.2.16	Mulberry WWTP Hydropneumatic Tank Electrical and Instrumentation	1	L.S.	\$ _____	\$ _____
2.2.17	Mulberry WWTP Hydropneumatic Tank System Integration	1	L.S.	\$ _____	\$ _____
2.2.18	Island WWTP Reuse Package Booster Pump Station	1	L.S.	\$ _____	\$ _____
2.2.19	Island WWTP Reuse Package Booster Pump Station Installation	1	L.S.	\$ _____	\$ _____
2.2.20	Island WWTP Reuse Package Booster Pump Station Electrical and Instrumentation	1	L.S.	\$ _____	\$ _____
2.2.21	Island WWTP Reuse Package Booster Pump Station System Integration	1	L.S.	\$ _____	\$ _____

SECTION 00310

2.2.22	18-inch Reuse Line Motor Operated Valves and Valve Vaults at Smoketree and AZ 95	1	L.S.	\$ _____	\$ _____
2.2.23	18-inch Reuse Line Motor Operated Valves and Valve Vaults at Smoketree and AZ 95 Electrical and Instrumentation	1	L.S.	\$ _____	\$ _____
2.2.24	18-inch Reuse Line Motor Operated Valves and Vaults at Smoketree and AZ 95 System Integration	1	L.S.	\$ _____	\$ _____
2.2.25	Oak Drive Line Motor Operated Valve and Valve Vault from Mulberry WWTP	1	L.S.	\$ _____	\$ _____
2.2.26	Environmental Control Measures	1	L.S.	\$ _____	\$ _____
2.2.27	Dye Testing	1	L.S.	\$ _____	\$ _____

SECTION 00310

2.2.28	All Other Work Not Included in Items 2.2.1 through 2.2.27	1	L.S.	\$ _____	\$ _____
2.2.29	Force Account	1	L.S.	\$ <u>20,000</u> Twenty Thousand Dollars and no cents	\$ <u>20,000</u>

BID TOTAL + FORCE ACCOUNT \$ _____

The unit prices for **Water Conservation Program Implementation Package No. 2, Project No. SS2970** shall include all labor, materials, water disposal, bailing, shoring, removal, disposal, overhead, profit, insurance, and all other related costs and work to cover the finished work of the several kinds called for. Changes in the Contract shall be processed in accordance with Paragraph 16 of the General Conditions.

Bidder understands that the Owner reserves the right to reject any or all Bids, or portions thereof, and to waive any informalities in the bidding.

The Bidder agrees that this Bid shall be good and may not be withdrawn for a period of ninety (90) calendar days after the scheduled closing time for receiving Bids.

Upon receipt of written notice of the acceptance of this Bid, Bidder shall execute the formal Contract attached within 10 days and deliver a Performance Bond, Payment Bond, and Certificates of Insurance as required by Paragraph 25 of the General Conditions and the Special Provisions.

The Bid security attached in the sum of \$ _____ is to become the property of the Owner in the event the Contract and Bond(s) are not executed and provided within the time above set forth, as liquidated damages for the delay and additional expense to the Owner caused thereby.

Bidder hereby acknowledges receipt of the following Addenda: ____, ____, ____.

RESPECTFULLY SUBMITTED BY:

BY: _____

TITLE: _____

FIRM: _____

ADDRESS: _____

PHONE: _____ FAX _____

Seal - if Bid by a corporation

AZ Contractor's License No: _____ Type _____

** END OF SECTION **

SECTION 00400
ARIZONA STATUTORY BID BOND

PURSUANT TO TITLES 28, 34 AND 41, ARIZONA REVISED STATUTES
(Penalty of this bond must not be less than 10% of the bid amount)

KNOW ALL MEN BY THESE PRESENTS:

That, _____(hereinafter "Principal"), as Principal, and _____, (hereinafter "Surety"), a corporation organized and existing under the laws of the State of _____, with its principal offices in the City of _____, holding a certificate of authority to transact surety business in Arizona issued by the Director of the Department of Insurance pursuant to Title 20, Chapter 2, Article 1, as Surety, are held and firmly bound unto Lake Havasu City, Arizona, (hereinafter "Obligee"), as Obligee, in the amount of Ten Percent (10%) of the amount of the bid of Principal, submitted by Principal to the Obligee for the work described below, for the payment of which sum, the Principal and Surety bind themselves, and their heirs, administrators, successors and assigns, jointly and severally, firmly by these presents.

WHEREAS, the Principal has submitted a bid for **Water Conservation Program Implementation Package No. 2, Project No. SS2970**

NOW, THEREFORE, if the Obligee shall accept the proposal of the Principal and the Principal shall enter into a contract with the Obligee in accordance with the terms of the proposal and give the bonds and certificates of insurance as specified in the standard specifications with good and sufficient surety for the faithful performance of the contract and for the prompt payment of labor and materials furnished in the prosecution of the contract, or in the event of the failure of the Principal to enter into the contract and give the bonds and certificates of insurance, if the Principal pays to the Obligee the difference not to exceed the penalty of the bond between the amount specified in the proposal and such larger amount for which the Obligee may in good faith contract with another party to perform the work covered by the proposal then this obligation is void. Otherwise it remains in full force and effect provided, however, that this bond is executed pursuant to the provisions of Section 34-201, Arizona Revised Statutes, and all liabilities on this bond shall be determined in accordance with the provisions of that section to the extent as if it were copied at length herein.

Witness our hands this ____ day of _____, _____.

PRINCIPAL

SEAL

SURETY

SEAL

By: _____ By: _____
Attorney-in-Fact

Its: _____
Agency of Record

Agency Address

** END OF SECTION **

SECTION 00420
BIDDER'S STATEMENT OF QUALIFICATIONS

The Undersigned certifies the truth and correctness of all statements and of all answers to questions made hereinafter.

SUBMITTED TO: Lake Havasu City, Arizona
2330 N. McCulloch Boulevard
Lake Havasu City, AZ 86403

SUBMITTED BY: NAME: _____ Corporation Partnership
ADDRESS: _____ Individual Joint Venture
PRINCIPAL OFFICE: _____ Other

(NOTE: Attach separate sheets as required)

1. How many years has your organization been in business as a Contractor? _____
2. How many years has your organization been in business under its present business name? _____
3. If a Corporation, answer the following:
Date of Incorporation: _____
State of Incorporation: _____
President: _____
Vice President(s): _____
Secretary: _____
Treasurer: _____
4. If a Partnership, answer the following:
Date of organization: _____
Type of Partnership: _____
(General/Limited/Assoc.)
Name and Address of all partners.

5. If other than a Corporation or Partnership, describe Organization and name Principals:

6. What percent of the work do you normally perform with your own forces?

List trades:

7. Have you ever failed to complete any work awarded to you? If so, indicate when, where and why:

8. Has any Officer or Partner of your Organization ever been an Officer or Partner of another Organization that failed to complete a construction contract? _____ If so, state circumstances:

9. List major construction projects your Organization has under contract on this date:

Project Name	Name, Email Address & Telephone Number of Owner	Project Location	Contract Amount	Contract Date	Percent Complete	Scheduled Completion

10. List similar construction projects your Organization has completed in the past five years:

Project Name	Name, Email Address & Telephone Number of Owner	Project Location	Contract Amount	Date Awarded	Date Completed	Percent with Own Forces

11. List the construction experience of the principal individuals in your Organization:

Individual's Name	Construction Experience - Years	Within Your Organization		
		Present Position & Years Experience	Dollar Volume Responsibility	Previous Position & Years Experience

12. List states and categories in which your Organization is legally qualified to do business:

13. List all Arizona Contractor licenses currently held by your Organization; the status of each license; and provide a photocopy of each license with your bid proposal.

	<u>License Class / #</u>	<u>Status</u>
1.	_____	_____
2.	_____	_____
3.	_____	_____
4.	_____	_____

Please attach a list of additional Arizona Contractor licenses, if any.

14. Bank References:

15. Trade References:

16. Name of Bonding and Insurance Companies and Name and Address of Agents: Maximum Bonding Capacity _____

17. The Undersigned agrees to furnish, upon request by the Owner, within seven days after the Bid Opening, a current Statement of Financial Conditions, including Contractor's latest regular dated financial statement or balance sheet which must contain the following items:

Current Assets: (Cash, joint venture accounts, accounts receivable, notes receivable, accrued interest on notes, deposits, and materials and prepaid expenses), net fixed assets and other assets.

Current Liabilities: (Accounts payable, notes payable, accrued interest on notes, provision for income taxes, advances received from owners, accrued salaries, accrued payroll taxes), other liabilities, and capital (capital stock, authorized and outstanding shares par values, earned surplus).

Date of statement or balance sheet: _____

Name of firm preparing statement: _____

By: _____

(Agent and Capacity)

THIS PAGE INTENTIONALLY LEFT BLANK

** END OF SECTION **

SECTION 00450
HAZARD COMMUNICATION PROGRAM
Lake Havasu City

HAZARD COMMUNICATION PROGRAM FOR _____
(Name of Company)

The purpose of this program is to ensure that potential hazards and hazard control measures for chemicals used by this company are understood by company employees.

The written program is available for employee review at any time. It is located _____ . A copy of the program will be provided to any employee or employee representative, upon request.

CONTAINER LABELING:

_____ will verify that all containers received for use by this company will: (name/title of individual)

- * be clearly labeled as to the contents, matching identification on MSDS;
- * note the appropriate hazard warnings;
- * List the name and address of the manufacturer.

No containers will be released for use until the above data is verified.

MATERIAL SAFETY DATA SHEETS:

Copies of MSDS's for all hazardous chemicals to which employees may be exposed will be kept

_____ will be responsible for ensuring that:
(name/title of individual)

- * MSDS's for the new chemicals are available;
- * MSDS's will be available for review to all employees during each work shift;
- * Copies will be available on request.

EMPLOYEE TRAINING AND INFORMATION:

Each employee will be provided the following information and training before working in areas where hazardous chemicals exist. In addition, if a new hazardous material is introduced into the workplace, affected employees will be given new information and training concerning that material.

A. Minimum Information Provided:

- (1) All operations and locations in the work area where hazardous chemicals are present.

GENERAL INDUSTRY

A. Minimum Information Provided:

- (1) The location and availability of the written hazard communication program, including list(s) of hazardous chemicals used and related material safety data sheets;
- (2) The method the company will use to inform employees of potential hazards of non-routine tasks (jobs that are not routine for an individual because of infrequency, location or type.)

B. Minimum Training Provided:

- (1) Methods and observations used to detect the presence or release of a hazardous chemical in the work area (such as company monitoring programs, continuous monitoring device, visual appearance, odor or to other characteristics of hazardous chemicals;
- (2) The physical and health hazards of chemicals in the assigned work area;
- (3) The measures to take to protect against such hazards, including specific company procedures concerning work practices, emergencies and care and use of protective equipment.
- (4) Details of the company hazard communication program, including explanation of the labeling system, the material safety data sheets, and how to obtain and use the appropriate hazard information.

(OPTIONAL) Upon completion of the training, each employee will sign a form acknowledging receipt of the written hazard communication program and related training.

HAZARDOUS NON-ROUTINE TASKS: (If applicable.)

If company employees are required to do hazardous non-routine tasks, such as welding in confined spaces, or cleaning of tanks, the employer must address how the employees doing the work will be informed about the specific hazards to which they will be exposed, what personal protective equipment will be provided and who will be responsible to oversee the operation or operations. If the company does not have any hazardous non-routine tasks, line through this section and state "NO HAZARDOUS NON-ROUTINE TASKS".

CHEMICALS IN UNLABELED PIPES: (If applicable.)

If the company has chemicals in unlabeled pipes, the company must inform the employees of the hazards associated with those chemicals. If the company does not have any chemicals in unlabeled pipes, line through this section and state "NO CHEMICALS IN UNLABELED PIPES".

INFORMING CONTRACTORS:

Providing contractors and their employees with the following information is the responsibility of _____.
(Name/title of individual)

- (1) Hazardous chemicals to which they may be exposed while on the job site;
- (2) Measures the employees may take to lessen the possibility of exposure;
- (3) Steps the company has taken to lessen the risks;
- (4) Where the MSDS's are for chemicals to which they may be exposed;
- (5) Procedures to follow if they are exposed.

CONTRACTORS INFORMING EMPLOYERS:

Contractors entering this workplace with hazardous materials will supply this employer with MSDS's covering those particular products the contractor may expose this company's employees to while working at this site.

LIST OF HAZARDOUS CHEMICALS IN THIS WORKPLACE

CONTRACTOR:

By: _____

Name: _____

Title: _____

Address: _____

****END OF SECTION****

THIS PAGE INTENTIONALLY LEFT BLANK

SECTION 00460 EMPLOYMENT ELIGIBILITY VERIFICATION FORM

INSTRUCTIONS FOR COMPLETION OF EMPLOYMENT ELIGIBILITY VERIFICATION FORM

WHO MUST COMPLETE THIS FORM:

In accordance with Lake Havasu City Code Chapter 3.30, Employment of Unauthorized Aliens, all contractors and subcontractors furnishing labor, time, or effort for construction or maintenance of any structure, building, transportation facility, or improvements of real property must complete this form.

Contractors or subcontractors, as described above, must certify that they have complied, in good faith, with the applicable requirements of the Federal Immigration Control and Reform Act with respect to the hiring of covered employees. This certification must be executed by an authorized representative.

WHEN THIS FORM MUST BE COMPLETED:

This form must be completed by all contractors and subcontractors and submitted to the City department awarding the contract, license agreement, or lease no later than notification of successful direct selection, bid, request for proposals, request for qualification, or any similar competitive or noncompetitive procurement or bidding process.

This form can be found at:

<http://www.lhcaz.gov/docs/default-source/department-documents/employerverificationofemploymenteligibility.pdf>

THIS PAGE INTENTIONALLY LEFT BLANK

SECTION 00500
CONTRACT

THIS CONTRACT is entered into by and between LAKE HAVASU CITY, ARIZONA, a municipal corporation (hereinafter "OWNER"), and a(n) STATE corporation, **Federal I.D. # _____**, (hereinafter "CONTRACTOR").

WHEREAS, OWNER has developed plans for and desires to commence the Project Name, Project No. (hereinafter "PROJECT"); and

WHEREAS, CONTRACTOR represents that it possesses the experience, competence, equipment and financing to properly complete the PROJECT, and has formally proposed to do so, and to furnish all necessary labor, materials, and equipment and services therefore in accordance with said plans, and subject to the terms and conditions hereof.

NOW, THEREFORE, in consideration of these promises and the mutual covenants herein, it is hereby agreed as follows:

1. CONTRACTOR shall commence and complete the construction of the Project Name, Project No. ;
2. CONTRACTOR shall furnish all of the material, supplies, tools, equipment, labor and other services necessary for the construction and completion of the PROJECT.
3. CONTRACTOR shall commence the PROJECT in accordance with the CONTRACT DOCUMENTS within TEN (10) calendar days after the date of the Notice to Proceed. Final completion of the PROJECT shall occur within XXX calendar days of the date of the Notice to Proceed. The period for completion may be extended through the authorized and approved change order process.
4. Liquidated Damages: OWNER and CONTRACTOR recognize that time is of the essence of this CONTRACT and that OWNER will suffer financial loss if the PROJECT is not completed within the time specified in paragraph 3 above, plus any extensions thereof allowed in accordance with the General Conditions. They also recognize the delays, expense and difficulties involved in proving in a legal or arbitration proceeding the actual losses or damages (including special, indirect, consequential, incidental and any other losses or damages) suffered by OWNER if a complete acceptable PROJECT is not delivered on time.

Accordingly, and instead of requiring proof of such losses or damages, OWNER and CONTRACTOR agree that as liquidated damages for delay (but not as a penalty) CONTRACTOR shall pay the OWNER \$ for each calendar day that expires after the time specified in paragraph 3 for delivery of acceptable Bid Items, plus any costs incurred by the Engineer as provided in Section 17 of the General Conditions.

Revised 7/20/16
Water Conservation Program Implementation, Package No. 2

00500-1

August 2016
Project SS2970

5. CONTRACTOR agrees to complete the PROJECT in accordance with all of the terms and conditions of the CONTRACT DOCUMENTS for the sum of \$_____ as shown in the Bid Schedule.

6. CONTRACTOR shall submit a completed Section 00450 entitled Hazard Communication Program with the executed copy of this CONTRACT.

7. The term "CONTRACT DOCUMENTS" means and includes the following:

- 00020 Notice Inviting Bids
- 00100 Information for Bidders
- 00300 Bid Proposal
- 00310 Bid Price Schedule
- 00400 Bid Bond
- 00420 Bidder's Statement of Qualifications
- 00430 Bidder's Affidavit of No Collusion
- 00450 Hazard Communication Program
- 00460 Employment Eligibility Verification
- 00500 CONTRACT
- 00500A Indemnification and Insurance Requirements
- 00500B Contractor Claim Handling Procedure
- 00510 Arizona Statutory Performance Bond
- 00520 Arizona Statutory Payment Bond
- 00670 Notice of Award
- 00680 Notice to Proceed
- 00685 Certificate of Substantial Completion
- 00690 Certificate of Final Completion
- 00700 General Conditions
- 00800 Special Provisions
- Technical Specifications and Details
- Construction Contract Drawings
- Change Orders
- Lien Releases (Conditional and Final)
- Addenda

8. OWNER shall pay CONTRACTOR in the manner and at such times as set forth in the General Conditions and in such amounts as required by the CONTRACT DOCUMENTS.

9. In the event CONTRACTOR fails to perform any portion of the PROJECT or satisfy any term or condition of the CONTRACT DOCUMENTS, OWNER may at its sole discretion file notice and/or claim of such failure with CONTRACTOR'S surety.

10. Israel. [CONTRACTOR] certifies that it is not currently engaged in, and agrees for the duration of this [Contract] that it will not engage in, a boycott of Israel, as

that term is defined in A.R.S. § 35-393.

11. Export Administration Act. The CONTRACTOR warrants compliance with the Export Administration Act.

12. Recyclable Products. The CONTRACTOR shall use recyclable products and products which contain recycled content to the maximum extent economically feasible in the performance of the work set forth in the CONTRACT.

13. Asbestos License. The CONTRACTOR shall possess an asbestos abatement license if required under A.R.S. Title 32 or 49.

14. Assignment. No right or interest in this CONTRACT shall be assigned by CONTRACTOR without prior, written permission of the OWNER signed by the City Manager; and no delegation of any duty of CONTRACTOR shall be made without prior written permission of the OWNER signed by the City Manager. Any attempted assignment or delegation by CONTRACTOR in violation of this provision shall be a breach of this CONTRACT by CONTRACTOR.

[SIGNATURES ON FOLLOWING PAGE]

SAMPLE

IN WITNESS WHEREOF, the parties hereto have executed, or caused to be executed by their duly authorized officials, this CONTRACT in two (2) copies, each of which shall be deemed an original. The last date of signature shall be the effective date of this CONTRACT.

OWNER:

Lake Havasu City, Arizona

By: _____

Date: _____

Name: _____

Title: _____

APPROVED AS TO FORM:

Lake Havasu City Attorney's Office

By: _____

Date: _____

CITY ENGINEER:

By: _____

Date: _____

ADMINISTRATIVE SERVICES:

By: _____

Date: _____

CONTRACTOR:

By: _____

Date: _____

Name/Title: _____

Address: _____

ATTEST:

BY: _____

Name/Title: _____

** END OF SECTION **

SECTION 00500A
LAKE HAVASU CITY CONSTRUCTION CONTRACT
INDEMNIFICATION AND INSURANCE REQUIREMENTS
(long form)

I. INDEMNIFICATION

Contractor shall indemnify and hold harmless City, its officers, employees and volunteers from and against any and all liabilities, damages, losses, and costs, including reasonable attorney's fees, but only to the extent caused by the negligence, recklessness, or intentional wrongful conduct of Contractor or other persons employed or used by the Contractor in the performance of this Contract. It is agreed that Contractor will be responsible for primary loss investigation, defense, and judgment costs where this indemnification is applicable.

II. INSURANCE REQUIREMENTS

A. CONTRACTOR and its subcontractors shall procure and maintain until all of their obligations have been discharged, including any warranty periods under this CONTRACT, are satisfied, insurance against claims for injury to persons or damage to property which may arise from or in connection with the performance of the work hereunder by the CONTRACTOR, its agents, representatives, employees or subcontractors.

B. The insurance requirements herein are minimum requirements for this CONTRACT and in no way limit the indemnity covenants contained in this CONTRACT. City in no way warrants that the minimum limits contained herein are sufficient to protect the CONTRACTOR from liabilities that might arise out of the performance of the work under this CONTRACT by the CONTRACTOR, its agents, representatives, employees or subcontractors, and CONTRACTOR is free to purchase additional insurance.

C. MINIMUM SCOPE AND LIMITS OF INSURANCE: CONTRACTOR shall provide coverage with limits of liability not less than those stated below.

1. Commercial General Liability – Occurrence Form

Policy shall include bodily injury, property damage, personal injury and broad form contractual liability coverage.

a. General Aggregate	\$10,000,000
b. Products – Completed Operations Aggregate	\$10,000,000
c. Personal and Advertising Injury	\$1,000,000
d. Blanket Contractual Liability – Written and Oral	\$1,000,000
e. Fire Legal Liability	\$50,000
f. Each Occurrence	\$5,000,000

i. The policy shall be endorsed to include the following additional insured language: *“Lake Havasu City, its departments, agencies, boards, commissions, and its officers, officials, agents, volunteers and employees shall be named as additional insureds with respect to liability arising out of*

- i. In the event that the professional liability insurance required by this CONTRACT is written on a claims-made basis, CONTRACTOR warrants that any retroactive date under the policy shall precede the effective date of this CONTRACT; and that either continuous coverage will be maintained or an extended discovery period will be exercised for a period of two (2) years beginning at the time work under this CONTRACT is completed.
- ii. The policy shall cover professional misconduct or lack of ordinary skill for those positions defined in the Scope of Work of this CONTRACT.

5. Builders' Risk (Property) Insurance (Vertical Construction Only)

a. CONTRACTOR shall purchase and maintain, on a replacement cost basis Builders' Risk insurance in the amount of the initial CONTRACT amount as well as subsequent modifications thereto, including modifications through Change Order, for the entire work at the site. Such Builders' Risk insurance shall be maintained until final payment has been made or until no person or entity other than CITY has an insurable interest in the property required to be covered, whichever is earlier. This insurance shall include interests of CITY, CONTRACTOR and any tier of CONTRACTOR's subcontractors in the work during the life of the CONTRACT and course of construction, and shall continue until the work is completed and accepted by CITY. For new construction projects, CONTRACTOR agrees to assume full responsibility for loss or damage to the work being performed and to the buildings or structures under construction. For renovation construction projects, CONTRACTOR agrees to assume responsibility for loss or damage to the work being performed at least up to the full CONTRACT amount, unless otherwise required by the Contract documents or amendments thereto.

b. Builders' Risk insurance shall be on an all-risk policy form and shall also cover false work and temporary buildings or structures and shall insure against risk of direct physical loss or damage from external causes including debris removal, demolition occasioned by enforcement of any applicable legal requirements and shall cover reasonable compensation for architects' and engineers' services and expenses, and other "soft costs," required as a result of such insured loss.

c. Builders' Risk insurance must provide coverage from the time any covered property falls within CONTRACTOR's control and/or responsibility and continue without interruption during construction or renovation or installation, including any time during which covered property is being transported to the construction or installation site, and while on the construction or installation site awaiting installation. The policy will provide coverage while the covered premises or any part thereof is occupied. Builders' Risk insurance shall be primary and not contributory.

d. If the CONTRACT requires testing of equipment or materials or other similar operations, at the option of CITY, CONTRACTOR will be responsible for providing property insurance for these exposures under a Boiler Machinery insurance policy.

6. Contractor's Personal Property

CONTRACTOR and each of its subcontractors and suppliers shall be solely responsible for any loss or damage to its or their personal property and that of their employees and workers, including, without limitation, property or materials created or provided pursuant to this CONTRACT, any subcontract or otherwise, its or their tools, equipment, clothing, fencing, forms, mobile construction equipment, scaffolding, automobiles, trucks, trailers or semi-trailers including any machinery or apparatus attached thereto, temporary structures and uninstalled materials, whether owned, used, leased, hired or rented by CONTRACTOR or any subcontractor, consultant or supplier or employee or worker (collectively, "Personal Property"). CONTRACTOR and its subcontractors, consultants and suppliers, at its or their option and own expense, may purchase and maintain insurance for such Personal Property and any deductible or self-insured retention in relation thereto shall be its or their sole responsibility. Any such insurance shall be CONTRACTOR's and the subcontractors', suppliers' volunteers and employees' and workers' sole source of recovery in the event of loss or damage to its or their Personal Property. Any such insurance purchased and maintained by CONTRACTOR and any subcontractor, consultant or supplier shall include a waiver of subrogation as to Owner. CONTRACTOR waives all rights of recovery, whether under subrogation or otherwise, against all such parties for loss or damage covered by CONTRACTOR's property insurance. CONTRACTOR shall require the same waivers from all subcontractors and suppliers and from the insurers issuing property insurance policies relating to the Work or the Project purchased and maintained by all subcontractors and suppliers. The waivers of subrogation referred to in this subparagraph shall be effective as to any individual or entity even if such individual or entity (a) would otherwise have a duty of indemnification, contractual or otherwise, (b) did not pay the insurance premium, directly or indirectly, and (c) whether or not such individual or entity has an insurable interest in the property which is the subject of the loss or damage.

7. Theft, Damage, or Destruction of Work

In the event of theft, damage or destruction of the Work, CONTRACTOR will re-supply or rebuild its Work without additional compensation and will look to its own resources or insurance coverages to pay for such re-supply or rebuilding. CONTRACTOR will promptly perform, re-supply or rebuild, regardless of the pendency of any claim by CONTRACTOR against any other party, including Owner, that such party is liable for damages, theft or destruction of CONTRACTOR's Work. This subparagraph shall apply except to the extent that the cost of re-supply or rebuilding is paid by Owner's builder's risk insurance; in such event, Owner waives (to the fullest extent permitted by the builder's risk policy) all

rights of subrogation against CONTRACTOR and each of its subcontractors to the extent of such payment by Owner's builder's risk insurer.

- D. ADDITIONAL INSURANCE REQUIREMENTS: The policies shall include, or be endorsed to include, the following provisions:
1. Lake Havasu City, its departments, agencies, boards, commissions and its officers, officials, agents, volunteers and employees wherever additional insured status is required. Such additional insured shall be covered to the full limits of liability purchased by the CONTRACTOR, even if those limits of liability are in excess of those required by this CONTRACT.
 2. The Contractor's insurance coverage shall be primary insurance with respect to all other available sources.
 3. Coverage provided by the Contractor shall not be limited to the liability assumed under the indemnification provisions of this CONTRACT.
- E. NOTICE OF CANCELLATION: Each insurance policy required by the insurance provisions of this CONTRACT shall not be suspended, voided, cancelled, reduced in coverage or in limits without ten (10) business days written notice to City. Such notice shall be mailed directly to Lake Havasu City, Community Investment Department, Procurement Division, 2330 McCulloch Blvd. North, Lake Havasu City, AZ 86403 and shall be sent by certified mail, return receipt requested.
- F. ACCEPTABILITY OF INSURERS: Insurance is to be placed with duly licensed or approved non-admitted insurers in the state of Arizona with an "A.M. Best" rating of not less than A- VII. CITY in no way warrants that the above-required minimum insurer rating is sufficient to protect the CONTRACTOR from potential insurer insolvency.
- G. VERIFICATION OF COVERAGE:
1. CONTRACTOR shall furnish CITY with certificates of insurance as required by this CONTRACT. The certificates for each insurance policy are to be signed by a person authorized by that insurer to bind coverage on its behalf and the Project/contract number and project description shall be noted on the certificate of insurance.
 2. All certificates and endorsements are to be received and approved by CITY at least ten (10) days before work commences. Each insurance policy required by this CONTRACT must be in effect at or prior to commencement of work under this CONTRACT and remain in effect for the duration of the Project. Failure to maintain the insurance policies as required by this CONTRACT, or to provide evidence of renewal, is a material breach of contract.
 3. All renewal certificates required by this CONTRACT shall be sent directly to Lake Havasu City, Community Investment Department, Procurement Division, 2330 McCulloch Blvd. North, Lake Havasu City, AZ 86403. The Project/contract number and project description shall be noted on the certificate of insurance. CITY

reserves the right to require complete, certified copies of all insurance policies required by this CONTRACT at any time.

- H. SUBCONTRACTORS: CONTRACTOR's certificate(s) shall include all subcontractors as insureds under its policies **or** CONTRACTOR shall furnish to CITY separate certificates and endorsements for each subcontractor. All coverages for subcontractors shall be subject to the minimum requirements identified above.
- I. APPROVAL: Any modification or variation from the insurance requirements in this CONTRACT must have prior approval from the CITY's Risk Management Division, whose decision shall be final. Such action will not require a formal CONTRACT amendment, but may be made by administrative action.
- J. EXCEPTIONS: In the event the CONTRACTOR or sub-contractor(s) is/are a public entity, then the Insurance Requirements shall not apply. Such public entity shall provide a Certificate of Self-Insurance.

Section 00500B
CONTRACTOR CLAIM HANDLING PROCEDURE

1. Claimant is to submit in writing to the OWNER or their REPRESENTATIVE the details of the claim to include the where, when, and how of the claim, and an estimate of damage, if applicable.
2. OWNER or their REPRESENTATIVE will forward the claim directly to the CONTRACTOR for handling. The CONTRACTOR is to respond to the claimant, in writing, within 30 calendar days of receipt with copies to:

Lake Havasu City Risk Management
Lake Havasu City Community Investment Department
OWNER'S REPRESENTATIVE, if applicable

If the CONTRACTOR denies the claim, the reasons for such denial must be included in the response to the claimant.

THIS PAGE INTENTIONALLY LEFT BLANK

SECTION 00510
ARIZONA STATUTORY PERFORMANCE BOND

PURSUANT TO TITLES 28, 34, AND 41, ARIZONA REVISED STATUTES
(Penalty of this bond must be 100% of the Contract amount)

KNOW ALL MEN BY THESE PRESENTS THAT: _____
(hereinafter "Principal"), as Principal, and _____
(hereinafter "Surety"), a corporation organized and existing under the laws of the State of _____
with its principal office in the City of _____, holding a certificate of authority
to transact surety business in Arizona issued by the Director of Insurance pursuant to Title 20,
Chapter 2, Article 1, as Surety, are held and firmly bound unto Lake Havasu City, Arizona
(hereinafter "Obligee") in the amount of _____ (Dollars) (\$ _____), for the
payment whereof, Principal and Surety bind themselves, and their heirs, administrators,
executors, successors and assigns, jointly and severally, firmly by these presents.

WHEREAS, the Principal has entered into a certain written contract with the Obligee,
dated the ___ day of _____, _____, to furnish all of the material, supplies, tools, equipment,
labor and other services necessary for the construction and completion of **Water
Conservation Program Implementation, Package No. 2, Project No. SS2970**, which
contract is hereby referred to and made a part hereof as fully and to the same extent as if
copied at length herein.

NOW, THEREFORE, THE CONDITION OF THE OBLIGATION IS SUCH, that if the
Principal faithfully performs and fulfills all of the undertakings, covenants, terms, conditions
and agreements of the contract during the original term of the contract and any extension of
the contract, with or without notice of the Surety, and during the life of any guarantee
required under the contract, and also performs and fulfills all of the undertakings, covenants,
terms, conditions and agreements of all duly authorized modifications of the contract that may
hereafter be made, notice of which modifications to the Surety being hereby waived, the
above obligation is void. Otherwise it remains in full force and effect.

PROVIDED, HOWEVER, that this bond is executed pursuant to the provisions of Title
34, Chapter 2, Article 2, Arizona Revised Statutes, and all liabilities on this bond shall be
determined in accordance with the provisions of Title 34, Chapter 2, Article 2, Arizona Revised
Statutes, to the same extent as if it were copied at length in this agreement.

The prevailing party in a suit on this bond shall recover as part of the judgment
reasonable attorney fees that may be fixed by a judge of the court.

Witness our hands this ____ day of _____, _____.

PRINCIPAL SEAL

AGENCY OF RECORD BY: _____

AGENCY ADDRESS SURETY SEAL

BY: _____

** END OF SECTION **

SECTION 00520
ARIZONA STATUTORY PAYMENT BOND

PURSUANT TO TITLES 28, 34, AND 41, ARIZONA REVISED STATUTES
(Penalty of this bond must be 100% of the Contract amount)

KNOW ALL MEN BY THESE PRESENTS THAT: _____
(hereinafter "Principal"), as Principal, and _____ (hereinafter Surety), a corporation organized and existing under the laws of the State of _____ with its principal office in the City of _____, holding a certificate of authority to transact surety business in Arizona issued by the Director of the Department of Insurance pursuant to Title 20, Chapter 2, Article 1, as Surety, are held and firmly bound unto Lake Havasu City, Arizona (hereinafter "Obligee") in the amount of _____(Dollars) (\$ _____), for the payment whereof, Principal and Surety bind themselves, and their heirs, administrators, executors, successors and assigns, jointly and severally, firmly by these presents.

WHEREAS, the Principal has entered into a certain written contract with the Obligee, dated the _____ of _____, _____, to furnish all of the material, supplies, tools, equipment, labor and other services necessary for the construction and completion of **Water Conservation Program Implementation, Package No. 2, Project No. SS2970**, which contract is hereby referred to and made a part hereof as fully and to the same extent as if copied at length herein.

NOW, THEREFOR, THE CONDITION OF THE OBLIGATION IS SUCH, that if the Principal promptly pays all monies due to all persons supplying labor or materials to the Principal or the Principal's subcontractors in the prosecution of the work provided for in the contract, this obligation is void. Otherwise it remains in full force and effect.

PROVIDED, HOWEVER, that this bond is executed pursuant to the provisions of Title 34, Chapter 2, Article 2, Arizona Revised Statutes, and all liabilities on this bond shall be determined in accordance with the provisions, conditions and limitations of Title 34, Chapter 2, Article 2, Arizona Revised Statutes, to the same extent as if it were copied at length in this agreement.

The prevailing party in a suit on this bond shall recover as part of the judgment reasonable attorney fees that may be fixed by a judge of the court.

Witness our hands this ____ day of _____, ____.

PRINCIPAL

SEAL

AGENCY OF RECORD BY: _____

AGENCY ADDRESS

SURETY

SEAL

BY: _____

** END OF SECTION **

Acceptance of Notice

(NOTE: The contractor shall return a signed copy of this notice to the owner.)

Receipt of this NOTICE OF AWARD is hereby acknowledged by:

Contractor

This the ____ day of _____, 2016.

BY: _____ TITLE: _____

** END OF SECTION **

SECTION 00680
NOTICE TO PROCEED

DATE:

TO:

RE:

You are hereby notified to commence WORK in accordance with the Contract dated _____, _____, within ten (10) calendar days of the date of this Notice To Proceed, and you are to complete the WORK within 90 CALENDAR DAYS, with a completion date of _____, _____. The period for completion may be extended through the authorized and approved change order process.

OWNER: Lake Havasu City, Arizona

By: _____

Name: Kimberly Fiumara

Title: Purchasing & Grants Supervisor

ACCEPTANCE OF NOTICE

(NOTE: The Contractor shall return a signed copy of this Notice to the Owner)

Receipt of the above NOTICE TO PROCEED is hereby acknowledged

this the __ day of _____, _____.

By: _____

Name: _____

Title: _____

** END OF SECTION **

THIS PAGE INTENTIONALLY LEFT BLANK

SECTION 00685
CERTIFICATE OF SUBSTANTIAL COMPLETION

I hereby state that the degree of completion of:

**Water Conservation Program Implementation, Package No. 2
Project No. SS2970**

Provides the full-time use of the project, or defined portion of the project, for the purposes for which it was intended and is the commencement of the Guarantee Period.

"Substantial Completion" shall not be considered as final acceptance.

Lake Havasu City, Arizona

Date: _____

By: _____

Name: _____

Title: _____

ACCEPTANCE OF NOTICE

(NOTE: The Contractor shall return a signed copy of this Notice to the Owner)

Receipt of the above **CERTIFICATE OF SUBSTANTIAL COMPLETION** is hereby acknowledged this the _____ day of _____, _____.

By: _____

Name: _____

Title: _____

END OF SECTION

THIS PAGE INTENTIONALLY LEFT BLANK

SECTION 00690
CERTIFICATE OF COMPLETION

I hereby state that all goods and services required by:

Water Conservation Program Implementation, Package No. 2
Project No. SS2970

have been delivered in conformance with the Contract, and all activities required by the Contractor under the Contract were completed as of _____.
(Date)

Lake Havasu City, Arizona

By: _____

Name: _____

Title: _____

** END OF SECTION **

THIS PAGE INTENTIONALLY LEFT BLANK

SECTION 00700
GENERAL CONDITIONS

This section of the Contract Documents is pre-printed. Any modifications to the following Articles, as may be required for this Project, are made in the Special Provisions.

1.0 DEFINITIONS

Wherever in the Contract Document the following terms are used, the intent and meaning shall be interpreted as follows:

1.1 Addenda

Written or graphic instruments issued prior to the opening of Bids which modify or interpret the Contract Documents, Drawings and Specifications, by additions, deletions, clarifications or corrections.

1.2 As Approved

The words "as approved," unless otherwise qualified, shall be understood to be followed by the words "by the Owner."

1.3 As Shown, and as Indicated

The words "as shown" and "as indicated" shall be understood to be followed by the words "on the Drawings" or "in the Specifications."

1.4 Award

The acceptance, by the Owner, of the successful Bidder's proposal.

1.5 Bid

The offer or proposal of the Bidder submitted on the prescribed form setting forth the prices for the Work to be performed.

1.6 Bidder

Any individual, firm partnership or corporation, or combination thereof submitting a proposal for the Work contemplated, acting directly or through a duly authorized representative.

1.7 Bonds

Bid, Performance, and Payment Bonds and other instruments of security, furnished by the Contractor and its surety in accordance with the Contract Documents.

1.8 Calendar Day

Every day shown on the calendar, measured from midnight to the next midnight.

1.9 Change Order

A written order to the Contractor, signed by the Owner, covering changes in the Plans, Specifications, or proposal quantities and establishing the basis of payment and contract time adjustment, if any, for the Work affected by such changes.

If the Change Order increases the existing Contract Amount, the Builder's Risk Insurance limit must be increased to the adjusted Contract Amount.

1.10 Contract

The "Contract" is the written Contract covering the performance of the Work and the furnishing of labor, materials, incidental services, tools, and equipment in the construction of the Work. It includes Supplemental Contracts amending or extending the Work contemplated in the manner hereinafter described and which may be required to complete the Work in a substantial and acceptable manner to the Owner. The Contract may include Contract Change Orders.

1.11 Contract Documents

The "Contract Documents" consist of the Bidding Requirements, Contract Forms, Conditions of the Contract including General and/or Supplemental General Conditions, Special Provisions, the Technical Specifications, and the Drawings, including all Addenda and modifications thereafter incorporated into the Documents before execution and including all other requirements incorporated by specific reference thereto.

1.12 Contract Price

The total monies payable by Owner to the Contractor under the terms and conditions of the Contract Documents.

1.13 Contract Time

The number of calendar days stated in the Contract Documents for the completion of the Work.

1.14 Contractor

The individual, partnership, firm, or corporation primarily liable for the acceptable performance of the Work contracted for and the payment of all legal debts pertaining to the Work who acts directly or through lawful agents or employees to complete the Contract Work.

1.15 Days

Unless otherwise specifically stated, the term "days" will be understood to mean calendar days.

1.16 Drawings

The term "Drawings," also described as "Plans," refers to the official drawings, profiles, cross sections, elevations, details, and other working drawings, and supplementary drawings, or reproductions thereof, which show the locations, character, dimensions, and details of the Work to be performed. Drawings may either be bound in the same book as the balance of the Contract Documents or bound in separate sets, and are a part of the Contract Documents, regardless of the method of binding.

1.17 Engineer

The individual, partnership, firm, or corporation duly authorized by the Owner (sponsor) to be responsible for the Engineering of the contract Work and acting directly or through an authorized representative.

1.18 Field Order

A written order effecting a change in the Work not involving an adjustment in the Contract Price or an extension of the Contract Time, issued by the Engineer to the Contractor during construction.

1.19 Final Acceptance

Upon due notice from the Contractor of presumptive completion of the entire project, the Owner will make an inspection. If all construction provided for and contemplated by the contract is found completed to the Owner's satisfaction and all requirements of the contract have been met, that inspection shall constitute the final inspection and the Owner will make the final acceptance and issue the Certificate of Completion.

If, however, the inspection discloses any work, in whole or in part, as being unsatisfactory or that all requirements of the contract have not been met, the Owner will give the Contractor the necessary instructions for correction or completion, and the Contractor shall immediately comply with and execute the instructions. Upon correction of the work, completion of contract requirements, and notification to Owner, another inspection will be

made which shall constitute the final inspection provided the work has been satisfactorily completed and all requirements of the contract met. In such event, the Owner will make the final acceptance and issue the Certificate of Completion.

1.20 Inspector

An authorized representative of the Owner assigned to make all necessary inspections and/or tests of the Work performed or being performed, or of the materials furnished or being furnished by the Contractor.

1.21 Methodology and Quality of Workmanship

The manner and sequence of construction which considered to be the acceptable standard in which to perform the Work.

1.22 Notice

The term "notice" or the requirement to notify, as used in the Contract Documents or applicable State or Federal statutes, shall signify a written communication delivered in person or by certified or registered mail to the individual, or to a member of the firm, or to an officer of the corporation for whom it is intended. Certified or registered mail shall be addressed to the last business address known to him who gives the notice.

1.23 Notice of Award

The written notice of the acceptance of the Bid from the Owner to the successful Bidder.

1.24 Notice to Proceed

Written communication issued by the Owner to the Contractor authorizing him to proceed with the Work and establishing the date of commencement of the Work.

1.25 Or Equal

The phrase "or equal" shall be understood to indicate that the "equal" product is the same or better than the product names in function, performance, reliability, quality, and general configuration. Determination of equality in reference to the project design requirements will be made by the Owner.

1.26 Owner

The term "Owner" shall be understood to be Lake Havasu City, Arizona.

1.27 Payment Bond

The approved form of security furnished by the Contractor and its surety as a guaranty that it will pay in full all bills and accounts for materials and labor used in the construction of Work.

1.28 Performance Bond

The approved form of security furnished by the Contractor and its surety as a guarantee that the Contractor will complete the Work in accordance with the terms of the Contract and guarantee the Work for a period of one (1) year after the date of Certificate of Substantial Completion.

1.29 Plans

Plans shall have the same meaning as "Drawings," see Section 1.16.

1.30 Project

The undertaking to be performed as provided in the Contract Documents, see Section 1.11.

1.31 Proposal

The offer of the Bidder for the Work when made out and submitted on the prescribed proposal form, properly signed and guaranteed.

1.32 Proposal Guarantee

The cash, or cashier's check or certified check, or bidder's bond accompanying the Proposal submitted by the Bidder, as a guarantee that the Bidder will enter into a contract with the Owner for the construction or doing of the Work, if it is awarded to it, and will provide the contract bonds and insurance required.

1.33 Shop Drawings

All drawings, diagrams, illustrations, brochures, schedules and other data which are prepared by the Contractor, a Subcontractor, manufacturer, supplier or distributor, which illustrate how specific portions of the Work shall be fabricated or installed.

1.34 Specifications

The directions, provisions and requirements pertaining to the method and manner of performing the Work or to the quantities and qualities of the materials to be furnished under the Contract, together with all other directions, provisions and requirements, plus such amendments, deletions from or additions which may be provided for by Supplemental Contract or Change Orders.

1.35 Subcontractor

A Subcontractor is a person or entity who has a direct or indirect contract with a Contractor to perform any of the Work at the site. For convenience, the term Subcontractor is referred to throughout the Contract Documents as if singular in number and masculine in gender but includes the plural and feminine gender and includes a Sub-Subcontractor or an authorized representative thereof. The term Subcontractor does not include any separate Contractor or its Subcontractors.

1.36 Substantial Completion

"Substantial Completion" shall be that degree of completion of the project or a defined portion of the project, sufficient to provide the Owner, at its discretion, the full-time use of the project or defined portion of the project for the purposes for which it was intended. "Substantial Completion" shall not be considered as final acceptance.

1.37 Supplemental General Conditions

Modifications to General Conditions required by a Federal Agency for participation in the Project and approved by the agency for participation in the Project and approved by the agency in writing prior to inclusion in the Contract Documents and such requirements that may be imposed by applicable state laws. The term also includes modifications or additions to the General Conditions required by the Owner or Engineer.

1.38 Supplier

Any person or organization who supplies materials or equipment for the Work, including that fabricated to a special design, but who does not perform labor at the site.

1.39 Surety

The corporation, partnership, or individual, other than the Contractor, executing Payment, or Performance Bonds which are furnished to the Owner by the Contractor.

1.40 Work

The word "Work" within these Contract Documents shall include all material, labor, tools, utilities, and all appliances, machinery, transportation, and appurtenances necessary to perform and complete the Contract, and such additional items not specifically indicated or described which can be reasonably inferred as belonging to the item described or indicated and as required by good practice to provide a complete and satisfactory system or structure.

1.41 Working Day

A working day shall be any day, other than a legal holiday, Saturday or Sunday, on which the normal working forces of the Contractor may proceed with regular work.

2.0 NOTICE TO PROCEED

2.1 After the Owner has issued the Notice Of Award, the Contractor shall provide the Performance Bond, the Payment Bond, the Certificate Of Insurance, the Work Schedule, the monthly cash flow, and a signed Contract within ten (10) calendar days. The Owner's attorney will review each document and, if they are found to be acceptable, the Owner will sign and execute the Contract. Within a period of sixty (60) calendar days after executing the Contract, the Owner will issue the Notice To Proceed. Within ten (10) calendar days of the postmark date of the Notice To Proceed, the Work shall commence. The Contractor shall not commence any Work until such time that the Notice To Proceed has been issued.

3.0 ADDITIONAL INSTRUCTIONS AND DETAIL DRAWINGS

3.1 The Engineer may furnish additional instructions to the Contractor by means of Drawings or otherwise, during the progress of the Work as necessary to make clear or to define in greater detail the intent of the Specifications and Contract Drawings.

The additional drawings and instruction thus supplied will become a part of the Contract Documents. The Contractor shall carry out the Work in accordance with the additional detail drawings and instructions.

4.0 SCHEDULES, REPORTS AND RECORDS

4.1 The Contractor shall submit to the Owner payrolls, reports, estimates, records and other data where applicable as are required by the Contract Documents for the Work to be performed.

4.2 The Contractor, after the Contract award and prior to the Pre-Construction Conference, shall prepare for submittal to the Engineer for review, a detailed progress schedule. The progress schedule shall be brought up to date and submitted to the Engineer prior to each progress payment request, and at such other time intervals as the Engineer may request.

A. Progress Schedule

The schedule shall be a time-scaled critical path progress schedule showing in detail the proposed sequence of activity. The critical path analysis shall consist of a graphic network diagram and shall clearly show start and completion dates and percentage of work completed.

4.3 The Contractor shall also forward to the Engineer, prior to each progress payment request, an itemized report of the delivery status of major and critical items of purchased equipment and material, including Shop Drawings and the status of shop and field fabricated work. These progress reports shall indicate the date of the purchase order, the current percentage of completion, estimated delivery, and cause of delay, if any.

4.4 If the completion of any part of the Work or the delivery of materials is behind the approved schedule, the Contractor shall submit in writing a plan acceptable to the Engineer for bringing the Work up to schedule.

4.5 The Owner shall have the right to withhold progress payments for the Work if the Contractor fails to update and submit the progress schedule and reports as specified, and such withholding shall not constitute grounds for additional claims by the Contractor against the Owner.

4.6 The Contractor shall submit an estimated monthly cash flow, based upon the progress schedule with the bonds, schedules, and Certificate Of Insurance.

5.0 DRAWINGS AND SPECIFICATONS

5.1 The intent of the Drawings and Specifications is that the Contractor shall furnish all labor, materials, tools, equipment, utilities, and transportation necessary for the proper execution of the Work in accordance with the Contract Documents and all incidental work necessary to complete the Project in an acceptable quality and manner, ready for use, occupancy or operation by the Owner.

5.2 In case of conflict between the Drawings and Specifications, the Specifications shall govern. Figure dimensions on Drawings shall govern over scale dimensions, and detailed Drawings shall govern over general Drawings.

5.3 Any discrepancies found between the Drawings and Specifications and site conditions or any inconsistencies or ambiguities in the Drawings or Specifications shall be immediately reported verbally and within 24 hours of such a discovery, in writing to the Engineer, who shall promptly correct such inconsistencies or ambiguities in writing. Work done by the Contractor after his discovery of such discrepancies, inconsistencies or ambiguities shall be done at the Contractor's risk, and the Contractor shall assume full responsibility therefor and shall bear all costs attributable thereto, if not acceptable to the Owner.

6.0 SHOP DRAWINGS

6.1 The Contractor shall provide seven (7) copies of the Shop Drawings as specified or as may be necessary for the prosecution of the Work as required by the Contract Documents. All drawings and schedules shall be submitted sufficiently in advance to allow the Engineer not less than 20 regular working days for checking the submittal. The Engineer's approval of any Shop Drawings shall not release the Contractor from responsibility for deviations from the Contract Documents.

6.2 When submitted for the Engineer's review, Shop Drawings shall bear the Contractor's certification by means of a signed Stamp, that he has reviewed, checked and approved the Shop Drawings and that they are in conformance with the requirements of the Contract Documents. Shop Drawings, which in the opinion of the Engineer are incomplete or unchecked by the Contractor, will be returned to the Contractor for resubmission in the proper form.

If Shop Drawings or submittals are rejected by the Engineer, all costs incurred by the Engineer or the Owner for reviewing the resubmittals shall be charged to the Contractor, and the Owner has the right to deduct such costs from any monies owed the Contractor by the Owner.

6.3 When Shop Drawings have been reviewed by the Engineer, two sets of submittals will be returned to the Contractor appropriately stamped. If major changes or corrections are necessary, the Shop Drawing may be rejected and one set will be returned to the Contractor with such changes or corrections indicated, and the Contractor shall correct and resubmit the Shop Drawings. No changes shall be made by the Contractor to resubmitted Shop Drawings other than those changes indicated by the Engineer, unless such changes are clearly described in a letter accompanying the resubmitted Shop Drawings.

6.4 The review of such Shop Drawings and catalog cuts by the Engineer shall not relieve the Contractor from responsibility for corrections of dimensions, fabrication details, and space requirements, or for deviations from the Contract Drawings or Specifications, unless the Contractor has called attention to such deviations in writing by a letter accompanying the Shop Drawings and the Engineer approves the change or deviation in writing at the time of submission; nor shall review by the Engineer relieve the Contractor from the responsibility for errors in the Shop Drawings. When the Contractor does call such deviations to the attention of the Engineer, the Contractor shall state in his letter whether or not such deviations involve any deduction or extra cost adjustment.

6.5 Portions of the Work requiring a Shop Drawing or sample submission shall not begin until the Shop Drawing or submission has been approved by the Engineer. A copy of each approved Shop Drawing and each approved sample shall be kept in good order by the Contractor at the site and shall be available to the Engineer.

7.0 RECORD DRAWINGS

7.1 During construction, the Contractor shall keep an accurate record of the following:

- A. Deviations between the Work as shown on the Plans and the Work as actually installed.

- B. The specific locations of piping, valves, electric conduits, duct work, equipment, and other such work which was not located on the Plans. The Record Drawings shall show distances to these locations from known points on the Plans.
- C. Equipment schedules indicating manufacturer's names and model numbers. When all revisions showing work as installed are made, the corrected set of plans shall be delivered to the Engineer before the final pay request is processed. These plans shall be clearly marked "Record Drawings."

7.2 Nothing contained in this section shall be construed as authorizing any deviation in the Work as shown on the Contract Drawings without a written Change Order or written authority to the Contractor from the Engineer.

8.0 MATERIALS, SERVICES, AND FACILITIES

8.1 It is understood that, except as otherwise specifically stated in the Contract Documents, the Contractor shall provide and pay for all materials, labor, tools, equipment, water, light, power, transportation, supervision, temporary construction of any nature, and all other services and facilities of any nature whatsoever necessary to execute, complete, and deliver the Work within the specified time.

8.2 The Contractor shall furnish the Owner a list of materials and the source of supply of each of the materials on the list. The source of supply of each of the materials shall be approved by the Owner before the delivery of said materials is started. Only materials conforming to these Specifications and approved by the Owner shall be used in the Work. All materials proposed for use may be inspected or tested at any time during their preparation and use. After trial, if it is found that sources of supply which have been approved do not furnish a uniform product, or if the product from any source proves unacceptable at any time, the Contractor shall furnish approved material from other approved sources. No material which, after approval, has in any way become unfit for use shall be used in the Work.

8.3 The Contractor warrants to the Owner and Engineer that the materials and equipment furnished under the Contract will be new and of a quality equal to that specified or approved and, that all Work will be of good quality, free from faults and defects and in conformance with the Contract Documents. Mechanical and electrical equipment shall be the products of manufacturers of established good reputations and regularly engaged in the fabrication of such equipment. Unless otherwise noted, any equipment offered shall be current models which have been in successful regular operation under comparable conditions for a period of at least two years. This time requirement, however, does not apply to minor details nor to thoroughly demonstrated improvements in design or in material of construction. Work shall be done and completed in a thorough and workmanlike manner and if required by Engineer, the Contractor shall furnish satisfactory evidence as to the kind and quality of materials and equipment used.

8.4 All materials which the Engineer or its authorized Inspector has determined do not conform to the requirements of the Plans and Specifications will be rejected. They shall be removed immediately from the vicinity of the Work by the Contractor at his own expense, unless otherwise permitted by the Engineer. No rejected material, the defects of which have been subsequently corrected, shall be used in the Work, unless approval in writing has been given by the Engineer. Upon failure of the Contractor to comply promptly with any order of the Engineer made under the provisions in this section, the Engineer shall have authority to cause the removal and replacement of rejected material and to deduct the cost thereof from any monies due or to become due the Contractor.

8.5 If any part or portions of the Work done or material furnished under this Contract shall prove defective or non-conforming with the Drawings and Specifications, and if the imperfection in the same shall not be of sufficient magnitude or importance as to make the Work dangerous or unsuitable, or if the removal of such Work will create conditions which are dangerous or undesirable, the Engineer shall have the right and authority to retain such Work but shall make such deductions in the final payment therefor as may be just and reasonable. Such adjustment shall be effected whether or not final payment has been made.

8.6 Materials and equipment shall be so stored as to insure the preservation of their quality and fitness for the Work. Stored materials and equipment to be incorporated in the Work shall be located so as to facilitate prompt inspection.

8.7 Manufactured articles, materials and equipment shall be applied, installed, connected, erected, used, cleaned and conditioned as directed by the manufacturer.

8.8 Materials, supplies or equipment to be incorporated into the Work shall not be purchased by the Contractor or the Subcontractor subject to a chattel mortgage or under a conditional sale contract or other Contract by which an interest is retained by the seller.

9.0 INSPECTION AND TESTING

9.1 All material and equipment used in the construction of the Project shall be subject to adequate inspection and testing in accordance with generally accepted standards, as required and defined in the Contract Documents.

9.2 The Owner shall provide all inspection and testing services not required by the Contract Documents.

9.3 The Contractor shall provide at its expense the testing and inspection services required by the Contract Documents.

9.4 If the Contract Documents, laws, ordinances, rules, regulations or orders of any public authority having jurisdiction require any Work to specifically be inspected, tested, or approved by someone other than the Contractor, the Contractor will give the Engineer timely notice of readiness, the minimum of which shall be forty-eight (48) hours. The Contractor will then furnish the Engineer the required certificates of inspection, testing or approval.

9.5 Inspections, tests or approvals by the Engineer or others shall not relieve the Contractor from its obligations to perform the Work in accordance with the requirements of the Contract Documents.

9.6 The Engineer and its representatives will at all times have access to the Work. In addition, authorized representatives and agents of any participating Federal or State agency shall be permitted to inspect all Work, materials, payrolls, records of personnel, invoices of materials, and other relevant data and records. The Contractor will provide proper facilities for such access and observation of the Work and also for any inspection, or testing thereof.

9.7 If any Work is covered contrary to the written instructions of the Engineer or prior to inspection, if must, if requested by the Engineer, be uncovered for his observation and replaced at the Contractor's expense.

9.8 If the Engineer considers it necessary or advisable that Work that has already been approved be inspected or tested by the Engineer or others, the Contractor, at the Engineer's request, will uncover, expose or otherwise make available for observation, inspection or testing as the Engineer may require, that portion of the Work in question, furnishing all necessary labor, materials, tools, and equipment. If it is found that such Work is defective, the Contractor will bear all the expenses of such uncovering, exposure, observation, inspection and testing and of satisfactory reconstruction. If, however, such Work is not found to be defective, the Contractor will be allowed an increase in the Contract Price or an extension of the Contract Time, or both, directly attributable to such uncovering, exposure, observation, inspection, testing and reconstruction and an appropriate Change Order shall be issued.

10.0 SUBSTITUTIONS

10.1 Whenever a material, article or piece of equipment is identified on the Drawings or Specifications by reference to brand name or catalogue number, it shall be understood that this is referenced for the purpose of defining the performance or other salient requirements and that other products of equal capacities, quality and function shall be considered. The Contractor may recommend the substitution of a material, article, or piece of equipment of equal substance and function for those referred to in the Contract Documents by reference to brand name or catalogue number, and if, in the opinion of the Engineer, such material, article, or piece of equipment is of equal substance and function to that specified, the Engineer may approve its substitution and use by the Contractor. Any cost differential shall be deductible from the Contract Price and the Contract Documents shall be appropriately modified by Change Order. The Contractor warrants that if substitutes are approved, no major changes in the function or general design of the Project will result. Incidental changes or extra component parts required to accommodate the substitute will be made by the Contractor without a change in the Contract Price or Contract Time. Any substitutions not properly approved and authorized by the Engineer may be considered defective and the Engineer may require the Contractor to remove the substituted material, article or piece of equipment and the Contractor shall bear any and all costs associated with the removal of

the substituted item, including all engineering, inspection, testing or surveying costs incurred by the Owner or the Engineer.

10.2 Determination of equality in reference to the project design requirements will be made by the Owner. "Equal" products shall not be purchased or installed by the Contractor without the Owner's written approval. Contractor shall have fourteen (14) days after issuance of Notice to Proceed for submission of data substantiating a request for substitution of an "or equal" item.

11.0 PATENTS

11.1 The Contractor shall pay all applicable royalties and license fees. The Contractor shall defend all suits or claims for infringement of any patent rights and indemnify and hold the Owner and Engineer harmless from loss on account thereof, except that the Owner shall be responsible for any such loss when a particular process, design, or the product of a particular manufacturer or manufacturers is specified, however if the Contractor has reason to believe that the design, process or product specified is an infringement of a patent, it shall be responsible for such loss unless it promptly gives such information to the Engineer.

12.0 SURVEYS, PERMITS, REGULATIONS

12.1 The Owner shall furnish all boundary surveys and establish all base lines for locating the principal component parts of the Work together with a suitable number of bench marks adjacent to the Work as shown in the Contract Documents. The Contractor shall satisfy itself as to the accuracy of all measurements before constructing any permanent structure and shall not take advantage of any errors which may have been made in laying out the Work. From the information provided by the Owner, unless otherwise specified in the Contract Documents, the Contractor shall develop and make all detail surveys needed for construction such as slope stakes, batter boards, stakes for pile locations and other working points, lines, elevations and cut sheets.

12.2 Such stakes and markings as the Engineer may set for either its own or the Contractor's guidance shall be scrupulously preserved by the Contractor. In the event the Contractor, or its employees, destroy or otherwise remove or obliterate such stakes or markings, an amount equal to the cost of replacing the same may be deducted from subsequent estimates due the Contractor at the discretion of the Owner.

12.3 Permits and licenses of a temporary nature necessary for the prosecution of the Work shall be secured and paid for by the Contractor unless otherwise stated in the Supplemental General Conditions. Permits, licenses and easements for permanent structures or permanent changes in existing facilities shall be secured and paid for by the Owner, unless otherwise specified. The Contractor shall give all notices and comply with all laws, ordinances, rules and regulations bearing on the conduct of the Work as drawn and specified. If the Contractor perceives that the Contract Documents are at variance therewith, he shall promptly notify the Engineer in writing, and any necessary changes shall be adjusted as provided in Section 16. Changes In The Work. If the Contractor performs

and works knowing it to be contrary to such laws, ordinances, rules and regulations, and without such notice to the Engineer, he shall assume full responsibility therefore and shall bear all costs attributable thereto.

13.0 PROTECTION OF WORK, PROPERTY AND PERSONS

13.1 The Contractor shall have sole responsibility for initiating, maintaining and supervising all safety precautions and programs in connection with the Work. The Contractor shall take all necessary precautions for the safety of, and shall provide the necessary protection to prevent damage, injury or loss to, all employees on the Work and other persons who may be affected thereby, all the Work and all materials or equipment to be incorporated therein, whether in storage on or off the site, and other property at the site or adjacent thereto, including trees, shrubs, lawns, walks, pavements, roadways, structures, utilities and other items not designated for removal, relocation or replacement in the course of construction.

13.2 The Contractor shall comply with all applicable laws, ordinances, rules, regulations and orders of any public body having jurisdiction. The Contractor shall erect and maintain, as required by the conditions and progress of the Work, all necessary safeguards for safety and protection. The Contractor shall notify Owners of adjacent utilities when prosecution of the Work may affect them. The Contractor shall remedy all damage, injury or loss to any property caused, directly or indirectly, in whole or in part, by the Contractor, any Subcontractor or anyone directly or indirectly employed by any of them or anyone for whose acts any of them be liable, except damage or loss attributable to the fault of the Contract Documents or to the acts or omissions of the Owner or the Engineer or anyone employed by either of them or anyone for whose acts either of them may be liable, and not attributable, directly or indirectly, in whole or in part, to the fault or negligence of the Contractor.

13.3 In emergencies affecting the safety of persons or the Work or property at the site or adjacent thereto, the Contractor, without special instruction or authorization from the Engineer or Owner, shall act to prevent threatened damage, injury or loss. He shall give the Engineer prompt Written Notice of any significant changes in the Work or deviations from the Contract Documents caused thereby, and a Change Order shall thereupon be negotiated and issued covering the changes and deviations involved, as provided in Section 16.0, Changes in the Work.

13.4 The Contractor shall designate a responsible member of its organization at the site whose duty shall be the prevention of accidents and the safety of all those at the site. The person shall be the Contractor's superintendent unless otherwise designated by the Contractor in writing to the Owner and the Engineer. The Engineer will not be responsible for safety precautions and programs in connection with the Work or for the Contractor's failure to properly perform its responsibilities with respect to initiating, maintaining and supervising all safety precautions and programs.

14.0 PUBLIC SAFETY

14.1 Whenever the Contractor's operations create a condition hazardous to traffic or to the public, it shall furnish at its own expense, and without cost to the Owner, such flagmen and guards as are necessary to give adequate warning to the public of any dangerous conditions to be encountered and he shall furnish, erect, and maintain such fences, barricades, lights, signs, and other devices as are necessary to prevent accidents and avoid damage or injury to the public.

14.2 Should the Contractor appear to be neglectful or negligent in furnishing warning and protective measures as above provided, the Engineer may direct attention to the existence of a hazard and the necessary warning and protective measures shall be furnished and installed by the Contractor at its own expense without cost to the Owner. Should the Engineer point out the inadequacy of warning and protective measures, such action on the part of the Engineer shall not relieve the Contractor from responsibility for public safety or abrogate his obligation to furnish and pay for these devices.

14.3 Should the Contractor fail to, be neglectful, or be negligent in furnishing or maintaining warning and protective facilities as required herein, the Owner may furnish or maintain such facilities and charge Contractor therefor by deducting the cost thereof from periodic progress payments due the Contractor as such costs are incurred by Owner.

14.4 No material or equipment shall be stored where it will interfere with the free and safe passage of public traffic, and at the end of each day's Work and at other times when construction operations are suspended for any reason, the Contractor shall remove all equipment and other obstructions from that portion of the right-of-way open for use by public traffic.

15.0 SUPERVISION BY CONTRACTOR

15.1 The Contractor shall supervise and direct the Work, using its best skill and attention. The Contractor shall be solely responsible for the means, methods, techniques, sequences and procedures of construction. The Contractor shall employ and maintain on the Work a qualified supervisor or superintendent who shall have been designated in writing by the Contractor as the Contractor's representative at the site, and who shall have been approved by the Engineer, which approval shall not be unreasonably withheld. The supervisor shall have full authority to act on behalf of the Contractor and all communications given to and by the supervisor shall be as binding as if given to and by the Contractor. The supervisor shall be present on the site at all times. The Contractor shall be responsible to the Owner for the acts and omissions of the employees, subcontractors, and the agents and employees, and other persons performing any other Work under the Contract with the Contractor.

16.0 CHANGES IN THE WORK

16.1 The Owner may at any time, as the need arises, order changes within the scope of the Work without invalidating the Contract. If such changes increase or decrease the amount due under the Contract Documents, or in the time required for performance of the Work, an equitable adjustment shall be authorized by Change Order.

16.2 The Engineer, also, may at any time, by issuing a Field Order, make changes in the details of the Work. The Contractor shall proceed with the performance of any changes in the Work so ordered by the Engineer unless the Contractor believes that such Field Order entitles him to a change in Contract Price or Time, or both, in which event he shall give the Engineer Written Notice thereof within seven (7) days after the receipt of the ordered change. Thereafter the Contractor shall document the basis for the change in Contract Price or Time within fourteen (14) days. The Contractor shall not execute such changes pending the receipt of an executed Change Order or further instruction from the Owner.

16.3 If the Contractor wishes to make a claim for an increase in the Contract sum, it shall give the Engineer written notice thereof within fourteen (14) days after the occurrence of the event giving rise to such claim. This notice shall be given by the Contractor before proceeding to execute the Work, except in an emergency endangering life or property, in which case Contractor shall proceed in accordance with the provisions of the Contract. No such claim shall be valid unless so made. If the Owner and Contractor cannot agree on the amount of adjustment in the Contract sum, it shall be determined by the Engineer. Any change in the Contract sum resulting from such claim shall be authorized in a Change Order.

16.4 The value of any Work covered by a Change Order shall be determined by one or more of the following methods in the order of precedence listed below:

- A. Unit prices previously approved.
- B. An agreed lump sum.
- C. Cost plus percentage.

17.0 TIME FOR COMPLETION AND LIQUIDATED DAMAGES

17.1 The date of beginning and the time for completion of the Work are essential conditions of the Contract Documents and the Work embraced shall be commenced on a date specified in the Notice To Proceed.

17.2 The Contractor shall proceed with the Work at such rate of progress to insure full completion within the Contract Time. It is expressly understood and agreed, by and between the Contractor and the Owner, that the Contract Time for the completion of the Work described herein is a reasonable time, taking into consideration the average climatic and economic conditions and other factors prevailing in the locality of the Work.

17.3 The Contractor shall only work an eight (8) hour day consisting of Monday through Friday, between 6:00 a.m. to 6:00 p.m., and do not include local municipal holidays. If the Contractor desires to carry on Work more than eight (8) hours each day, or work at night or outside the regular hours, it shall give timely notice (72 hours) to the Engineer and receive the Owner's written approval to allow satisfactory arrangements to be made for inspecting the Work in progress. Should the prosecution of the Work be discontinued for any reason, the Contractor shall notify the Engineer at least 24 hours in advance of resuming operations. The Contractor shall be responsible for any extra compensation due or costs incurred as a result of Contractor's desire to carry out Work beyond an eight (8) hour day, or at night or outside regular hours, including but not limited to, any additional costs or compensation due the Engineer And Owner or its employees or agents as a result of having to be present at the site. The costs or extra compensation necessitated by the Contractor's Work beyond an eight (8) hour day, or at night or outside regular business hours may be deducted or withheld from progress payment or any other payments due to Contractor.

17.4 If for any reason a suspension of the work should occur; the Contractor, at its own expense, shall do all the Work necessary to provide a safe, smooth and unobstructed passageway through construction for use by public traffic or to provide for the proper and efficient operation of sewer, drainage and other facilities within the site of the Work, during the period of such suspension. In the event that the Contractor fails to perform the Work specified in this Subsection, the Owner will perform such Work and the cost thereof will be deducted from periodic progress payments due the Contractor.

17.5 During inclement weather and other conditions, the Contractor shall pursue only such portions of the Work as shall not be damaged thereby. No portions of the Work which satisfactory quality or efficiency will be affected by an unfavorable condition shall be constructed while these conditions remain, unless by special means or precautions, approved by the Engineer, the Contractor is able to overcome them.

17.6 Delays in delivery of equipment or material purchased by the Contractor or its Subcontractor, including Engineer-selected equipment, shall not be considered as a just cause for delay as this is not beyond the control of the Contractor. The Contractor shall be fully responsible for the timely ordering, scheduling, expediting, delivery, and installation of all equipment and materials.

17.7 In case of failure on the part of the Contractor to complete the Work within the time affixed in the Contract, or such extension thereof as may be allowed by Engineer or Owner, the Contract shall by that fact be terminated by written notice. The Owner shall not thereafter pay or allow the Contractor any further compensation for any Work done by it under said Contract, and the Contractor and its sureties shall be liable to the Owner for all loss or damage which it may suffer by reason of his failure to complete the Contract within such time. Failure to prosecute the Work diligently shall be grounds for termination by the Owner pursuant to this paragraph.

In the event the Contract should be terminated, the Owner shall have the right to take over the Work and to proceed with the same until it is completed, either by performing said Work

itself directly or by contracting it out to some other person or persons, and in such event the Owner may take possession of and utilize, in completing the Work, such materials, appliances and plant as may be on the site of the Work and necessary for its completion. Nothing herein contained shall be deemed to limit the right of the Owner in the event of any breach of Contract by the Contractor; but all rights herein given to the Owner are and shall be deemed to be additional to any other rights or remedies which the Owner shall have under any provision of law.

17.8 Should the Contractor fail to complete the Work, or any part thereof, in the time agreed upon in the Contract or within such extra time as may have been allowed for delays by extensions granted as provided in the Contract, the Contractor shall reimburse the Owner for the additional expense and damage for each calendar day that the Contract remains uncompleted after the Contract completion date. It is agreed that the amount of such additional expense and damage incurred by reason of failure to complete the Work is the per diem rate, as stipulated in Section 15, Information For Bidders, plus any costs incurred by the Engineer including, but not limited to: the Engineer's costs for additional inspection, testing or surveying as a result of the Contractor's failure to complete the Work in the time agreed upon. The said amounts are agreed upon as liquidated damages for the loss to the Owner on account of expense due to the employment of Engineers, inspectors, and other employees after the expiration of the time of completion, and on account of the value of the operation of the Works dependent thereon. It is expressly understood and agreed that this amount is not to be considered in the nature of a penalty, but as liquidated damages which have accrued against the Contractor. The Owner shall have the right to deduct such damages from any amount due, or that may become due the Contractor, or the amount of such damages shall be due and collectible from the Contractor or its Surety.

17.9 The Contractor shall not be charged with liquidated damages or any excess costs when the delay in completion of the Work is due to any of the reasons set forth below provided the Contractor has given Written Notice of the delay within three (3) days of the occurrence of the cause of the delay to the Owner or Engineer. In the event notice is not given as provided, liquidated damages may be assessed.

- A. To unforeseeable causes beyond the control and without the fault or negligence of the Contractor, including but not restricted to: acts of God, or of the public enemy, acts of the Owner, acts of another Contractor in the performance of a separate contract with the Owner, fires, floods, epidemics, quarantine restrictions, strikes, freight embargoes, and abnormal and unforeseeable weather.

18.0 CORRECTION OF WORK

18.1 The Contractor shall promptly correct all work rejected by the engineer as defective or as failing to conform to the contract documents, whether observed before or after substantial completion and whether or not fabricated, installed or completed. Contractor shall bear all costs of correcting such rejected work, including compensation for the engineer's additional services made necessary thereby. Contractor shall also bear the costs

of making good all work of the Owner or separate Contractor destroyed or damaged by such correction or removal.

18.2 All removal and replacement work shall be done at the Contractor's expense. If the Contractor does not take action to remove such rejected work within ten (10) days after receipt of Written Notice, the Owner may remove such work and store the materials at the expense of the Contractor, including compensation for the engineer's additional services made necessary thereby.

19.0 SUBSURFACE CONDITIONS

19.1 The Contractor shall promptly, and before such conditions are disturbed, except in the event of an emergency, notify the Owner by Written Notice of:

- A. Subsurface or latent physical conditions at the site differing materially from those indicated in the Contract Documents; or
- B. Unknown physical conditions at the site, of an unusual nature, differing materially from those ordinarily encountered and generally recognized as inherent in Work of the character provided for in the Contract Documents.

19.2 The Owner shall promptly investigate the conditions, and if it finds that such conditions do so materially differ and cause an increase or decrease in the cost of, or in the time required for, performance of the Work, an equitable adjustment shall be made and the Contract Documents shall be modified by a Change Order. Any claim of the Contractor for adjustment hereunder shall not be allowed unless he has given the required Written Notice; provided that the Owner may, if he determines the facts so justify, consider and adjust any such claims asserted before the date of final payment.

20.0 SUSPENSION OF WORK, TERMINATION AND DELAY

20.1 The Owner may suspend the Work or any portion thereof for a period of not more than ninety (90) days or such further time as agreed upon by the Contractor, by Written Notice to the Contractor and the Engineer which notice shall fix the date on which Work shall be resumed. The Contractor shall resume that Work on the date so fixed. The Contractor shall be allowed an increase in the Contract Price or an extension of the Contract Time, or both, directly attributable to any suspension.

20.2 In addition to any other reasons for termination provided in the Contract, the Contractor shall be considered in default of the Contract and such default will be considered as cause for the Owner to terminate the Contract for any of the following reasons if the Contractor:

- A. Fails to begin the Work under the Contract within the time specified in the "Notice To Proceed," or

- B. Fails to perform the Work or fails to provide sufficient workers, equipment or materials to assure completion of Work in accordance with the terms of the Contract, or
- C. Performs the Work unsuitably or neglects or refuses to remove materials or to perform such new Work as may be rejected as unacceptable and unsuitable, or
- D. Discontinues the prosecution of the Work, or
- E. Fails to resume Work which has been discontinued within a reasonable time after notice to do so, or
- F. Becomes insolvent or is declared bankrupt, or commits any act of bankruptcy or insolvency, or
- G. Allows any final judgment to stand against him unsatisfied for a period of 10 days, or
- H. Makes an assignment for the benefit of creditors, or acceptable manner, or
- I. Is otherwise in breach of the Contract and has failed to remedy the breach within ten (10) days of written notice of the existence of such breach, or
- J. Fails to provide safe conditions for its workers and/or the general public.

Should the Owner consider the Contractor in default of the Contract for any reason above, he shall immediately give Written Notice to the Contractor and the Contractor's surety as to the reasons for considering the Contractor in default and the Owner's intentions to terminate the Contract.

If the Contractor or Surety, within a period of 10 days after Written Notice, does not proceed in accordance therewith, then the Owner shall have, upon written notification of the facts of such delay or neglect, the power and authority without violating the Contract, to take the prosecution of the Work out of the hands of the Contractor. The Owner may appropriate or use any or all materials and equipment that have been mobilized for use in the Work and are acceptable and may enter into an Contract for the completion of said Contract according to the terms and provisions thereof, or use such other methods as in the opinion of the Owner will be required for the completion of said Contract in an acceptable manner.

All costs and charges incurred by the Owner, together with the cost of completing the Work under Contract, will be deducted from any monies due or which may come due the Contractor. If such expense exceeds the sum which would have been payable under the Contract, then the Contractor and the Surety shall pay to the Owner the amount of such excess.

20.3 Where Contractor's services have been so terminated by Owner, the termination will not affect any rights or remedies of Owner against Contractor then existing or which may thereafter accrue. Any retention or payment of monies due Contractor by Owner will not release Contractor from liability.

20.4 Upon seven days Written Notice to Contractor and Engineer, Owner may, without cause and without prejudice to any other right or remedy of Owner, elect to terminate the Contract. In such case, Contractor shall be paid (without duplication of any items):

- A. for completed and acceptable Work executed in accordance with the Contract Documents prior to the effective date of termination, including fair and reasonable sums for overhead and profit on such work;
- B. for expenses sustained prior to the effective date of termination in performing services and furnishing labor, materials or equipment as required by the Contract Documents in connection with uncompleted Work, plus fair and reasonable sums for overhead on such expenses;
- C. for reasonable costs incurred in settlement of terminated contracts with Subcontractors, Suppliers and others; and
- D. for reasonable expenses directly attributable to termination.

Contractor shall not be paid on account of loss of anticipated profits or revenue or other economic loss arising out of or resulting from such termination.

20.5 If the Work should be stopped under an order of any court or other public authority for a period of more than ninety (90) days, through no act or fault of the Contractor or of anyone employed by him, or if the Owner should fail to pay the Contractor within 45 days after the time specified in the Payments To Contractor, Section 22.0, then the Contractor may, upon 15 days Written Notice to the Owner, stop Work until payment of the amount owing has been received.

20.6 The Owner may terminate the Contract or a portion thereof if conditions encountered during the progress of the Work make it impossible or impracticable to proceed with the Work or a local or national emergency exists.

When Contracts, or any portion thereof, are terminated before completion of all Work in the Contract, adjustments in the amount bid for the pay items will be made on the actual quantity of Work performed and accepted, or as mutually agreed for pay items of Work partially completed or not started. No claim for loss of anticipated profits will be considered.

Termination of the Contract or any portion thereof shall not relieve the Contractor of its responsibilities for the completed work nor the surety of its obligation for and concerning any just claims arising out of the Work performed.

21.0 ISSUANCE OF NOTICE OF COMPLETION AND FINAL ACCEPTANCE BY OWNER

21.1 Upon completion of the Project, a Final Inspection shall be requested by the Contractor in writing and the Owner will make an inspection within seven (7) days. If all construction provided for and contemplated by the contract is found completed to his satisfaction, that inspection shall constitute the final inspection and the Owner will make the final acceptance and issue a Certificate Of Completion to the Contractor.

If, however, the inspection discloses any Work, in whole or in part, as being unsatisfactory, the Owner will give the Contractor the necessary instructions for correction of same, and the Contractor shall immediately comply with and execute such instructions. Upon correction of the Work, another inspection will be made which shall constitute the final inspection provided the Work has been satisfactorily completed. In such event, the Owner will make the final acceptance and issue a Certificate Of Completion to the Contractor.

22.0 PAYMENTS TO CONTRACTOR

22.1 In addition to any documents required by the Engineer to be submitted to Engineer at the time a partial pay estimate is submitted, including partial lien released as specified in Section 22.9 of the General Conditions, the Contractor shall, at least ten (10) days before each progress payment falls due (but not more often than once a month), submit to the Engineer a partial payment estimate filled out and signed by the Contractor covering the Work performed during the period covered by the partial payment estimate and supported by such data as the Engineer may reasonably require. If payment is requested on the basis of materials and equipment not incorporated in the Work, title to such materials and equipment shall vest in the Owner, and Contractor shall supply, at the time of submission of payment estimate, supporting documents satisfactory to the Owner, to establish and protect Owner's interest in the materials and equipment, and Contractor shall maintain appropriate insurance on same until such time as actual possession by the Owner of the materials and equipment shall occur. The Engineer will, within seven (7) days after receipt of each partial payment estimate, either indicate in writing his approval of payment and present the partial payment estimate to the Owner or return the partial payment estimate to the Contractor indicating in writing his reasons for refusing to approve payment. In the latter case, the Contractor may make the necessary corrections and resubmit the partial payment estimate. The Owner will, within fourteen (14) days of presentation to him of an approved partial payment estimate, pay the Contractor a progress payment on the basis of the approved partial payment estimate. The Owner shall retain ten (10) percent of the amount of each payment until final completion and acceptance of all Work covered by the Contract Documents. When the Contract is fifty percent completed, one-half of the amount retained shall be paid to the Contractor provided the Contractor makes a written request for the payment and the Contractor is making satisfactory progress on the Contract and there is no specific cause or claim requiring a greater amount to be retained. After the Contract is fifty per cent completed, no more than five per cent of the amount of any subsequent progress payments made under the Contract may be retained providing the Contractor is making satisfactory progress on the project, except that if at any time the Owner determines

satisfactory progress is not being made, ten per cent retention shall be reinstated for all progress payments made under the Contract subsequent to the determination.

22.2 In lieu of ten percent (10%) retention provided for in paragraph 22.1, of this Article, the Owner shall, at the Contractor's option, accept as a substitute an assignment of any of the following:

- A. Time certificates of deposit of banks licensed by the State of Arizona; or
- B. Securities of or guaranteed by the United States of America; or
- C. Securities of the State of Arizona, or any county, municipality or school district thereof; or
- D. Shares of savings and loan institutions authorized to transact business in the State of Arizona.

Such assigned instruments shall have a face value in an amount equal to ten percent (10%) of the progress payment for which such instruments are tendered and shall be retained by the Owner as a guarantee for complete performance of the Contract.

In the event the Owner accepts substitute security as provided herein for the ten percent (10%) retention, the Contractor shall be entitled to all interest or income earned by such security, and all such security in lieu of retention shall be returned to the Contractor within sixty (60) days after final completion and acceptance of all material, equipment and work covered by the contract if the Contractor has furnished the Owner satisfactory receipts for all labor and material billed and waivers of liens from any and all persons holding claims against the work.

In no event shall the Owner accept a time certificate of deposit of a bank or shares of a savings and loan institution in lieu of the retention specified in paragraph 22.1 of this Article unless accompanied by a signed and acknowledged waiver of the bank or savings and loan institution of any right or power to set off against either the Owner or the Contractor in relationship to the certificates or shares assigned.

22.3 The Contractor shall promptly pay each Subcontractor, upon receipt of payment from the Owner out of the amount paid to the Contractor on account of such Subcontractors' Work, the amount to which said Subcontractor is entitled, reflecting the percentage actually retained, if any, from payments to the Contractor on account of such Subcontractors' Work. The Contractor shall, by an appropriate Contract with each Subcontractor, require each Subcontractor to make payments to his Sub-subcontractors in similar manner.

22.4 Prior to Substantial Completion, the Owner, with the approval of the Engineer and with the concurrence of the Contractor, may use any completed or substantially completed portions of the Work. Such use shall not constitute an acceptance of such portions of the Work.

22.5 The Owner shall have the right to enter the premises for the purpose of doing Work not covered by the Contract Documents. This provision shall not be construed as relieving the Contractor of the sole responsibility for the care and protection of the Work, or the restoration of any damaged Work except such as may be caused by agents or employees of the Owner.

22.6 Upon final completion and acceptance of the Work, the Engineer shall issue a certificate attached to the final payment request that the Work has been accepted under the conditions of the Contract Documents. No retention of payments may be delayed or retained without a specific written finding by the Engineer or Owner of the reasons justifying the delay in payment. The entire balance found to be due the Contractor, including the retained percentages, except the amount necessary to pay the expenses the Owner reasonably expected to incur in order to pay or discharge the expenses determined by the Engineer or Owner in the finding justifying the retention or delay, shall be paid to the Contractor, within sixty (60) days of completion or proper filing of the Notice of Completion.

22.7 The Contractor shall indemnify and save the Owner or the Owner's agents harmless from all claims growing out of the lawful demands of Subcontractors, laborers, workmen, mechanics, materialmen, and furnishers of machinery and parts thereof, equipment, tools, and all supplies, incurred in the furtherance of the performance of the Work. The Contractor shall, at the Owner's request, furnish satisfactory evidence, in the form of lien releases or other documents deemed appropriate by the Owner, that all obligations of the nature designated above have been paid, discharged, or waived. If the Contractor fails to do so the Owner may, after having notified the Contractor, either pay unpaid bills or withhold from the Contractor's unpaid compensation a sum of money deemed reasonably sufficient to pay any and all such lawful claims until satisfactory evidence is furnished that all liabilities have been fully discharged whereupon payment to the Contractor shall be resumed, in accordance with the terms of the Contract Documents, but in no event shall the provisions of this sentence be construed to impose any obligations upon the Owner to either the Contractor, his Surety, or any third party. In paying any unpaid bills of the Contractor, any payment so made by the Owner shall be considered as a payment made under the Contract Documents by the Owner to the Contractor and the Owner shall not be liable to the Contractor for any such payments made in good faith.

22.8 If any payment to Contractor is delayed after the date due, interest shall be paid at the rate of one percent per month or fraction of a month on such unpaid balance as may be due. If the Owner fails to make payment sixty (60) days after final completion and acceptance, in addition to other remedies available to the Contractor, interest shall be paid at the rate of one per cent per month or fraction of the month on such unpaid balance as may be due, except for that amount necessary to pay the expenses the Owner reasonably expects to incur in order to pay or discharge the expense determined by the Engineer or Owner in the finding justifying the retention or delay.

22.9 The Owner may require the Contractor to furnish partial releases or liens executed by all persons, firms and corporations who have furnished labor services or materials incorporated into the Work during the period of time for which the progress payment is due, releasing such lien rights as these persons, firms or corporations may have for that period.

23.0 ACCEPTANCE OF FINAL PAYMENT AS RELEASE

23.1 Following the Owner's acceptance of the Work, the Owner will issue a Notice of Completion to the Contractor. Sixty days after the issuing of the Notice of Completion, and upon receipt of the necessary Unconditional lien releases executed by all persons, firms and corporations who have furnished labor services or materials incorporated into the work evidencing that all liabilities have been fully discharged, the Owner will pay to the Contractor the entire sum so found to be due after deducting therefrom all previous payments and all amounts to be kept and all amounts to be retained under the provisions of the Contract. All previous prior partial estimates and payments shall be subject to correction in the final estimate and payment.

23.2 The acceptance by the Contractor of final payment shall be and shall operate as a release to the Owner of all claims and all liability to the Contractor other than claims in stated amounts as may be specifically excepted by the Contractor for all things done or furnished in connection with this Work and for every act and neglect of the Owner and others relating to or arising out of this Work. Any payment, however, final or otherwise, shall not release the Contractor or his sureties from any obligations under the Contract Documents or the Performance Bond and Payment Bonds.

24.0 INSURANCE

24.1 The Contractor shall give special attention to Section 00500-A of the Bid Documents when preparing a bid, which outline the insurance requirements of Owner and the Contractor shall consider these insurance requirements part of the Bid/Contract documents.

The Contractor shall purchase and maintain such insurance as will protect him from claims set forth below which may arise out of or result from the Contractor's execution of the Work, whether such execution be by itself or by any Subcontractor or by anyone directly or indirectly employed by any of them, or by anyone for whose acts any of them may be liable:

- A. Claims under worker's compensation, disability benefit and other similar employee benefit acts;
- B. Claims for damages because of bodily injury, occupational sickness or disease, or death of his employees;
- C. Claims for damages because of bodily injury, sickness or disease, or death of any person other than his employees;

- D. Claims for damages insured by usual personal injury liability coverage which are sustained (1) by any person as a result of an offense directly or indirectly related to the employment of such person by the Contractor, or (2) by any other person; and
- E. Claims for damages because of injury to or destruction of tangible property, including loss of use resulting therefrom.

The Contractor is responsible to respond to claims arising as a result of its work. See Section 500-B for specific procedures.

24.2 Certificates of Insurance acceptable to the Owner shall be filed with the Owner prior to commencement of the Work. These Certificates shall contain a provision that coverages afforded under the policies will not be canceled unless at least ten (10) days prior Written Notice has been given to the Owner, "Attention: Contract Administrator, 2330 McCulloch Boulevard North, Lake Havasu City, AZ, 86403".

24.3 The Contractor shall procure and maintain, at its own expense, during the Contract Time, liability insurance as specified in Section 500-A, incorporated herein.

25.0 CONTRACT SECURITY

25.1 The Contractor shall within ten (10) days after the receipt of the Notice Of Award furnish the Owner with a Performance Bond and a Payment Bond in sums equal to the amount of the Contract PRICE, conditioned upon the performance by the Contractor of all undertakings, covenants, terms, conditions and Contracts of the Contract Documents, and upon the prompt payment by the Contractor to all persons supplying labor and materials in the prosecution of the Work provided by the Contract Documents. Such Bonds shall be executed by the Contractor and a corporate bonding company licensed to transact such business in the state in which the Work is to be performed and named on the current list of "Surety Companies Acceptable on Federal Bonds" as published in the Treasury Department Circular Number 570. The expense of these Bonds shall be borne by the Contractor. If at any time a surety on any such Bond is declared a bankrupt or loses its right to do business in the state in which the Work is to be performed or is removed from the list of Surety Companies accepted on Federal Bonds, Contractor shall within ten (10) days after notice from the Owner to do so, substitute an acceptable Bond (or Bonds) in such form and sum and signed by such other surety or sureties as may be satisfactory to the Owner. The premiums on such Bond shall be paid by the Contractor. No further payments shall be deemed due nor shall be made until the new surety or sureties shall have furnished an acceptable Bond to the Owner.

26.0 ASSIGNMENTS

26.1 Neither the Contractor nor the Owner shall sell, transfer, assign or otherwise dispose of the Contract or any portion thereof, or of his right, title or interest therein, or his obligations thereunder, without written consent of the other party. Nor shall the Contractor assign any monies due or to become due to him hereunder without the previous written consent of the Owner.

26.2 The Owner and Contractor each bind itself, its partners, successors and assigns and legal representatives to the other party hereto and to the partners, successors, assigns and legal representatives of such other party in respect to all covenants, Contracts and obligations contained in the Contract Documents.

27.0 INDEMNIFICATION

27.1 Contractor shall indemnify and hold harmless City, its officers and employees from and against any and all liabilities, damages, losses, and costs, including reasonable attorney's fees, but only to the extent caused by the negligence, recklessness, or intentional wrongful conduct of Contractor or other persons employed or used by the Contractor in the performance of this Contract. It is agreed that Contractor will be responsible for primary loss investigation, defense, and judgment costs where this indemnification is applicable.

27.2 In any and all claims against the Owner or the Engineer, or any of their agents or employees, by any employee of the Contractor, any Subcontractor, anyone directly or indirectly employed by any of them, or anyone for whose acts any of them may be liable, the indemnification obligation shall not be limited in any way by any limitation on the amount or type of damages, compensation of benefits payable by or for the Contractor or any Subcontractor under worker's compensation acts, disability benefit acts or other employee benefits acts.

27.3 The obligation of the Contractor under this paragraph shall not extend to the liability of the Engineer, his agents or employees arising out of the preparation or approval of maps, DRAWINGS, opinions, reports, surveys, Change Orders, designs or Specifications.

28.0 SEPARATE CONTRACTS

28.1 The Owner reserves the right to let other contracts in connection with this Project. The Contractor shall afford other Contractors reasonable opportunity for the introduction and storage of their materials and the execution of their Work, and shall properly connect and coordinate its Work with theirs. If the proper execution or results of any part of the Contractor's Work depends upon the Work of any other Contractor, the Contractor shall inspect and promptly report to the Engineer any defects in such Work that render it unsuitable for such proper execution and results.

28.2 The Owner may perform additional Work related to the Project by itself, or it may let other contracts containing provisions similar to these. The Contractor shall afford the other Contractors who are parties to such Contracts (or the Owner, if he is performing the additional Work himself), reasonable opportunity for the introduction and storage of materials and equipment and the execution of Work, and shall properly connect and coordinate his Work with theirs.

28.3 If the performance of additional Work by other Contractors or the Owner is not noted in the Contract Documents prior to the execution of the Contract, written notice thereof shall be given to the Contractor prior to starting any such additional Work. If the Contractor believes that the performance of such additional Work by the Owner or others involves it in additional expense or entitles him to an extension of the Contract Time, it may make a claim therefore as provided in Sections 16 and 17.

29.0 SUBCONTRACTING

29.1 The Contractor may utilize the services of specialty Subcontractors on those parts of the Work which come under normal contracting practices or are typically performed by specialty Subcontractors, provided the Contractor, simultaneously with the delivery of the executed Contract, shall furnish to the Owner and the Engineer in writing the names of the persons or entities (including those who are to furnish materials or equipment fabricated to a special design) proposed for each of the principal portions of the Work. The engineer will promptly reply to the Contractor in writing stating whether or not the Owner or the Engineer, after due investigation, has reasonable objection to any such proposed person or entity. Failure of the Owner or Engineer to promptly reply shall constitute notice of no reasonable objection. The Contractor shall not contract with any such proposed person or entity to whom the Owner or Engineer has made reasonable objection and the Contractor shall not be required to contract with anyone to whom he has a reasonable objection. If the Owner or Engineer has a reasonable objection to any proposed person or entity, the Contractor shall submit a substitute to whom the Owner or the Engineer has no reasonable objection. The Contractor shall make no substitution for any Subcontractor, person or entity previously selected if the Owner or Engineer makes reasonable objection to such substitution.

29.2 The Contractor shall not award Work to Subcontractor(s), in excess of forty-nine (49%) percent of the Contract Price, without prior written approval of the Owner.

29.3 The Contractor shall be fully responsible to the Owner for the acts and omissions of its Subcontractors, and of persons either directly or indirectly employed by them, as it is for the acts and omissions of persons directly employed by it.

29.4 The Contractor shall not employ any Subcontractors that are not properly licensed with Lake Havasu City and the State of Arizona. Changes of Subcontractors listed with the Proposal shall be made only with the approval of the Owner.

29.5 Nothing contained in these Contract Documents shall be construed as creating any contractual relationship between any Subcontractor and the Owner; the Contractor shall be as fully responsible to the Owner for the acts and omissions of Subcontractors, and of persons employed by them, as he is for the acts and omissions of persons directly employed by him.

29.6 The Contractor shall, without additional expense to the Owner, utilize the services of specialty Subcontractors on those parts of the Work which are specified or required by State or local laws to be performed by specialty Subcontractors.

29.7 The Contractor shall be responsible for the coordination of all trades, Subcontractors, material and people engaged upon this Work. The Owner will not undertake to settle any differences between the Contractor and his Subcontractors or between Subcontractors.

29.8 The Contractor shall cause appropriate provisions to be inserted in all subcontracts relative to the Work to bind Subcontractors to the Contractor by the terms of the Contract Documents insofar as applicable to the Work of Subcontractors and to give the Contractor the same power as regards terminating any subcontract that the Owner may exercise over the Contractor under any provision of the Contract Documents.

29.9 Nothing contained in this Contract shall create any contractual relation between any Subcontractor and the Owner.

30.0 ENGINEER'S AUTHORITY

30.1 The Engineer shall act as the Owner's representative during the construction period. The Engineer shall decide questions which may arise as to quality and acceptability of materials furnished and Work performed and shall interpret the intent of the Contract Documents in a fair and unbiased manner. The Engineer will make periodic visits to the site and determine if the Work is proceeding in accordance with the Contract Documents.

30.2 The Contractor will be held strictly to the intent of the Contract Documents in regard to the quality of materials, workmanship and execution of the Work. Inspections may be made at the factory or fabrication plant of the source of material supply.

30.3 The Engineer shall not be responsible for the construction means, controls, techniques, sequences, procedures, or construction safety precautions and programs in connection with the Work and will not be responsible for the Contractor's failure to carry out the Work in accordance with the Contract Documents. The Engineer shall not be responsible or have control or charge over the acts or omissions of the Subcontractors, or any of their agents or employees, or any other person performing any of the Work.

30.4 The Engineer shall promptly make decisions relative to interpretation of the Contract Documents.

30.5 The Engineer will have the authority to reject Work which does not conform to the Contract Documents. Whenever, in its opinion, it is considered necessary or advisable for the implementation of the intent of the Contract Documents, the Engineer will have authority to require special inspection or testing of the Work in accordance with the other terms of this Contract whether or not such Work be then fabricated, installed or completed.

31.0 LAND AND RIGHTS-OF-WAY

31.1 Prior to issuance of Notice To Proceed, the Owner shall obtain all land and rights-of-way necessary for carrying out and for the completion of the Work to be performed pursuant to the Contract Documents, unless otherwise mutually agreed.

31.2 The Owner shall provide to the Contractor information which delineates and describes the lands owned and rights-of-way acquired.

31.3 The Contractor shall provide at its own expense and without liability to the Owner any additional land and access thereto that the Contractor may desire for temporary construction facilities, or for storage of materials.

32.0 GUARANTEE

32.1 Except as otherwise specified, all Work shall be guaranteed by the Contractor against defects resulting from the use of inferior materials, equipment, or workmanship for a period of one (1) year from the date the Certificate of Substantial Completion is issued by the Owner, or within such longer period of time as may be prescribed by law or by the terms of any applicable special guarantee required by the Contract Documents.

32.2 If, within any guarantee period, repairs or changes are required in connection with guaranteed Work, which, in the opinion of the Owner, is rendered necessary as the result of the use of materials, equipment, or workmanship which are inferior, defective, or not in accordance with the terms of the Contract, the Contractor shall, promptly upon receipt of notice from the Owner, and without expense, (1) place in satisfactory condition in every particular all of such guaranteed Work, correcting all defects therein; (2) make good all damage to the building, site or Work, or equipment or contents thereof, which in the opinion of the Owner, is the result of the use of materials, equipment, or workmanship which are inferior, defective, or not in accordance with the terms of the contract; and (3) make good any Work or material, or the equipment and contents of said building, site or Work disturbed in fulfilling any such guarantee. If the Contractor, after notice, fails to proceed promptly to comply with the terms of the guarantee, the Owner may have the defects corrected and the Contractor and his surety shall be liable for all expense incurred. The Performance Bond shall remain in full force and effect through the guarantee period.

GUARANTEE

32.3 The Contractor agrees to execute, and to cause each Subcontractor to execute, a written guarantee to the Owner, in substantially the following form:

GUARANTEE FOR:

We hereby guarantee, both jointly and severally, that the improvement which we have installed for the Owner of Project, specifically described as:

**Water Conservation Program Implementation,
Package No. 2
Project No. SS2970**

has been done in accordance with the Contract Drawings and Specifications.

We agree, both jointly and severally, to repair and replace any or all Work included in said improvement, together with any other adjacent work which may be displaced or damaged by so doing, that may prove to be defective in its workmanship or material within a period of one year from date of the Certificate of Substantial Completion, ordinary wear and tear and unusual abuse or neglect accepted.

In the event of our failure to comply with the above mentioned conditions within a reasonable period of time (as determined by the Owner) after being notified in writing by the Owner, we both jointly and severally, do hereby authorize the Owner to proceed to have said defects repaired and made good at our expense, and we will honor and pay the costs and charges therefore upon demand.

Signed _____

Countersigned _____

Local Representative to be contacted for service:

Name _____

Address _____

Phone No. _____

FAX _____

The guarantee form(s) shall be completed and returned with the acknowledgement of the Certificate of Completion.

The failure of the Contractor or any Subcontractor to execute, such guarantee shall not affect the right of the Owner to rely on and enforce the guarantee and the obligations respectively assumed by the Contractor and each Subcontractor under Subparagraph 32.1 and 32.2 hereof.

33.0 ARBITRATION

33.1 Provided both parties mutually agree, all claims, disputes and other matters in question arising out of, or relating to, the Contract Documents or the breach thereof, except for claims which have been waived by the making and acceptance of final payment as provided by Section 23, may be decided by arbitration in accordance with the American Arbitration Association or any other similar body. The foregoing Contract to arbitrate shall be specifically enforceable under the prevailing arbitration law (Arizona Revised Statutes Sections 12-1501, *et seq.*) of the State of Arizona. The award rendered by the arbitrators shall be final, and judgment may be entered upon it in any court having jurisdiction thereof.

33.2 Notice of the demand for arbitration shall be filed in writing with the other party to the Contract Documents and with the American Arbitration Association and a copy shall be filed with the Engineer. The party filing for arbitration may select which arbitration service to use. Demand for arbitration shall in no event be made on any claim, dispute or other matter in question which would be barred by the applicable statute of limitations.

33.3 The Contractor shall carry on the Work and maintain the progress schedule during any arbitration proceedings, unless otherwise mutually agreed in writing.

33.4 The provisions of the Contract pertaining to arbitration are not binding upon Engineer and Engineer cannot be compelled to participate against his will in an arbitration arising out of a dispute over the Contract or Contract Documents unless Engineer so consents in writing to be a party to the arbitration.

34.0 TAXES AND CHARGES

34.1 The Contractor shall pay all State and local sales and use taxes on items, and in a manner as required by the laws and statutes of the State of Arizona and its political subdivisions. The Contractor shall withhold and pay any and all withholding taxes, whether State or Federal, and pay all Social Security charges, State Unemployment Compensation charges, industrial insurance, workers compensation charges, and pay or cause to be withheld, as the case may be, any and all taxes, charges, or fees, or sums whatsoever, which are now or may hereafter be required to be paid or withheld under any laws.

35.0 MISCELLANEOUS CONDITIONS

35.1 In the event that either party to the Contract is required to institute arbitration or litigation to enforce its rights under the terms of the Contract, then the prevailing party in the arbitration or litigation shall be entitled to recover all costs and attorney's fees incurred.

35.2 In the event that any provision contained in the Contract is found to be contrary to the applicable law, then it shall be severed and the remaining provisions of the Contract shall remain in full force and effect.

35.3 The Contract shall be governed by the laws of the State of Arizona.

36.0 CONFLICTS WITHIN THE PLANS OR SPECIFICATIONS

36.1 In the event that a conflict is discovered between sections of the Specifications or between the Plans and the Specifications, the following list of priority shall be used to resolve the conflict:

- A. Executed Change Orders
- B. Addenda
- C. Contract
- D. Special Provisions

- E. General Conditions
- F. Instructions to Bidders
- G. Technical Specifications
- H. Plans
- I. Referenced Standard Specifications or Other Documents

37.0 NONDISCRIMINATION

37.1 The Contractor, with regard to the work performed pursuant to this contract, shall not discriminate on the grounds of race, color, sex, religion, creed, age, physical or mental disability, or national origin or ancestry in any contracts with the public and in the selection and retention of employees or subcontractors, nor in the procurement of materials and leases of equipment.

38.0 INTEGRATION

38.1 This Contract represents the entire Contract between the parties hereto and supersedes any and all prior negotiations or representations, either written or oral.

38.2 Amendments or modifications to the Contract shall be in writing, signed by both parties, or by Change Orders.

38.3 The Contract Documents shall not be construed to create any contractual relationship of any kind between the Engineer and the Contractor, but the Engineer shall be entitled to performance of obligations intended for his benefit, and to the enforcement thereof.

39.0 HAZARD COMMUNICATION PROGRAM

39.1 All contractors working on City projects shall submit a copy of their hazard communication plan to the Fire Prevention Office prior to commencement of work on any project. This will ensure that other individuals on the job site are not unknowingly exposed to a hazardous substance or chemical.

The Fire Prevention Office shall be provided a list of the hazardous substances and the material safety data sheets that are applicable to the work areas of those contract employees.

All contract labor within City facilities will be treated the same as regular employees with regard to this hazard communication standard.

**** END OF SECTION ****

SECTION 00800
SPECIAL PROVISIONS

1.0 SCOPE

These Special Provisions supplement and modify the General Conditions, Technical Specifications, and Plans. All requirements and provisions of the General Conditions, Technical Specifications, and Plans apply except where modified by these Special Provisions.

2.0 PROJECT DESCRIPTION

This project consists of converting the irrigation water source at various locations along Arizona Highway 95 and at Cypress Park, Jack Hardie Park, and the ASU Campus from potable water to reclaimed water. This will involve disconnecting the landscape irrigation connections along the highway, the parks, and ASU campus irrigation systems from potable water service and reconnecting them to reclaimed water lines. The project includes the installation of approximately 1,260 linear feet of 4-inch DR 18 PVC, approximately 1,140 linear feet of 4-inch Schedule 80 PVC, and approximately 670 linear feet of 2-inch Schedule 80 PVC, associated tapping saddles, gate valves, fittings and appurtenances, and landscaping and surface replacement for areas disturbed by the work, and associated electrical and instrumentation. The project also includes installation of new motorized valves in valve vaults at the intersection of Smoketree and Arizona Highway 95, modifications to an existing lift station, including a new hydropneumatic tank and associated appurtenances at the Mulberry Wastewater Treatment Plant, and a packaged reuse booster pump station at the Island Wastewater Treatment Plant.

3.0 DEFINITION OF TERMS

Wherever in these documents the word "OWNER" appears, it shall be understood to mean Lake Havasu City, Arizona, the governing body of which is the City Council. Wherever in these documents the word "CONTRACTOR" appears, it shall be understood to mean the party or parties contracting with the Owner to perform the Work. Wherever in these documents the word "ENGINEER" appears, it shall be understood to mean Lake Havasu City Public Works Department, Engineering Division, or Authorized Agent.

4.0 PRECONSTRUCTION CONFERENCE

Within ten (10) days after the contract has been awarded, but before the start of construction, the ENGINEER will schedule a conference to be held at the site of the project for the purpose of discussing such matters as project supervision, onsite inspections, progress schedules and reports, payrolls, payments to Contractors, equal employment opportunity, contract change orders, insurance, safety, and any other items pertinent to the project. The Contractor shall arrange to have all supervisory personnel connected with the project on hand to meet with the representatives of the Owner and the Engineer.

5.0 COMPLIANCE WITH LAWS AND LABOR MATERIAL REQUIREMENTS

The Contractor shall conduct the work in compliance with all existing state and national laws and county and municipal ordinance and regulations limiting or controlling the work in any manner. Particular attention is called to the following State of Arizona laws:

WORKMAN'S COMPENSATION INSURANCE All personnel working on the project shall be covered by Workmen's Compensation Insurance as provided or approved by the Arizona Industrial Commission in accordance with ARS 23-901 et. seq.

EMPLOYMENT OF ALIENS Employment of aliens on Public Works projects prohibited. ARS 34-301 and residence requirements for employees, ARS 34-302.

The Contractor understands and acknowledges the applicability to it of the American with Disabilities Act, the Immigration Reform and Control Act of 1986 and the Drug Free Workplace Act of 1989. The following is only applicable to construction contracts: The Contractor must also comply with A.R.S. § 34-301, "Employment of Aliens on Public Works Prohibited", and A.R.S. § 34-302, as amended, "Residence Requirements for Employees".

Under the provisions of A.R.S. §41-4401, Contractor hereby warrants to the City that the Contractor and each of its subcontractors ("Subcontractors") will comply with, and are contractually obligated to comply with, all Federal Immigration laws and regulations that relate to their employees and A.R.S. §23-214(A) (hereinafter "Contractor Immigration Warranty").

A breach of the Contractor Immigration Warranty shall constitute a material breach of this Contract and shall subject the Contractor to penalties up to and including termination of this Contract at the sole discretion of the City.

The City retains the legal right to inspect the papers of any Contractor or Subcontractors employee who works on this Contract to ensure that the Contractor or Subcontractor is complying with the Contractor Immigration Warranty. Contractor agrees to assist the City in regard to any such inspections.

The City may, at its sole discretion, conduct random verification of the employment records of the Contractor and any of subcontractors to ensure compliance with Contractor's Immigration Warranty. Contractor agrees to assist the City in regard to any random verifications performed.

Neither the Contractor nor any of Subcontractor shall be deemed to have materially breached the Contractor Immigration Warranty if the Contractor or Subcontractor establishes that it has complied with the employment verification provisions prescribed by sections 274A and 274B of the Federal Immigration and Nationality Act and the E-Verify requirements prescribed by A.R.S. §23-214, Subsection A.

The provisions of this Article must be included in any contract the Contractor enters into with any and all of its subcontractors who provide services under this Contract or any subcontract. "Services" are defined as furnishing labor, time or effort in the State of Arizona by a contractor or

subcontractor. Services include construction or maintenance of any structure, building or transportation facility or improvement to real property.

6.0 COPIES OF DOCUMENTS

The Owner will furnish to the Contractor one electronic copy of the Contract Documents in pdf format, unless otherwise requested.

7.0 DRAWINGS OF RECORD

Two sets of the Contract Documents are to be kept at the job site, maintained in good condition, and marked daily by the Contractor as the work proceeds. The Contract Documents shall be kept available for inspection by the OWNER at all times, and shall be kept up to date.

8.0 CONTRACT TIME

The contract time shall be 270 CALENDAR DAYS from the NOTICE to PROCEED with the following intermediate completion dates:

- 10 days after NTP: Secure Purchase Order for Island WWTP Reuse Package Booster Pump Station and Mulberry WWTP Hydropneumatic Tank.
- 30 days after NTP: Submit shop drawings for Island WWTP Reuse Package Booster Pump Station and Mulberry WWTP Hydropneumatic Tank.
- 60 days after NTP: Pump cans for Island WWTP Reuse Package Booster Pump Station arrive on site.
- 70 days after NTP: All below grade work associated with Island WWTP Reuse Package Booster Pump Station is complete.
- 80 days after NTP: All work associated with the MOVs at the Island WWTP is complete.
- 90 days after NTP: Complete installation, including electrical, instrumentation, and integration of motor operated valves and vaults on Oak Drive and at Smoketree and AZ Highway 95.
- 150 days after NTP: Island WWTP Reuse Package Booster Pump Station work complete and operable.
- 180 days after NTP: Mulberry WWTP Hydropneumatic Tank work complete and operable.
- 180 days after NTP: Connections complete and operable at the ASU Campus, Jack Hardie Park, and Cypress Park

9.0 SURVEYS

The CONTRACTOR shall layout the WORK, in accordance with the drawings, shall establish all necessary lines, etc., required to complete the work in accordance with the Contract Documents. The CONTRACTOR shall employ an experienced and competent Arizona Registered Land Surveyor (R.L.S.) satisfactory to the OWNER to layout the WORK and to verify lines and elevations as the WORK progresses.

10.0 WEATHER CONDITIONS

In the event of temporary suspension of work, or during inclement weather, or whenever the OWNER shall direct, the Contractor will and will cause his Subcontractors to protect carefully his and their work and materials against damage or injury from the weather. If, in the opinion of the OWNER, any work or materials shall have been damaged or injured by reason of failure on the part of the Contractor or any of his subcontractors to so protect his work, such materials shall be removed and replaced at the expense of the Contractor.

11.0 SUBMITTALS

Prior to construction and as soon as possible, the Contractor shall supply all submittals required by the Technical Specifications or as requested by the Owner.

12.0 INSPECTION OF THE WORK

The Owner intends to provide a full-time resident inspector for the project. The resident inspector will be available for a forty (40) hour period during the week from Monday through Friday during the period of the Contract. In the event the Contractor elects to work outside the forty (40) hour week that occurs between Monday through Friday, such as Saturday, Sunday or legal holidays, in accordance with Section 17.0 of the General Conditions the Contractor will be responsible for all inspection, engineering, and testing costs incurred during that period. For any inspection work performed on Saturday, Sunday, or local municipal holidays the minimum chargeable time shall be four (4) hours. The Owner reserves the right to deduct these additional inspection, engineering, and testing costs directly from the Contractor's payments.

13.0 WATER AND POWER

A. WATER

Water is available from the Water Department at no cost to the Contractor. The Contractor shall make application and obtain a hydrant meter from the Water Department for the purpose of metering the use of water on the project. The Contractor shall adhere to all conditions stated in the Meter Application, including payment of a deposit for the meter, return of the meter to the Water Department each month during the project for reading, and notification to the Water Department prior to any change in the location of the hydrant meter. The maximum water to be drawn off a hydrant at any time is 200 gpm (water

drawn from 4" hydrant whenever available). Water shall only be drawn off hydrants approved by the Lake Havasu City Water Superintendent or his authorized representative.

B. POWER

All power for lighting, operation of Contractor's plant or equipment or for any other use as may be required for proper completion of the work to be performed under the provisions of these contract documents, shall be provided by the Contractor at his sole cost and expense.

14.0 BURNING OF VEGETATION

No burning of vegetation will be allowed.

15.0 MATERIALS TESTING

A. CONSTRUCTION TESTING

All quality control testing must be provided by CONTRACTOR. The material and workmanship provided during construction will be tested on a regular basis by the CONTRACTOR. It shall be the responsibility of the CONTRACTOR, at no additional cost, to provide material samples for testing at the **OWNER's** request.

The CONTRACTOR shall be responsible for charges resulting from failed tests, costs for retesting shall be based upon hourly and/or individual test rates. In the event any portion of the project is rejected because of substandard work, all materials testing, engineering, and inspection costs associated with corrective measures shall be chargeable to the CONTRACTOR at the current respective rates.

B. PRELIMINARY MATERIALS TESTING

All preliminary materials testing and mix design testing required by the specifications to ensure materials and mix designs are suitable for project use will be the responsibility of the CONTRACTOR at no additional cost to the OWNER.

16.0 CLEANUP AND POLLUTION CONTROL

A. GENERAL

The CONTRACTOR shall be responsible for the removal of all debris, litter and waste from the job site(s) and/or equipment maintenance area and the restoration of any and all areas affected, directly or indirectly by the construction, transportation of equipment or materials and/or by the acts of neglect or omission by his employees.

All debris, litter, etc., shall be disposed of in accordance with prevailing ordinance or law. Open burning of trash, debris, etc., will not be permitted.

Such clean-up operations shall be on a daily basis. All pavement, concrete, brush, rocks, excess materials, etc. accumulated or removed during the course of construction must be disposed of in those areas designated by the Engineer or his authorized representative, including but not limited to the Lake Havasu City Landfill. All costs for disposal, including gate or tipping fees, etc. are the responsibility of the Contractor. This material must be disposed of within ten (10) days of time of removal. If the areas in question are not cleaned up to the satisfaction of the ENGINEER, progress payments will be withheld until clean-up is completed and approved by the ENGINEER, or, in the case of private projects, other legal action will be taken.

B. TEMPORARY FACILITIES

The CONTRACTOR shall provide temporary mailboxes and traffic control signs where necessary until completion of backfilling and clean-up.

C. SOLID WASTES

All solid wastes shall be removed and disposed of in accordance with prevailing ordinance or law. Clean-up shall be completed on a daily basis. All costs for disposal shall be the responsibility of the Contractor, and shall be considered incidental to the costs of the various bid items.

All spilled paving material shall be removed and disposed of prior to final acceptance and payment.

D. MAINTENANCE AREAS

Maintenance areas shall be kept clean during construction and shall be free of litter at all times. All empty containers, debris, waste, etc., shall be removed and disposed of prior to final acceptance. Upon inspection by the ENGINEER, the CONTRACTOR may be required to dress the surface of the ground, dependent upon the extent of spillage of petroleum products on the surface. If so directed, such dressing shall consist of scarifying the surface to a depth of six (6) inches and moving and compacting the soil in such a way as to blend the spill areas into clean soil and restore the surface by partial compaction.

E. POLLUTION

The CONTRACTOR shall be held responsible for acts leading to pollution of water, air or land by any means.

Open burning of trash, debris, etc., will not be permitted anywhere in the City limits.

The discharge of any pollutants upon the surface of the ground, or into any stream, ravine, wash or body of water which may result in pollution of the public water supply, or of groundwater contributory thereto, will not be permitted.

Violation of these conditions will be cause for the termination of work, and possible legal action.

F. REMOVAL AND REPLACEMENT OF SIGNS, MAILBOXES, ETC.

It is the responsibility of the CONTRACTOR to remove all poles, etc. which are located within the construction area and replace at the time of backfilling and clean-up in the locations determined by the Street Superintendent. In the case of landscaping or other private items located in the construction area, the CONTRACTOR shall hand-deliver a written notice to all residences in that area stating his intentions to perform construction activities and shall do so at least five (5) working days prior to work commencing. If, at the time of construction these items are still in the construction area, the CONTRACTOR is to remove and dispose of them properly. All signs and mailboxes shall be permanently installed within forty-eight (48) hours of completion of construction activities.

G. NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) GENERAL PERMIT

At the time of the preconstruction conference, the contractor shall submit, for the Engineer's approval, a program which includes all the measures which the contractor proposes to take for the construction of permanent erosion control work specified in the contract and all the temporary control measures to prevent erosion and pollution of streams, lakes and reservoirs.

Permanent erosion control work and pollution prevention measures shall be performed at the earliest practicable time consistent with good construction practices. Temporary work and measures are not meant to be performed in lieu of permanent work specified in the contract.

Construction of drainage facilities as well as the performance of other contract work which will contribute to the control of erosion and sedimentation shall be carried out in conjunction with earthwork operations or as soon thereafter as possible.

Except for that approved in writing by the Engineer, the contractor shall perform no clearing and grubbing or earthwork until the contractor's program has been approved.

If in the opinion of the Engineer, clearing and grubbing, excavation, or other construction operations are likely to create an erosion problem because of the exposure of erodible earth material, the Engineer may limit the surface area to be disturbed until satisfactory control measures have been accomplished. Unless otherwise permitted by the Engineer, the contractor shall not expose an area of erodible earth material greater than 217,800 square feet at any one location.

The Engineer may order the contractor to provide immediate measures to control erosion and prevent pollution. Such measures may involve the construction of temporary berms, dikes, dams, sediment basins and slope drains; the use of temporary mulches, mats and seeds and the use of other devices, methods, items, etc., as necessary.

At any time the contractor proposes to change his/her schedule of operations, the contractor shall review and update his/her erosion and pollution control program and submit it to the Engineer for approval.

The contractor shall not be entitled to additional compensation or an extension of contract time for any delays to the work because of the contractor's failure to submit an acceptable erosion and pollution control program.

Erosion control and pollution prevention work specified in the contract which is to be accomplished under any of the various contract items will be paid for by the bid item. Any additional work required by the Owner will be paid for by the Force Account set up for this work.

The cost of any erosion control and pollution prevention work which may be proposed by the contractor in his/her program, in addition to that specified in the contract, will be considered as included in the prices bid for contract items.

17.0 DUST CONTROL

It shall be the Contractor's responsibility to provide adequate water for dust control. It is imperative that the air quality standards are maintained. In addition, dust could be quite hazardous in the everyday operations. It shall be the Contractor's responsibility to ensure that all regulations for air quality and safety are met.

18.0 SUPERVISORY PERSONNEL

It is the intent of these Specifications to provide a completed project which will in every way reflect the work of competent journeyman mechanics in the various trades represented. The Contractor shall ensure that each portion of the work is supervised by a qualified person, well versed in the operation of the various tools required for the trade, the method in which the work is to be done, and a knowledge of the general requirements of the construction work. All work is to be done in accordance with the latest methods devised for such work to ensure the highest quality product.

19.0 SAFETY REQUIREMENTS

The Contractor shall comply with all pertinent provisions of the Department of Labor "Safety and Health Regulations for Construction" (29 CFR Part 1518, 36 CFR 7340), with additions or modifications thereto, in effect during construction of this project.

THE FOLLOWING MEASURES OR PROVISIONS ARE TO BE ADHERED TO AT ALL TIMES DURING THE CONSTRUCTION OF THIS PROJECT:

- A. All heavy construction machinery to include trenching machines, bulldozers, backhoes, etc., must be equipped with a roll bar meeting the requirements of the above regulation.
- B. Safety helmets will be worn by all personnel working at the site. In addition, all spectators and inspectors will be required to wear safety helmets in construction zone.
- C. Steel toe safety shoes or boots will be worn by all personnel working at the site.

20.0 PRESERVATION OF BENCH MARKS AND MONUMENTS

The Contractor shall exercise caution to ensure that permanent bench marks, monuments, established property corners, survey lines, and points are not damaged or disturbed by this work. If any survey monuments, property corners, survey lines or points are damaged or disturbed, the Contractor's representative shall immediately notify the inspector. All centerline survey monumentation located in pavement removal areas shall be replaced by an Arizona Registered Land Surveyor (R.L.S.) after completion of the pavement removal and replacement operations. All costs incurred to re-establish such points shall be borne by the Contractor.

21.0 DISPOSAL OF EXCESS MATERIAL

Excess soil and unsuitable materials shall be removed from the site by the Contractor at his own expense and disposed of in accordance with the Contract Documents unless otherwise permitted herein. In the event the Contractor chooses to utilize local private lots to dispose of excess material, the Contractor must provide the Engineer with written permission from the lot owner prior to utilizing the lot. Placing material suitable for fill on vacant lots will require a Grading Permit in advance of placing the material.

22.0 REFERENCE STANDARD SPECIFICATIONS

Where standard specifications or testing methods have been referred to, such as ASTM or AASHTO, the intent is to refer to the latest applicable issue or revision of such specifications or testing methods. The following abbreviations are used in these specifications.

AWWA	American Waterworks Association
AASHTO	American Association of State Highway and Transportation Officials
ACI	American Concrete Institute
AI	Asphalt Institute
AISI	American Iron and Steel Institute

ANSI	American National Standards Institute (formerly the USA Standards Institute)
ASTM	American Society for Testing and Materials
NSF	National Sanitation Foundation
S.P.W.C.	Standard Specifications for Public Works Construction. (Wherever written herein shall mean "Maricopa Association of Governments, Arizona Specification for Public Works Construction".) The "Sample Forms" and "Part 100 – General Conditions" of these Standard Specifications for Public Works Construction are excluded from the documents for this project.

23.0 CODES, ORDINANCES AND LOCAL SPECIFICATIONS

All work under this project shall be performed in strict accordance with these specifications and the Standard Specifications for Public Works Construction (SPWC). Where any conflict occurs between these plans and specifications and the local codes and ordinances in effect at the time, such codes and ordinances shall take precedence over these plans and specifications only if these plans and specifications are inferior as to materials and workmanship called for by such codes and ordinances.

24.0 INTERFERING STRUCTURES AND UTILITIES

The Contractor shall notify Blue Stake (1-800-782-5348) at least three (3) working days prior to any excavations.

The Contractor shall exercise all possible caution to prevent damage to existing structures and utilities, whether above ground or underground. The Contractor shall notify all utility offices concerned at least seventy-two (72) hours in advance of construction operations in which a utility's facilities may be involved.

Any structure or utility damage caused by the work shall be repaired or replaced in a condition equal to or better than the condition prior to the damage. Such repair or replacement shall be accomplished at the Contractor's expense without additional compensation from the Owner.

If interfering structures or installations such as vaults, manholes, valves, utility poles, guy wires, or anchors are encountered, the Contractor shall notify the Engineer and contact the appropriate utility or structure owner at least seven (7) days in advance of construction to arrange for protection or relocation of the structure.

The Contractor shall remove, protect and/or replace all existing structures, utilities or other improvements and similar items within the proposed improvements at his own expense without additional compensation from the Owner unless specifically provided for as a pay item of work by

the Specifications or as otherwise provided for on the Plans. Replacement shall be in a manner and in a condition at least equivalent to, or better than, the original condition.

If the Contractor encounters existing facilities which will prevent the construction of any facility and which are not properly shown on the Plans, he shall notify the Owner before continuing with the construction in order that the Owner may make such field revisions as necessary to avoid conflict with the existing structure. The cost of waiting or "down" time during such field revision shall be borne by the Contractor without additional cost to the Owner. If the Contractor fails to notify the Owner when an existing structure is encountered, but proceeds with the construction despite this interference, he does so at his own risk. In particular, when the location of the new construction will prohibit the restoration of existing structures to their original condition; the Contractor shall notify the Engineer and contact the utility or structure owner so a field relocation may be made if possible to avoid the conflict.

In the event of interruption to any utility service as a result of accidental breakage or as a result of being exposed or unsupported, the Contractor shall promptly notify the proper authority. He shall cooperate with the said authority in restoration of service as promptly as possible and shall bear all costs of repair. In no case shall interruption of any utility service be allowed to exist outside working hours unless prior approval of the Owner is received.

Neither the Owner nor its officers or agents shall be responsible for damages to the Contractor as a result of the locations of the water and sewer lines or utilities being other than those shown on the Plans or for the existence of water, sewer lines or utilities not shown on the Plans.

25.0 AIR QUALITY - OPERATING PERMITS

The Contractor may be required to obtain registration certificates and/or operating permits for sources of air pollution.

Information concerning these certificates and permits may be obtained from:

The Office of Air Quality
Arizona Department of Environmental Quality
P.O. Box 600
Phoenix, AZ 85001-0600
(602) 207-2300

26.0 ADJUST UTILITIES TO FINISHED GRADE

The Contractor shall be responsible for locating all manhole rims, valve boxes, meter boxes, utility vaults, etc., and setting them to finished grade. The Contractor shall adjust sewer and water facilities to finished grade in accordance with the specifications within seven (7) days after street surfacing has been completed on each street. All valves and/or manholes will be made visible and accessible for emergency use within 24 hours. It shall be the responsibility of the Contractor to coordinate with the various private utility companies so that they can adjust their facilities to

finished grade at an appropriate time. Adjust all facilities in accordance with these specifications and the MAG Standard Details, as modified by Lake Havasu City.

27.0 SAFETY, HEALTH AND SANITATION PROVISIONS

The Contractor shall provide and maintain in a neat, sanitary condition such accommodations for the use of his employees as may be necessary to comply with the requirements and regulations of the Arizona State Department of Health.

The Contractor shall provide all safeguards, safety devices and protective equipment and take any other needed actions, on his own responsibility or as the Owner may determine, reasonably necessary to protect the life and health of employees on the job, the safety of the public and to protect property in connection with the performance of the work covered by the contract.

Precaution shall be exercised by the Contractor at all times for the protection of persons (including employees) and property. The Contractor shall comply with the provisions of all applicable laws, pertaining to such protection including all Federal and State occupational safety and health acts, and standards and regulations promulgated thereunder.

28.0 PUBLIC SAFETY AND TRAFFIC CONTROL

Every attempt shall be made to provide public safety during the construction of the project. Traffic control shall be performed in accordance with Section 2650, Traffic Control, of the Technical Specifications.

During all construction operations, the Contractor shall construct and maintain such facilities as may be required to provide access for all property owners to their property. No person shall be cut off from access to his residence or place of business for a period exceeding two (2) hours, unless the Contractor has made a special arrangement with the affected persons. It shall be the Contractor's responsibility to notify all adjacent property owners of the construction activity and the schedule of such activities.

The CONTRACTOR shall submit for approval a traffic control and barricade plan within ten (10) days of receipt of Notification of Award of Contract. There shall be no deviations from the approved barricade plan unless a revised barricade plan is submitted and approved. The CONTRACTOR shall issue a news release once a week for duration of the project. The release will be published in Sunday's newspaper and shall indicate the area in which the CONTRACTOR will be performing work for that week.

Businesses must be notified forty-eight (48) hours prior to any restrictions on normal parking areas used by their employees or patrons.

The CONTRACTOR shall contact, cooperate with, and give notice to each resident, homeowner, business or school that will be affected by any part of the construction process, particularly concerning temporary interruptions to vehicular access.

Written notice of the approximate schedule and explanation of work shall be given to each resident, homeowner, business or school at least five (5) days prior to commencement of work in the area. Verbal door-to-door communication shall be made at least twenty-four (24) hours prior to construction to remind all affected parties of the construction to take place.

The OWNER shall receive a copy of all notifications to residents. In the event of complaints by residents, the OWNER may require the CONTRACTOR to provide documentation (ie. check list) showing the date & time of the verbal door-to-door communication.

In addition, the CONTRACTOR is responsible to answer and resolve any conflicts that may arise between a homeowner or business owner and himself during the construction process.

The CONTRACTOR shall provide and station competent flaggers whose sole purpose shall be to direct the movement of public traffic through or around the work. Proper advanced warning signs shall be in place when flaggers are working and removed when work requiring flaggers is completed. Flaggers must be used to assist trucks for safe ingress and egress whenever truck movements may interfere with safe passage through the work zone.

All traffic control devices that are not in use or will not be used for a period greater than 72 hours or that are determined by the Engineer to be unnecessary, confusing, or causing an unsafe condition, shall be removed by the CONTRACTOR from the public right-of-way immediately upon notification by the Engineer.

Every attempt shall be made to provide public safety during the construction of the project. Traffic control shall be performed in accordance with Section 2650, Traffic Control, of the Technical Specifications. No person shall be cut off from access to his residence or place of business for a period exceeding six (6) hours, unless the Contractor has made a special arrangement with the affected persons. In addition, no work will be scheduled which will interrupt regular trash pickup to either residential or commercial properties. It will be the CONTRACTOR'S responsibility to coordinate his activities with the local trash haulers.

No streets, avenues, boulevards or cul-de-sacs will be closed to traffic unless prior arrangements have been made and approval has been obtained from the ENGINEER.

29.0 TEMPORARY FACILITIES ON SITE

A. General

Except as otherwise provided, the Owner shall bear no costs of temporary facilities and their removal.

B. Temporary Utility Services

The Contractor shall provide temporary electric power as necessary for the execution of the Work, including that required by all Subcontractors. He shall make the necessary

arrangements with Owner, shall bear all costs for these temporary services and shall furnish and install all necessary transformers, metering facilities and distribution centers from branch circuits as he may require.

The Contractor shall provide lighting and outlets in temporary structures throughout the project as may be required for safety, proper performance and inspection of the Work. If operations are performed during hours of darkness, or if natural lighting is deemed insufficient by Owner, the Contractor shall provide adequate floodlights, clusters and spot illumination. The use of permanently installed lighting fixtures, lamps and tubes for work will not be permitted except by special permission of Owner. The Contractor shall make arrangements with Subcontractors for electrical services and lighting as may be necessary in the performance of their work.

Temporary water service lines, if required, shall be installed and removed by the Contractor, who shall pay all charges for making the connections, running the temporary lines, removing the temporary lines at the completion of the Work and disconnecting the services. All relocations required to clear the work of others shall be performed by the Contractor when requested by the Owner.

C. Temporary Structures

Prior to starting Work, the Contractor shall, as directed by Owner, provide and maintain suitable temporary office facilities for the duration of the Project as required for the Contractor's project administration; and all necessary sheds and facilities for the proper storage of tools, materials and equipment employed in the performance of the Work.

D. Toilet Facilities

The Contractor shall provide and maintain temporary toilet facilities for the duration of operations, which shall be maintained in a clean and sanitary condition acceptable to Owner and in full compliance with applicable regulations of any public authority.

E. Telephones

The Contractor shall provide, maintain and pay for telephone services for the duration of the Work as required for the Contractor's operation.

F. Fence and Barricades

The Contractor shall provide such protective fences and barricades as he may deem necessary for public safety and to protect his storage areas and the Work in place. The location and appearance of all fences shall be subject to the approval of the Owner.

G. Contractor Parking

The Contractor shall not park his equipment, nor allow his personnel to park, in any area except those specifically designated by the Owner.

H. Temporary Living Quarters

Temporary living quarters shall not be allowed on the job site or on publicly owned properties. In addition, all Lake Havasu City Zoning Codes for the area in question shall be strictly adhered to.

I. Removal of Temporary Construction

The Contractor shall remove temporary office facilities, toilets, storage sheds and other temporary construction from the site as soon as, in Owner's opinion, the progress of Work permits. He shall recondition and restore those portions of the site occupied by the same to a condition equal to or better than it was prior to construction.

30.0 ACCESS TO WASHES

A. Unless otherwise mentioned herein, the Contractor must obtain written permission from the Owner prior to gaining access or utilizing washes or City parcels for any purpose. Request for access to washes and City parcels will be reviewed on a case by case basis. The Contractor shall have access to washes and City parcels via public streets and/or private easements only. For the purposes of this paragraph, "private easement" means a Contract(s) by and between the Contractor and a property owner, in writing, authorizing the Contractor to travel across the property owner's real property in order to have ingress or egress to washes, parcels or any portion thereof. Such Contract(s), if any, shall be filed with the Office of the City Engineer before the Contractor may exercise the rights thereunder granted. Access to any wash, parcels, or portion thereof by any means not in compliance with the terms of this paragraph shall be deemed a trespass and a breach of the terms of the Contract(s).

B. Violations of the provisions of subparagraph (a.) hereof, shall entitle the City to deduct the sum of One Thousand Dollars (\$1,000.00) from the monies due to Contractor as and for liquidated damages for each such violation. For the purposes of this paragraph, each entry by a vehicle upon land for which Contractor has not received permission to enter shall be deemed a separate violation of subparagraph (a.) hereof.

31.0 COORDINATION AND COOPERATION WITH UTILITY COMPANIES AND OTHER TRADES

A. Coordination/Interruption

The Contractor is responsible to coordinate work with all utility companies and other trades, on or affecting the job, for an efficient and effective execution of the complete project.

The Contractor shall carefully examine all work that may conflict, and plan removal and/or installation details in advance of the construction to avoid any such conflict. Failure on the contractor's part to coordinate with any and all utilities, public or private, shall preclude the City's consideration for additional time or cost.

B. Permission Required

Utility mains and utility service to buildings shall not be cut off or otherwise interrupted without the Contractor obtaining permission from the Owner in each and every instance.

C. Scheduling of Interruptions

Where utilities serve facilities or buildings in use, interruptions in service shall be scheduled during the hours when the facility is not in operation. Any overtime costs occasioned thereby shall be regarded as incidental to, and included within, the Contract Sum.

D. General Requirements

Prior to interrupting any utility service, the Contractor shall ascertain that he has the proper materials, together with adequate workmen and equipment, to complete the Work with a minimum of delay.

E. Project Electrical Service

The Contractor is responsible to coordinate with Unisource, Electric Division, to determine the extent of work to be performed by Unisource and by the Contractor to provide electric service for the finished product. The Contractor is also responsible to contact Unisource to determine the hardware required by Unisource to provide service to the final product. Unisource does not provide service to delta connections.

** END OF SECTION **

SECTION 01110
SUMMARY OF WORK

PART 1 - GENERAL

1.1 Summary

This Section summarizes the Work as covered in detail in the complete Contract Documents.

1.2 Project Description

A. Description of Project: This project consists of converting the irrigation water source at various locations along Arizona Highway 95 and at Cypress Park, Jack Hardie Park, and the ASU Campus from potable water to reclaimed water. This will involve disconnecting the landscape irrigation connections along the highway, the parks, and ASU campus irrigation systems from potable water service and reconnecting them to reclaimed water lines. The project includes the installation of approximately 1,260 linear feet of 4-inch DR 18 PVC, approximately 1,140 linear feet of 4-inch Schedule 80 PVC, and approximately 670 linear feet of 2-inch Schedule 80 PVC, associated tapping saddles, gate valves, fittings and appurtenances, and landscaping and surface replacement for areas disturbed by the work, and associated electrical and instrumentation. The project also includes installation of new motorized valves in valve vaults at the intersection of Smoketree and Arizona Highway 95, modifications to an existing lift station, including a new hydropneumatic tank and associated appurtenances at the Mulberry Wastewater Treatment Plant, and a packaged reuse booster pump station at the Island Wastewater Treatment Plant.

B. Work Covered by Contract Documents: Includes all construction activities associated with the construction of Water Conservation Program Implementation, Package No. 2 and appurtenances as identified on the Contract Drawings. The work also provides for the complete restoration of all areas disturbed by construction operations.

1.3 Contractor's Use of Premises

A. Limited Use

1. Limit use of the premises for storage and execution of the Work to allow for Owner occupancy. Confine operations to areas within Contract limits indicated. Portions of the Site outside the Contract limits shall not be disturbed.

2. Coordinate with other separate contractors and Owner to avoid interference of operations.
3. Conduct operations so as to ensure the least inconvenience to Owner and the general public.

1.4 Owner's Use of Premises

- A. Partial Owner Occupancy:** The Owner reserves the right to occupy and to use the area outside of the Contract limits.

1.5 Work Sequence

- A. General:** The general sequence of construction will be determined by the Contractor and submitted to the City for approval. The Contractor shall be required to construct the project as soon as possible

The Contractor shall submit a detailed resource based schedule, including a work breakdown structure within 10 days of the issuance of the Notice of Award. The schedule shall include the following intermediate completion dates:

10 days after NTP: Secure Purchase Order for Island WWTP Reuse Package Booster Pump Station and Mulberry WWTP Hydropneumatic Tank.

30 days after NTP: Submit shop drawings for Island WWTP Reuse Package Booster Pump Station and Mulberry WWTP Hydropneumatic Tank.

60 days after NTP: Pump cans for Island WWTP Reuse Package Booster Pump Station arrive on site.

70 days after NTP: All below grade work associated with Island WWTP Reuse Package Booster Pump Station is complete.

80 days after NTP: All work associated with the MOVs at the Island WWTP is complete.

90 days after NTP: Complete installation, including electrical, instrumentation, and integration of motor operated valves and vaults on Oak Drive and at Smoketree and AZ Highway 95.

150 days after NTP: Island WWTP Reuse Package Booster Pump Station work complete and operable.

180 days after NTP: Mulberry WWTP Hydropneumatic Tank work complete and operable.

180 days after NTP: Connections complete and operable at the ASU Campus, Jack Hardie Park, and Cypress Park

Upon completion of the schedule submittal and approval, the Contractor can begin construction of the facilities. The construction schedule should begin with obtaining all necessary permits in order to perform the work as shown on plans as well as equipment procurement. Coordinate temporary shutdowns. Final connections to irrigation customers, other than those associated with intermediate completion date, cannot be made until Island WWTP Package Pump Station and MOVs at Smoketree and Arizona Highway 95 are in place. Complete testing, startup, and commissioning.

When all work has been completed the Contractor shall proceed with restoring the site to pre-existing conditions or better. Survey grade control may be required in certain locations to establish and supplement as-built drawings.

- B. Continuous Service of Existing Facilities:** Exercise caution and schedule operations to ensure that functioning of present facilities will not be disrupted.

PART 2 – MATERIALS – Not Applicable

PART 3 – EXECUTION – Not Applicable

END OF SECTION

THIS PAGE INTENTIONALLY LEFT BLANK

SECTION 01210
MEASUREMENT AND PAYMENT

PART 1 - GENERAL

1.1 Description

The outline of measurement and payment in this section is intended to provide a general guideline to the Contractor in preparing bids and submitting pay requests. Listing of work included in each bid item is not intended to include all work, but is to provide general guidance to the Contractor for allocating costs. All work will be paid for on a unit price basis with payment made for the quantity of each item completed.

All materials required for construction shall be furnished by the Contractor unless specifically stated. Items not specifically measured and paid for shall be considered as subsidiary items required to complete the installation in accordance with the intent of the contract documents. The Contractor shall include in the unit price bid items, all costs associated with subsidiary items not being measured for payment.

1.2 Authority

Measurement methods delineated in the individual specification sections complement the criteria of this section. In the event of conflict, the requirements of the individual specification section govern.

Take all measurements and compute quantities. The Engineer will verify measurements and quantities.

1.3 Unit Quantities

Quantities indicated in the Bid Form are for bidding and contract purpose only. Quantities and measurements supplied or placed in the Work and verified by the Engineer shall determine payment.

If the actual Work requires more or fewer quantities than indicated, provide the required quantities at the unit prices contracted.

PART 2 – UNITS AND METHODS OF MEASUREMENT AND PAYMENT

2.1 General

All items that are included in the bid for measurement and payment are included herein. All other items of work shall be considered subsidiary to construction and will not be measured for payment.

2.2 UNITS AND METHODS OF MEASUREMENT

2.2.1 Mobilization, Demobilization, Bonds, and Insurance

The Contract Lump Sum Price for "Mobilization, Demobilization, Bonds, and Insurance" shall constitute full compensation for furnishing all materials, labor, equipment, and tools for all required bonds, insurance, mobilization, demobilization of staff and equipment, and any other costs associated with complying with the contract administrative requirements and commencing work at the project site.

Payment for Mobilization, Demobilization, Bonds, and Insurance shall be lump sum and shall not be requested until at least thirty days from the notice to proceed has elapsed.

Payment for this item shall be made in accordance with Table A.

TABLE A

Payment for Mobilization on First Partial Payment	Not to exceed 2.5% of the Total Bid + Force Amount
Subsequent payments for Mobilization	Not to exceed 2.5% of Total Bid + Force Amount
Payment for Mobilization on Final Partial Payment	Any remaining Mobilization in excess of 5% Total Bid + Force Amount

2.2.2 Construction Staking

The quantity of "Construction Staking" measured for payment shall be lump sum.

The Contract lump sum price for "Construction Staking" shall constitute full compensation for furnishing all materials, labor, equipment and tools for the construction staking of all force main and any other piping, connections to irrigation systems, and all other related items. This item also includes all work and materials necessary to complete the work as described in the Plans and Specifications.

2.2.3 Location A Connections – W Acoma Blvd-Industrial Blvd

The quantity of "Location A Connections - W Acoma Blvd-Industrial Blvd" measured for payment shall be lump sum.

The Contract lump sum price for "Location A Connections - W Acoma Blvd-Industrial Blvd" shall constitute full compensation for furnishing all materials, labor, equipment, and tools necessary to disconnect the potable water supply from and connect the reclaimed water supply to the landscape irrigation system. This item includes but is not limited to all traffic control, utility locating, excavation, backfill, compaction required for the construction of the connection, the capping and removal of interfering portions of existing 2-inch potable water main, installation of a 2-inch tapping valve on the existing 18-

01210-2

August 2016

inch reclaimed water main, and installing 2-inch PVC Schedule 80 reclaimed water pipe including all fittings, gate valves, pipe locator ribbon, PRV including box, meter assembly including box, and testing as shown on the Drawings. This item also includes any surface repair in the landscape and elsewhere as required for the construction of the connection. This item also includes all work and materials necessary to complete the work in accordance with the Plans and Specifications.

2.2.4 Location B Connections – Paseo Del Sol

The quantity of "Location B Connections - Paseo Del Sol" measured for payment shall be lump sum.

The Contract lump sum price for "Location B Connections - Paseo Del Sol" shall constitute full compensation for furnishing all materials, labor, equipment, and tools necessary to disconnect the potable water supply from and connect the reclaimed water supply to the landscape irrigation system. This item includes but is not limited to all traffic control, utility location, excavation, backfill, compaction required for the construction of the 4-inch fusible and standard PVC C900 (DR 18) force main, connections, the capping and removal of interfering portions of the existing 2-inch potable water main, installation of a 4-inch tapping valve on the existing 18-inch reclaimed water main, and installing 2-inch PVC Schedule 80 reclaimed water pipe including all fittings, gate valves, restrained joints and/or thrust blocks, tape-wrap coating of ductile iron pipe fittings, and pipe locator ribbon, and meter assembly including vault as shown on the Drawings. This item also includes any surface repair in the roadway, landscape and elsewhere as required for the construction of the connection. This item also includes all work and materials necessary to complete the work in accordance with the Plans and Specifications.

2.2.5 Location C Connections – S Palo Verde Blvd

The quantity of "Location C Connections - S Palo Verde Blvd" measured for payment shall be lump sum.

The Contract lump sum price for "Location C Connections - S Palo Verde Blvd" shall constitute full compensation for furnishing all materials, labor, equipment, and tools necessary to disconnect the potable water supply from and connect the reclaimed water supply to the landscape irrigation system. This item includes but is not limited to all traffic control, utility locating, excavation, backfill, compaction required for the construction of the connection, the capping and removal of interfering portions of the existing 2-inch potable water main, salvage of existing water meter and irrigation loop to LHC, installation of a 2-inch tapping valve on the existing 18-inch reclaimed water main, and installing 2-inch PVC Schedule 80 reclaimed water pipe including all fittings, gate valves, pipe locator ribbon, PRV including box, meter assembly including box, and testing as shown on the Drawings. This item also includes any surface repair in the landscape and elsewhere as required for the construction of the connection. This item also includes all work and materials

necessary to complete the work in accordance with the Plans and Specifications.

2.2.6 Location D Connections – McCulloch Blvd N-Swanson Ave

The quantity of "Location D Connections - McCulloch Blvd N-Swanson Ave" measured for payment shall be lump sum.

The Contract lump sum price for "Location D Connections - McCulloch Blvd N-Swanson Ave" shall constitute full compensation for furnishing all materials, labor, equipment, and tools necessary to disconnect the potable water supply from and connect the reclaimed water supply to the landscape irrigation system. This item includes but is not limited to all traffic control, utility locating, excavation, backfill, compaction required for the construction of the connections, 4-inch PVC C900 (DR 18) force main, installation of a 4-inch tapping valve on the existing 18-inch reclaimed water main, the capping and removal of interfering portions of the existing 1-1/4 inch and 1-1/2 inch potable water main, and installing 1-1/2 inch and 2-inch PVC Schedule 80 reclaimed water pipe including all fittings, gate valves, pipe locator ribbon, PRV including box, meter assembly including box, and testing as shown on the Drawings. This item also includes any surface repair in the landscape and elsewhere as required for the construction of the connection. This item also includes all work and materials necessary to complete the work in accordance with the Plans and Specifications.

2.2.7 Location E Connection – S Smoketree Ave

The quantity of "Location E Connection - S Smoketree Ave" measured for payment shall be lump sum.

The Contract lump sum price for "Location E Connection - S Smoketree Ave" shall constitute full compensation for furnishing all materials, labor, equipment, and tools necessary to disconnect the potable water supply from the landscape irrigation system. This item includes but is not limited to capping and removal of existing irrigation loop and salvage of existing irrigation loop to LHC as shown on the Drawings. This item also includes any surface repair in the landscape and elsewhere as required for the construction of the connection. This item also includes all work and materials necessary to complete the work in accordance with the Plans and Specifications.

2.2.8 Location F Connection – Lake Havasu City Aquatic Center

The quantity of "Location F Connection - Lake Havasu City Aquatic Center" measured for payment shall be lump sum.

The Contract lump sum price for "Location F Connection - Lake Havasu City Aquatic Center" shall constitute full compensation for furnishing all materials, labor, equipment, and tools necessary to disconnect the potable water supply from and connect the reclaimed water supply to the landscape irrigation system. This item includes but is not limited to all traffic control, utility

locating, excavation, backfill, compaction required for the construction of the connections, the capping and removal of interfering portions of the existing 2-inch potable water main, installation of a 2-inch tapping valve on the existing 18-inch reclaimed water main, and installing 2-inch PVC Schedule 80 reclaimed water pipe including all fittings, gate valves, restrained joints and/or thrust blocks, and pipe locator ribbon as shown on the Drawings. This item also includes any surface repair in the landscape and elsewhere as required for the construction of the connection. This item also includes all work and materials necessary to complete the work in accordance with the Plans and Specifications.

2.2.9 Location G Connection – Walnut Dr

The quantity of "Location G Connection - Walnut Dr" measured for payment shall be lump sum.

The Contract lump sum price for "Location G Connection - Walnut Dr" shall constitute full compensation for furnishing all materials, labor, equipment, and tools necessary to connect the reclaimed water supply to the landscape irrigation system. This item includes but is not limited to all traffic control, utility locating, excavation, backfill, compaction required for the construction of the connection, installation of a 4-inch tapping valve on the existing 18-inch reclaimed water main, and installing 4-inch PVC C-900 (DR 18) reclaimed water pipe including all fittings, gate valves, restrained joints and/or thrust blocks, tape-wrap coating of ductile iron pipe fittings, meter assembly including vault, pipe loop assembly, and pipe locator ribbon as shown on the Drawings. This item also includes any surface repair in the landscape and elsewhere as required for the construction of the connection. This item also includes all work and materials necessary to complete the work in accordance with the Plans and Specifications.

2.2.10 Location G Connection – Walnut Dr Electrical and Instrumentation

The quantity of "Location G Connection - Walnut Dr Electrical and Instrumentation" measured for payment shall be lump sum.

The contract lump sum price for "Location G Connection - Walnut Dr Electrical and Instrumentation" shall be full compensation for furnishing all materials, labor, equipment and tools to install all conduits, pull boxes, cable, etc. to complete the work in accordance with the Plans and Specifications.

2.2.11 Location H Connections – Cypress Park

The quantity of "Location H - Cypress Park" measured for payment shall be lump sum.

The Contract lump sum price for "Location H - Cypress Park" shall constitute full compensation for furnishing all materials, labor, equipment, and tools necessary to disconnect the potable water supply from and connect the

01210-5

August 2016

reclaimed water supply to the park's irrigation system. This item includes but is not limited to all traffic control, utility locating, excavation, backfill, compaction required for the construction of the 4-inch PVC C900 (DR 18) force main, 8-inch fusible PVC C900 (DR 18) force main, 3-inch PVC Schedule 80 reclaimed water piping, connections, the capping and removal of interfering portions of the existing 3-inch potable water main, installation of a 4-inch and 8-inch tapping valve on the existing 8-inch reclaimed water main, and installing 4-inch irrigation loop including all electrical wiring, fittings, gate valves, restrained joints and/or thrust blocks, tape-wrap coating of ductile iron pipe fittings, and pipe locator ribbon as shown on the Drawings. This item also includes any surface repair in the roadway, landscape and elsewhere as required for the construction of the connection. This item also includes all work and materials necessary to complete the work in accordance with the Plans and Specifications.

2.2.12 Location I Connections – ASU Campus

The quantity of "Location I Connections- ASU Campus" measured for payment shall be lump sum.

The Contract lump sum price for "Location I Connections - ASU Campus" shall constitute full compensation for furnishing all materials, labor, equipment, and tools necessary to disconnect the potable water supply from and connect the reclaimed water supply to the ASU Campus irrigation system. This item includes but is not limited to all traffic control, utility locating, excavation, backfill, compaction required for the construction of the 4-inch PVC C900 (DR 18) force main, connections, the capping and removal of interfering portions of the existing 2-inch potable water main, and installing 2-inch PVC Schedule 80 reclaimed water pipe and 2-inch copper piping, and modifications to existing irrigation loop including all fittings, gate valves, restrained joints and/or thrust blocks, tape-wrap coating of ductile iron pipe fittings, PRV including box, meter assembly including vault, and pipe locator ribbon as shown on the Drawings. This item also includes any surface repair in the roadway, curb, gutter, sidewalk, landscape and elsewhere as required for the construction of the connection. This item also includes all work and materials necessary to complete the work in accordance with the Plans and Specifications.

2.2.13 Location J Connections – Jack Hardie Park

The quantity of "Location J Connections - Jack Hardie Park" measured for payment shall be lump sum.

The Contract lump sum price for "Location J Connections - Jack Hardie Park" shall constitute full compensation for furnishing all materials, labor, equipment, and tools necessary to disconnect the potable water supply from and connect the reclaimed water supply to the park's irrigation system. This item includes but is not limited to all traffic control, utility locating, excavation, backfill, compaction required for the construction of the 2-inch PVC Schedule 80 force main, connections, the capping and removal of interfering portions of

the existing 2-inch potable water main, gate valves, restrained joints and/or thrust blocks, and pipe locator ribbon as shown on the Drawings. This item also includes any surface repair in the landscape and elsewhere as required for the construction of the connection. This item also includes all work and materials necessary to complete the work in accordance with the Plans and Specifications.

2.2.14 Mulberry WWTP Hydropneumatic Tank

The quantity of "Mulberry WWTP Hydropneumatic Tank" measured for payment shall be lump sum.

The Contract lump sum price for "Mulberry WWTP Hydropneumatic Tank" shall constitute full compensation for procuring the pumping system as specified in Section 13206G.

2.2.15 Mulberry WWTP Hydropneumatic Tank Installation

The quantity of "Mulberry WWTP Hydropneumatic Tank Installation" measured for payment shall be lump sum.

The contract lump sum price for "Mulberry WWTP Hydropneumatic Tank Installation" shall be full compensation for furnishing all materials, labor, equipment, and tools to fully install the Hydropneumatic Tank including piping, excavation, backfill, concrete, pipe supports, equipment supports, testing, and all other appurtenances not included in item 2.2.14, but required for complete and operational Hydropneumatic Tank system.

2.2.16 Mulberry WWTP Hydropneumatic Tank Electrical and Instrumentation

The quantity of "Mulberry WWTP Electrical and Instrumentation" measured for payment shall be lump sum.

The Contract lump sum price for "Mulberry WWTP Electrical and Instrumentation" shall constitute full compensation for furnishing all materials, labor, equipment, and tools necessary to modify the electrical, control and instrumentation systems associated with the new hydropneumatic tank.

2.2.17 Mulberry WWTP Hydropneumatic Tank System Integration

The quantity of "Mulberry WWTP System Integration" measured for payment shall be lump sum.

The contract lump sum price for "Mulberry WWTP System Integration" shall be full compensation for furnishing all materials, labor, equipment and tools

to install perform all system integration required to provide a complete operating system in accordance with the Plans and Specifications.

2.2.18 Island WWTP Reuse Package Booster Pump Station

The quantity of "Island WWTP Reuse Package Booster Pump Station" measured for payment shall be lump sum.

The Contract lump sum price for "Island WWTP Reuse Package Booster Pump Station" shall constitute full compensation for procuring the pumping system as specified in Section 11211.

2.2.19 Island WWTP Reuse Package Booster Pump Station Installation

The quantity of "Island WWTP Reuse Package Booster Pump Station Installation" measured for payment shall be lump sum.

The contract lump sum price for "Island WWTP Reuse Package Booster Pump Station Installation" shall be full compensation for furnishing all materials, labor, equipment, and tools to fully install the Island WWTP Reuse Package Booster Pump Station including piping, excavation, backfill, concrete, pipe supports, equipment supports, testing, and all other appurtenances not included in item 2.2.18, but required for complete and operational Booster Pump Station.

2.2.20 Island WWTP Reuse Package Booster Pump Station Electrical and Instrumentation

The quantity of "Island WWTP Reuse Package Booster Pump Station Electrical and Instrumentation" measured for payment shall be lump sum.

The contract lump sum price for "Island WWTP Reuse Package Booster Pump Station Electrical and Instrumentation" shall be full compensation for furnishing all materials, labor, equipment and tools to install all conduits, cable, electrical supports, etc. to complete the work in accordance with the Plans and Specifications.

2.2.21 Island WWTP Reuse Package Booster Pump Station System Integration

The quantity of "Island WWTP Reuse Package Booster Pump Station System Integration" measured for payment shall be lump sum.

The contract lump sum price for "Island WWTP Reuse Package Booster Pump Station System Integration" shall be full compensation for furnishing all materials, labor, equipment and tools to install perform all system integration required to provide a complete operating system in accordance with the Plans and Specifications.

2.2.22 18-inch Reuse Line Motor Operated Valves and Valve Vaults at Smoketree and AZ95

The quantity of "18-inch Reuse Line Motor Operated Valves and Valve Vaults at Smoketree and AZ95" measured for payment shall be lump sum.

The contract lump sum price for "18-inch Reuse Line Motor Operated Valves and Valve Vaults at Smoketree and AZ95" shall be full compensation for furnishing all materials, labor, equipment, and tools to fully install the valve vaults and motorized valves including all piping, fittings, concrete, hatches, and other appurtenances except electrical and control to the motor operator.

2.2.23 18-inch Reuse Line Motor Operated Valves and Valve Vaults at Smoketree and AZ95 Electrical and Instrumentation

The quantity of "18-inch Reuse Line Motor Operated Valves and Valve Vaults at Smoketree and AZ95 Electrical and Instrumentation" measured for payment shall be lump sum.

The contract lump sum price for "18-inch Reuse Line Motor Operated Valves and Valve Vaults at Smoketree and AZ95 Electrical and Instrumentation" shall be full compensation for furnishing all materials, labor, equipment and tools to install all conduits, cable, electrical supports, etc. to complete the work in accordance with the Plans and Specifications.

2.2.24 18-inch Reuse Line Motor Operated Valves and Valve Vaults at Smoketree and AZ95 System Integration

The quantity of "18-inch Reuse Line Moto Operated Valves and Valve Vaults at Smoketree and AZ95 System Integration" measured for payment shall be lump sum.

The contract lump sum price for "18-inch Reuse Line Motor Operated Valves and Valve Vaults at Smoketree and AZ95 System Integration" shall be full compensation for furnishing all materials, labor, equipment and tools to install perform all system integration required to provide a complete operating system in accordance with the Plans and Specifications.

2.2.25 Oak Drive Line Motor Operated Valve and Valve Vault from Mulberry WWTP

The quantity of "Oak Drive Line Valve and Valve and Vault from Mulberry WWTP" measured for payment shall be lump sum.

The contract lump sum price for "Oak Drive Line Valve and Valve and Vault from Mulberry WWTP" shall be full compensation for furnishing all materials, labor, equipment, and tools to fully install the valve vault and motorized valve including all piping, fittings, concrete, hatches, and

other appurtenances except electrical and control to the motor operator.

2.2.26 Environmental Control Measures

The quantity of "Environmental Control Measures" measured for payment shall be lump sum.

The contract lump sum price for "Environmental Control Measures" shall be full compensation for furnishing all materials, labor, equipment and tools to comply with the environmental controls to mitigate noise, storm water runoff, preparation of the SWPPP document, dust control, and water quality.

2.2.27 Dye Testing

The quantity of "Dye Testing" measured for payment shall be lump sum.

The contract lump sum price for "Dye Testing" shall be full compensation for furnishing all materials, labor, equipment and tools to conduct dye tests at Industrial Blvd/95, Lake Havasu City Aquatic Center, Cypress Park, ASU campus, and Jack Hardie Park. This item also includes all work and materials necessary to complete the work in accordance with the Plans and Specifications.

2.2.28 All Other Work Not Included In Items 2.2.1 through 2.2.27

The quantity of "All Other Work Not Included in Items 2.2.1 through 2.2.27" measured for payment shall be per lump sum.

Payment for this item is the Contract per lump sum price for "All Other Work Not Included in Items 2.2.1 through 2.2.27" shall constitute full compensation for furnishing all materials, labor, equipment, and tools required to complete the project not specifically identified in Bid Items 2.2.1 through 2.2.27. This item also includes all work and materials necessary to complete the work in accordance with the Plans and Specifications.

2.2.29 Force Account

A force account has been established and is indicated in the Bid Form as a lump sum cost item. The value indicated in the Bid Form is to be included in the total bid price for the work. The Contractor shall not consider any monies indicated in the force account item as a part of his payment for the Work or profit or otherwise without written notification by the Owner.

2.3 Measurement Devices

- A.** Weigh Scales: Inspected, tested and certified by the applicable State Weights and Measures Department within the past year.

- B. Platform Scales: Of sufficient size and capacity to accommodate the conveying vehicle.
- C. Metering Devices: Inspected, tested and certified by the applicable State department within the past year.

2.4 Measurement by Weight

Measured by tons as described above.

2.5 Measurement by Volume

Measured by cubic dimension using mean length, width and height or thickness.

2.6 Measurement by Area

Measured by square dimension using mean length and width or radius.

2.7 Linear Measurement

Measured by linear dimension, at the item centerline or meanchord.

2.8 Stipulated Sum/Price Measurement

Items measured by lump sum or each, as appropriate, as a completed item or unit of the work.

2.9 Progress Payments

- A. Contract provides for payment of 90% for completed work until final payment.
- B. Partial pay estimates must be submitted to the Engineer no later than the 25th of each month. Pay estimates may only include work that has been completed at that time.

2.10 Final Payment

Final payment for Work governed by unit prices will be made on the basis of the actual measurements and quantities accepted by the ENGINEER multiplied by the unit sum/price for work which is incorporated in or made necessary by the Work.

PART 3 – DEFECT ASSESSMENT

- 3.1** Replace the Work, or portions of the work, not conforming to specified requirements.
- 3.2** If, in the opinion of the Engineer, it is not practical to remove and replace the Work, the Engineer will direct one of the following remedies:
 - A.** The defective Work may remain, but the unit price will be adjusted to a new price at the discretion of the Engineer.

- B.** The defective Work will be partially repaired to the instructions of the Engineer, and the unit price will be adjusted to a new price at the discretion of the Engineer.
- 3.3** The individual specification sections may modify these options or may identify a specific formula or percentage sum/price reduction.
- 3.4** The authority of the Engineer to assess the defect and identify payment adjustment is final.

PART 4 – NON-PAYMENT FOR REJECTED PRODUCTS

- 4.1** Payment will not be made for any of the following:
 - A.** Products wasted or disposed of in a manner that is not acceptable.
 - B.** Products determined as unacceptable before or after placement.
 - C.** Products not completely unloaded from the transportation vehicle.
 - D.** Products placed beyond the lines and levels of the required Work.
 - E.** Products remaining on hand after completion of the Work.
 - F.** Loading, hauling and disposing of rejected products.

****END OF SECTION 01210****

SECTION 11211

PACKAGED BOOSTER PUMP SYSTEM

PART 1 GENERAL

1.01 DESCRIPTION

- A. Scope:
 - 1. Provide all labor, materials, equipment, and incidentals required to furnish and install a packaged booster pump system complete and operational with variable frequency drives (VFDs), motors, control equipment, and accessories as shown on the Drawings and as specified. Anchor bolts are included in this Section.

- B. Related sections:
 - 1. The Contract Documents are complementary; what is called for by one is as binding as if called for by all.
 - 2. It is the Contractor's responsibility for scheduling and coordinating the Work of subcontractors, suppliers, and other individuals or entities performing or furnishing any of Contractor's Work.
 - 3. The City's Standard Specifications take precedence where applicable.

1.02 QUALITY ASSURANCE

- A. Manufacturer's qualifications:
 - 1. Manufacturer shall have a minimum of five years experience of producing substantially similar equipment, and shall be able to show evidence of at least five installations in satisfactory operation for at least five years.

- B. Reference standards: Comply with applicable provisions and recommendations of the following, except as otherwise shown or specified.
 - 1. Standards of the Hydraulic Institute (HI).
 - 2. National Electrical Code (NEC).
 - 3. Standards of National Electrical Manufacturers Association (NEMA).
 - 4. Institute of Electrical and Electronic Engineers (IEEE).
 - 5. American National Standards Institute (ANSI).
 - 6. Standards of American Water Works Association (AWWA).
 - 7. National Sanitation Foundation (NSF).
 - 8. Underwriters Laboratories (UL).
 - 9. ASTM International (ASTM).

- C. Unit responsibility: A Certificate of Unit Responsibility shall be provided.

1.03 SUBMITTALS

- A. Shop drawings: Submit for approval the following:
 - 1. Manufacturer's literature, illustrations, paint certification, specifications, and engineering data including: Dimensions, materials, size, weight, performance data and curves showing overall pump efficiencies, required

- net positive suction head, allowable suction lift, flow rate, head, brake horsepower, motor horsepower, speed and shut-off head.
 - 2. Shop drawings showing: Fabrication, assembly, installation and wiring diagrams.
 - 3. Provide setting drawings, templates, and directions for the installation of anchor bolts and other anchorage devices.
- B. Provide a control panel hardware submittal for each control panel and enclosure being provided on this project, including but not limited to:
- 1. Product data:
 - a. Enclosure construction details and NEMA type.
 - b. Manufacturer's literature and specification data sheets for each type of equipment to be installed within or on the panel or enclosure.
 - 2. Shop drawings:
 - a. Scaled, detailed exterior panel (front and side views) and interior panel layout showing equipment arrangement and dimensional information:
 - 1) Provide draft for review and approval by Engineer. The Engineer has the authority to substantially alter initial panel layouts.
 - b. Complete nameplate engraving schedule.
 - c. Structural details of fabricated panels.
 - 3. Calculations:
 - a. Provide installation details based on calculated shear and tension forces:
 - 1) Calculations shall be signed and sealed by a Professional Engineer licensed in the state where the cabinets and panels will be installed.
 - b. For assembled enclosures and other equipment with a weight of 200 pounds or more, provide calculations for:
 - 1) Weight including panel internal components.
 - 2) Seismic forces and overturning moments.
 - 3) Shear and tension forces in connections.
 - c. Cooling calculations, including but not limited to:
 - 1) Highest expected ambient temperature for the enclosure's location.
 - 2) Internal heat load.
 - 3) Exposure to direct sunlight.
 - 4) Dimensions of the enclosure in inches.
 - 5) Maximum allowable temperature inside the enclosure, based on the lowest operating temperature limit of the installed components.
 - d. Seismic design:
 - 1) Seismic panel construction:
 - a) Seismic anchorage: Provide seismic design calculations and installation details for anchorage of all panels, enclosures, consoles, etc. to meet seismic requirements of the project site.
 - b) Stamped by a Professional Engineer registered in the state where the project is being constructed.

- C. Operation and maintenance manuals:
1. Submit complete installation, operation and maintenance manuals, including test reports, pump curves, maintenance data and schedules, description of operation and spare parts information.
 2. Furnish operation and maintenance manuals.

1.04 PRODUCT DELIVERY, STORAGE AND HANDLING

- A. Deliver materials to the site to ensure uninterrupted progress of the Work. Deliver anchor bolts and anchorage devices, which are to be embedded in cast-in-place concrete, in ample time to not delay that Work.
- B. All boxes, crates and packages shall be inspected by Contractor upon delivery to the site. Notify Engineer If any loss or damage exists to equipment or components. Replace loss and repair damage to new condition, in accordance with manufacturer's instructions.
- C. Store materials to permit easy access for inspection and identification. Keep all material off the ground, using pallets, platforms, or other supports. Protect steel members and packaged materials from corrosion and deterioration.

Design Conditions	Pump Nos. 1 & 2
Location:	Reuse Booster Pump Station-Island WWTP
Use:	Booster
Service:	Non-Potable, Reuse Water
Manufacturer/Model or equal	Simflo SC12C-4
Number Pumps Required:	2
Type of Pump	Canned Vertical Turbine
*Rated Design Flow: gpm	600
*Design TDH: ft.	200
**Horsepower	40
Min. Efficiency at Design: %	80
Column Assembly	Flanged/416 SS Shaft/304 SS Coupling/316 SS Bolting/ Coated with Devoe Barrrust 233H
Max. Operating Speed: rpm	1,800
Number of Stages	4
Pump Can Diameter (inches)***	16
Discharge Size: in.	8.0
Max NPSH Required at Design: ft.	15
Temperature: °F	50-90
Liquid pH:	7.0-9.0
Suction Strainer	Required, 316 SS

Design Conditions	Pump Nos. 1 & 2
Drive Type:	VFD
Motor: Volts/Phase/Hertz	460/3/60
<p>* Per Pump - At maximum speed. Does not include entrance, pump, column, and discharge head losses.</p> <p>** Pump horsepower requirements shall not exceed stated horsepower at any point on operating curve.</p> <p>*** Pump Can shall be supplied by Pump Manufacturer. Coating shall be DeVoe Barrust 233H.</p>	

PART 2 PRODUCTS

2.01 SERVICE CONDITIONS

- A. Furnish and install a pre-fabricated, and tested variable speed packaged pumping system to maintain constant water delivery pressure. Delivery pressure shall be variable, 150-200 THD, at a flow 50-600 gpm.
- B. The packaged pump system shall be a standard product of a single pump manufacturer and UL listed. The entire pump system, including pumps, vendor control panel (VCP) and pump controller, shall be designed and assembled by the same manufacturer.
- C. Pumps shall be multi-stage vertical turbine pump design, suitable for the capacity and head conditions identified. They shall be specially designed, constructed, and installed for the service intended and shall comply with the following minimum conditions.

2.02 DETAILS OF CONSTRUCTION

- A. Pump Materials and Construction:
 - 1. Minimum Discharge Connection Size: 8 inch, ANSI Class 150 flanges.
 - 2. Discharge head: Ductile iron or fabricated steel.
 - 3. Impellers: Aluminum Bronze.
 - 4. Pump Drive: VFD.
 - 5. Shaft Seal:
 - a. Packing.
 - 6. Provide stainless steel nameplates indicating the manufacturer's model, serial number, rated capacity, head, speed, and other pertinent data.
 - 7. Check valves: 8-inch non slam.
 - 8. Valves: 8-inch butterfly with gear operators.
 - 9. Flexible Couplings: 8-inch dresser style or equal with restraining rods.
 - 10. Piping- Steel, Coated interior and exterior.
 - 11. Gauges: 4.5 inch with isolation valves.
- B. Motors:
 - 1. Voltage:
 - a. All motors shall be rated 460 V, 3 phase.
 - 2. Motors driving identical machines shall be identical.
 - 3. All motors shall meet the "NEMA Premium Efficiency" percent listed in NEMA MG-1.

4. Horsepower as indicated herein.
5. Service factor:
 - a. 1.0 when driven by VFD.
6. Torque:
 - a. Provide motors that develop sufficient torque for acceleration to full speed at voltage 10 percent less than motor nameplate rating.
 - b. When started using reduced voltage starters:
 - 1) Provide motors that develop sufficient torque for acceleration to full speed.
 - c. NEMA Design B except where driven load characteristics require other than normal starting torque:
 - 1) In no case shall starting torque or breakdown torque be less than the values specified in NEMA MG-1.
7. Enclosure:
 - a. Totally enclosed fan cooled:
 - 1) Cast iron conduit box.
 - b. Tapped drain holes with Type 316 stainless steel plugs for frames 286 and smaller, and automatic breather and drain devices for frames 324 and larger.
 - c. Lifting devices: All motors weighing 265 pounds (120 kilograms) or more shall have suitable lifting devices for installation and removal.
8. Manufactured with cast iron frames in accordance with NEMA MG-1 or manufacturer's standard material for the specified rating.
9. Nameplates:
 - a. Provide all motors with a permanent, stainless steel nameplate indelibly stamped or engraved with:
 - 1) NEMA standard motor data.
 - a) Indicate compliance with NEMA MG-1 Part 31 for inverter duty motors.
 - 2) AFBMA bearing numbers and lubrication instructions.
10. Hardware:
 - a. Type 316 stainless steel.
11. Conduit boxes:
 - a. Cast iron or stamped steel.
 - b. Split from top to bottom.
 - c. Provide gaskets at the following interfaces:
 - 1) Frames and conduit boxes.
 - 2) Conduit boxes and box covers.
 - d. Rotatable through 360 degrees in 90-degree increments.
 - 1) Where available based on the size of the conduit box.
 - e. Exceeding the dimensions defined in NEMA MG-1.
 - f. Provide grounding lugs inside conduit boxes for motor frame grounding.
12. Motor bearings:
 - a. Antifriction.
 - b. Vertical motors per manufacturer's standard design.
 - c. Bearings and lubrication suitable for ambient temperature and temperature rise.
 - d. Suitable for intended application and have ABMA L-10 rating life of 60,000 hours or more.
 - e. Fit bearings with easily accessible grease supply, flush, drain, and relief fittings using extension tubes where necessary.

- f. Where specified in the equipment Specifications, provide split-sleeve type hydrodynamic radial bearings. Provide a bearing isolator to protect bearings from contaminants.
13. Insulation systems:
 - 1) Provide Class F insulation.
 - 2) Design temperature rise consistent with Class B insulation.
 - 3) Rated to operate at an ambient temperature of 50 degrees Celsius at the altitude where the motor will be installed.
 14. Motor leads:
 - a. Insulated leads with non-wicking, non-hydroscopic material. Class F insulation.
 15. Noise:
 - a. Maximum operating noise level in accordance with NEMA MG-1.
 16. Motors driven by variable frequency drives:
 - a. Compatible with the variable frequency drives specified.
 - b. Inverter duty rated and labeled.
 - c. Meet the requirements of NEMA MG-1 Part 31.
 - d. Winding insulation meets the requirements of NEMA MG-1 Part 31.4.4.2.
 - e. Capable of running continuously at 1/10th of full speed, with no harmful effects or overheating.
 - f. Shaft grounding ring:
 - 1) Provide a shaft grounding ring for each VFD driven motor.
 - 2) Aluminum frame and internal components.
 - 3) Conductive microfiber brushes.
 - 4) Maintenance free design.
 - 5) Aegis Bearing Protection ring as manufactured by Electro Static Technology or equal.
 17. Provide temperature switches with normally closed contacts.
- C. Variable Frequency Drives:
1. Manufacturers:
 - a. One of the following, no equals:
 - a) Eaton/Cutler-Hammer.
 - b) Allen-Bradley.
 - c) Siemens-Robicon.
 - d) Schneider Electric/Square D.
 - e) General Electric.
 - f) ABB.
 2. General:
 - a. Sinusoidal pulse width modulated (PWM) type drive.
 - 1) Six-pulse insulated gate bipolar transistor (IGBT) power section.
 - 2) Microprocessor based controls.
 - 3) Line reactors.
 - b. 480 Volt, 3-phase input voltage
 3. Operational features:
 - a. Protective features:
 - 1) Provide the following minimum protective features:
 - a) Motor overload protection.
 - b) Instantaneous overcurrent.
 - c) Instantaneous overvoltage.
 - d) Undervoltage.
 - e) Power unit overtemperature.

- f) Phase loss.
 - g) VFD output short circuit.
 - b. Control mode:
 - 1) Operation in either a constant volts/hertz or sensorless vector mode:
 - a) The control mode selectable using the programming keypad.
 - c. Frequency control:
 - 1) Minimum of 3 selectable skip frequencies with adjustable bandwidths.
 - 2) Programmable minimum frequency.
 - 3) Programmable maximum frequency.
 - d. Acceleration/deceleration:
 - 1) Separately adjustable acceleration and deceleration rates:
 - a) Each rate adjustable from 0.01 to 1,800 seconds.
 - e. Spinning load:
 - 1) The VFD shall be capable of determining the speed and direction of a spinning load, "catch" the load and accelerate or decelerate it without damage to the load.
 - f. Programmable loss of signal:
 - 1) Upon loss of speed reference the VFD shall be programmable to either:
 - a) Stop.
 - b) Maintain current speed.
 - c) Default to pre-selected speed.
 - g. Power interrupt ride-through:
 - 1) The VFD shall be capable of continuous operation in the event of a power loss of 5 cycles or less.
 - h. Inputs/Outputs:
 - 1) Manufacturer's standard number the following:
 - a) Analog inputs:
 - (1) Configurable as either 0 to 10 volts or 4 to 20 milliamperes.
 - b) Analog outputs:
 - (1) Programmable 4 to 20 milliamperes isolated.
 - c) Discrete inputs:
 - (1) Programmable.
 - d) Discrete outputs:
 - (1) Programmable.
 - (2) Form C relay contacts.
 - e) Potentiometer 3-wire input.
 - 2) Provide additional inputs/outputs as required to meet the control functions described herein.
- 4. 5 percent line reactor.
 - a. At the input to the VCP, the harmonics shall not exceed those allowable by IEEE 519.
- 5. Keypad:
 - a. Provide each VFD with a keypad for programming and control.
 - b. Keypad requirements:
 - 1) Password security to protect drive parameters.
 - 2) Mounted on the door of the VCP.

- 3) Back-lit LCD:
 - a) Minimum of 2 lines with a minimum of 16 characters per line.
- 4) Programming and display features language: English.
- 5) Capable of displaying the following parameters:
 - a) Speed (percent).
 - b) Output current (amperes).
 - c) Output frequency (hertz).
 - d) Input voltage.
 - e) Output voltage.
 - f) Total 3-phase kilowatt.
 - g) Kilowatt-hour meter.
 - h) Elapsed run time meter.
 - i) Revolutions per minute.
 - j) Direct current bus voltage.
6. Metal oxide varistors:
 - a. Provide protection for the VFD against:
 - 1) Line transients: 5,000 volt peak minimum.
 - b. Line to ground transients: 7,000 peak minimum.

D. System Accessories:

1. The can and discharge manifolds shall be constructed of coated steel. Manifold connection shall be size indicated on the Drawings and as specified in the schedule above with ANSI Class 150 flanges. The manifolds shall be equipped with a pressure transducer.
2. Pump isolation valves shall be provided on the suction and discharge of each pump. Isolation valves shall be a full lug style butterfly valve. The valve seat material shall be EPDM and the body shall be cast iron, coated internally and externally with fusion-bonded epoxy.
3. A spring-loaded non-slam type check valve shall be installed on the discharge of each pump. The valve shall be a wafer style type fitted between two flanges. The head loss through the valve shall not exceed 5 psi at the pump design capacity.
4. Each pump discharge header will be equipped with a high pressure switch, installed upstream of the check valve, with a variable setting from 75-150 psig, and normality set at 110 psig. Upon activation, via a variable time delay relay (0-5 minutes), the high pressure switch will cause the pumps to de-energize.
5. A pressure transducer shall be factory installed on the discharge manifold. Pressure transducers shall be made of Type 316 stainless steel. Transducer accuracy shall be +/- 1.0 percent full scale with hysteresis and repeatability of no greater than 0.1 percent full scale. The output signal shall be 4-20 mA with a supply voltage range of 9-32 VDC. Provide with sunshield. Refer to Drawings for sunshield detail.
6. A bourdon type pressure gauge, 4.5-inch diameter, shall be placed on each pump discharge manifolds. The gauge shall be liquid filled and have copper alloy internal parts in a stainless steel case. Gauge accuracy shall be 2-1/2 percent. The gauge range shall be 0-160 psig.
7. Magnetic flow meter:
 - a. Manufacturers: One of the following or equal:
 - 1) Endress+Hauser: Promag 53.
 - 2) Rosemount: 8700E.
 - 3) Krohne: IFC.

- 4) Yokogawa: AXF.
- b. General:
 - 1) Magnetic flowmeters obtain the flow velocity by measuring the changes of induced voltage of the conductive fluid passing across a controlled magnetic field.
 - 2) Complete zero stability shall be an inherent characteristic of the flowmeter system.
 - 3) Include for each magnetic flow metering system:
 - a) A metering tube with electrodes (sensor).
 - b) Signal cable.
 - c) Transmitter integral or remote as indicated on the Drawings.
 - d) Flowmeter grounding rings.
- c. Performance requirements:
 - 1) Accuracy:
 - a) 0.25 percent of flow rate from 10 to 100 percent of full scale for velocities ranging between 1.9 to 10 feet per second.
 - 2) Repeatability:
 - a) 0.25 percent of rate.
- d. Element:
 - 1) Metering tube:
 - a) Constructed of carbon steel or Type 304 stainless steel with flanged connections to match with piping material.
 - (1) Refer to drawings for size.
 - b) Liner material in conformance with:
 - (1) Manufacturer's recommendations for the intended service.
 - (2) NSF certified for all drinking water applications.
 - c) Electrodes type and material in conformance with:
 - (1) Manufacturer's recommendations for the intended service.
 - (2) Utilize a minimum of 2, self-cleaning electrodes.
 - d) Meter terminal housing NEMA Type 4X unless specifically noted otherwise in the instrument data sheets.
 - e) Meter coating consisting of epoxy painted finish.
 - f) Components:
 - (1) 2 grounding rings:
 - (a) Which are in conformance with the manufacturer's bore and material recommendation for the meter's intended service.
 - (b) Designed to protect and shield from abrasion of the liner's edge interface at the meter's end.
- e. Transmitter:
 - 1) Power supply:
 - a) 120 VAC.
 - b) Power consumption: 60 VA maximum.
 - 2) Outputs:
 - a) As noted in the instrument data sheets.
 - b) For all instruments with 4 to 20 mA HART or digital bus protocol, provide a Device Type Manager (DTM) certification by FDT group.
 - 3) Microprocessor-based signal converter/transmitter.
 - 4) Utilize DC pulse technique to drive flux-producing coils.

- 5) Contain a 6-digit display for flow rate, percent of span, and totalizer.
- 6) Operator keypad interface.
- 7) Integral zero return to provide consistent zero output signals in response to an external dry contact closure.
- 8) Integral low flow cut-off zero return.
- 9) Programmable parameters including:
 - a) Meter size.
 - b) Full-scale flow rate.
 - c) Magnetic field frequency.
 - d) Time constant.
- 10) Data retention for a minimum of 5 years without auxiliary main or battery power.
- 11) Self-diagnostics and automatic data checking.
- 12) Protected terminals and fuses in a separate compartment which isolates field connection from electronics.
- 13) Ambient operating temperature limits of -5 to 140 degrees Fahrenheit (-20 to 60 degrees Celsius).
- 14) Provide with sunshield. Refer to Drawings for sunshield detail.

E. Product and Manufacturer: Provide one of the following:

1. Tigerflow or equal.

2.03 VENDOR CONTROL PANEL (VCP)

- A. The vendor control panel (VCP) shall include all the components necessary for operation of the packaged booster pump system. Including, but not limited to:
1. Manufacturer standard PLC.
 2. 7-inch HMI. Manufacturer standard HMI. Variable Frequency Drives:
 - a. Variable frequency drives shall conform to the requirements noted herein.
 - b. Each pump motor shall have a dedicated variable frequency drive built and tested by one manufacturer.
- B. The VCP shall be powered from a 480-volt, 80 amp, 3-phase 60 hertz power supply.
1. Rated to withstand a fault current of 65 kA.
 2. Provide control panel transformers for all other voltages required within the VCP for operation.
- C. Circuit Breakers:
1. Manufactured in accordance with UL 489.
 2. Provide a flange-mounted disconnect to disconnect main incoming power.
 3. Provide a feeder circuit breaker for each pump's VFD.
 4. Provide a 15A-3P feeder circuit breaker for the 12-inch valve actuator.
 5. Provide a 15A-3P feeder circuit breaker for the 18-inch valve actuator.
- D. It shall be factory wired and tested and UL listed. Components shall be labeled and include the following:
1. Enclosure: NEMA 4, steel with gasketed door, rain-tight
 - a. The control panel and all appurtenances shall be suitable for outdoor installation.

- b. All control devices shall be rigidly mounted within the enclosure except for breaker handles and HMI, which shall be mounted on the panel door.
 2. Control relays:
 - a. General:
 - 1) Provide all controls relays required to provide all necessary control functions.
 - 2) For all types of 120-VAC relays, provide surge protection across the coil of each relay.
 - 3) For all types of 24-VDC relays, provide a free-wheeling diode across the coil of each relay.
 - b. General purpose:
 - 1) Magnetic control relays.
 - 2) NEMA Type A300 rated:
 - a) 300 volts.
 - b) 8 Amps continuous (minimum).
 - c) 7,200 volt-amperes make.
 - d) 720 volt-amperes break.
 - 3) Plug-in type.
 - 4) LED indication for energization status.
 - 5) Coil voltages: As required for the application.
 - 6) Minimum poles: DPDT.
 - 7) Touch-safe design: All connection terminals to be protected against accidental touch.
 - 8) Enclose each relay in a clear plastic heat and shock-resistant dust cover.
 - 9) Quantity and type of contact shall be as indicated on the Drawings or as needed for system compatibility.
 - 10) Relays with screw-type socket terminals.
 - 11) Provide additional (slave/interposing) relays when the following occurs:
 - a) The number or type of contacts shown exceeds the contact capacity of the specified relays.
 - b) Higher contact rating is required in order to interface with starter circuits or other equipment.
 - 12) DIN rail mounting on 35-millimeter rail.
 - 13) Ice-cube-type relays with retainer clips to secure relay in socket.
 - 14) Integrated label holder for device labeling.
 - 15) Manufacturer: One of the following or equal:
 - a) Phoenix Contact PLC Series.
 - b) Potter and Brumfield Type KRP or KUP.
 - c) IDEC R* Series (* = H, J, R, S, U).
 - d) Allen-Bradley Type 700 HC.
 - e) Square D Type K.
3. Thermal management:
 - a. Provide heating, cooling, and dehumidifying devices in order to maintain all instrumentation and control devices to within their manufacturer specified ranges.
 - b. Air conditioner:
 - 1) Provide solid-state cabinet coolers or air conditioning units on all outdoor panels containing electronic components such as local operator interface (LOI) units, panel instruments, programmable logic controllers, or remote I/O.

- 2) Provide filters on intake and exhaust openings.
- 3) Increase panel sizes as needed to accommodate cooling units.
- 4) Manufacturer: The following or equal:
 - a) Kooltronic Integrity Series 21.
- 4. Provide with Ethernet/IP communication for all signals required between the VCP and the plant control system. At a minimum, the following signals shall be communicated:
 - a. The controller shall be capable of receiving a remote analog setpoint signal (4-20 mA) as well as a remote on/off (digital) signal.
 - b. The controller shall provide an analog signal (4-20 mA) to the Plant PLC for the following:
 - 1) Discharge pressure.
 - c. The controller shall provide dry relay contact outputs for the following:
 - 1) System Running.
 - 2) System Failure.
 - 3) Pump Failure (for each pump).
 - 4) Pump Running (for each pump).
 - 5) Discharge Pressure High.
 - 6) Discharge Pressure Low.
 - 7) System in Remote.
- E. The pump system controller shall be a standard product developed and supported by the pump manufacturer.
- F. The controller shall be microprocessor based with EPROM programming for individual system types. The controller shall have (as a minimum) a 2 line by 24 character LCD display for field programming. Password protection of system settings shall be standard.
- G. Pump system programming (field adjustable) shall include as a minimum the following:

System Pressure Setpoint	Low System Pressure Shut-Down
High System Pressure Shut-Down	Individual Pump low flow
Pressure Transducer Supply/Range	Sequence Time (Start Delay)
System Time (Reaction)	Pump Priority (Start Sequence)
Backup Pump Designation	

- H. The system pressure setpoint shall be capable of being automatically adjusted by a built-in clock program. The clock program shall be capable of 10 different setpoints per 24-hour period.
- I. The system pressure setpoint shall also be capable of being automatically adjusted by a system pressure compensating function. As flow increases the discharge pressure shall increase linearly as flow approaches design capacity. System compensation percentage shall be field adjustable.

- J. The controller shall display the following as status readings in addition to all system programming parameters:

System Pressure Setpoint	Actual System Pressure
Individual Pump Status (On/Off/Fault)	Pump System Capacity (%)
Individual Pump Running Total Running Hours	Individual Pump Speed (%)

- K. The pump system controller shall store the 10 most recent alarms in memory. The time, date and duration of each alarm shall be recorded. A communications module shall be provided for pump system performance monitoring and alarm notification to a remote central monitoring system via analog and digital I/O communication to an OWNER supplied RTU. The controller shall display the following alarm conditions:

High System Pressure	Low System Discharge Pressure
Individual Pump Failure	Loss of Sensor Signal (4-20 mA)
VFD Trip/Failure	Individual Pump Run
System Pressure Setpoint	Loss of Remote Setpoint Signal (4-20 mA)

- L. The system controller shall operate equal capacity variable speed pumps to maintain a constant discharge pressure (system setpoint). The system controller shall receive an analog signal (4-20 mA) from the pressure transducer on the discharge manifold, indicating the actual system pressure. As flow demand increases the pump speed shall be increased to maintain the system setpoint pressure. When the operating pump(s) cannot maintain the system setpoint as flow increases (pressure starts to drop), an additional pump will be started and will increase speed until the system setpoint is achieved. All pumps in operation will be running at the same speed to maintain the system setpoint. As flow demand decreases the pump speed shall be reduced while system setpoint pressure is maintained. When all pumps in operation are running at low speed the system controller shall switch off pumps when fewer pumps are able to maintain system demand.
- M. The system controller shall be capable of switching pumps on and off to satisfy system demand without the use of flow switches or motor current monitors.
- N. When a no flow shut-down is experienced (periods of zero demand). When zero flow is detected by the system controller, the remaining pump(s) shall be switched off. When the system pressure falls to 5 percent below the system setpoint (flow begins after shut-down), a pump shall be switched on, increasing speed to maintain the system setpoint pressure.
- O. All pumps in the system shall alternate automatically based on demand, time and fault. If flow demand is continuous (no flow shut-down does not occur), the system controller shall have the capability to alternate the pumps every 24 hours or once per week. The time of the pump change-over shall be field adjustable.

2.04 SURFACE PREPARATION AND PAINTING

- A. Pumps, motors, drives, frames, baseplates, appurtenances, etc., shall receive shop primer and shop finish coating conforming to the requirements of the City's Standard Specifications. If any damage to the paint system occurs, the equipment shall be repainted as directed by the ENGINEER.
- B. Surface preparation and painting shall conform to the requirements of City's Standard Specifications.
- C. All gears, bearing surfaces, machined surfaces and other surfaces which are to remain unpainted shall receive a heavy application of grease or other rust-resistant coating. This coating shall be maintained during storage and until the equipment is placed into operation.
- D. Certify, in writing, that the shop primer and shop finish coating system conforms to the requirements of City's Standard Specifications.

PART 3 EXECUTION

3.01 FACTORY TESTING

- A. Motors:
 - 1. Perform manufacturer's standard production tests including but not limited to:
 - a. No load current.
 - b. High potential test.
 - c. Winding resistance.
 - 2. Furnish copies of standard test reports on prototype or identical units.

3.02 INSTALLATION

- A. Equipment shall be installed in accordance with manufacturer's instructions and recommendations and the approved Shop Drawings.
- B. Installation shall include furnishing and applying an initial supply of grease and oil, recommended by the manufacturer.
- C. Support piping independent of pump.
- D. Check and align all pump, motor and flexible shafting.

3.03 START-UP AND TEST

- A. Make adjustments required to place system in proper operating condition. Field test and calibrate the equipment to assure that the system operates in accordance with these Specifications and to the satisfaction of the Engineer.
- B. After completion of installation, the system shall be completely tested to ensure compliance with the operating requirements as specified, indicated on the Drawings and in accordance with the City's Standard Specifications.

- C. The Contractor shall submit a startup and commissioning and sequence plan for approval by the Engineer.

3.04 MANUFACTURER'S SERVICES

- A. A factory trained representative shall be provided for installation supervision, start-up and test services and operation and maintenance personnel training services. The representative shall make a minimum of 1 visit, minimum 2 hours on-site for each visit, to the site. The first visit shall be for assistance in the installation of equipment. The second visit shall be for checking the completed installation and start-up of the system. The third visit shall be for commissioning the system. Manufacturer's representative shall test operate the system in the presence of the Engineer and verify that the pumps conform to requirements. Representative shall revisit the job site as often as necessary until all trouble is corrected and the installation is entirely satisfactory.
- B. All costs, including travel, lodging, meals and incidentals, shall be considered as included in Contractor's bid price.

END OF SECTION

THIS PAGE INTENTIONALLY LEFT BLANK

SECTION 13206G

HYDROPNEUMATIC PRESSURE CONTROL SYSTEM INCLUDING TANK

PART 1 GENERAL

1.01 SUMMARY

- A. Section includes: Pressure tank, air compressor, and accessories.

1.02 REFERENCES

- A. American Society of Mechanical Engineers (ASME):
 - 1. B31.1 - Power Piping.
 - 2. Boiler and Pressure Vessel Code (BPVC), Section VIII, Rules for Construction of Pressure Vessels, Division 1.
- B. ASTM International (ASTM):
 - 1. A 269 - Standard Specification for Seamless and Welded Austenitic Stainless Steel Tubing for General Service.
 - 2. A 516 - Specification for Pressure Vessel Plates, Carbon Steel, for Moderate and Lower Temperature Service.
- C. National Electrical Code (NEC).
- D. National Electrical Manufacturers Association (NEMA):
 - 1. 250 - Enclosures for Electrical Equipment (1000 V Maximum).
 - 2. MG-1 - Motors and Generators.
- E. NSF International (NSF):
 - 1. 61 - Drinking Water System Components - Health Effects.
- F. Uniform Building Code (UBC).
- G. Underwriters Laboratories, Inc. (UL).

1.03 DEFINITIONS

- A. NEMA:
 - 1. Type 1 enclosure in accordance with NEMA 250.
 - 2. Type 4 enclosure in accordance with NEMA 250.

1.04 SYSTEM DESCRIPTION

- A. Performance requirements:
 - 1. The hydropneumatic pressure control system shall include a pressure tank, air compressor, automatic water level control system, and all piping and accessories needed to assemble a complete working system at the job site.
 - 2. The hydropneumatic system shall be designed to maintain a discharged water pressure of 106 to 150 pounds per square inch gauge (psig).

- B. Design requirements:
1. Tank size:
 - a. Nominal tank diameter: 120 inches.
 - b. Tank length: Approximately 204 inches.
 - c. Minimum tank capacity: 10,000 gallons.
 2. Pressure rating: The new tank shall be fabricated in accordance with the ASME Code for unfired pressure vessels, for a design pressure rating of 200 psig.
 3. Corrosion allowance: 1/16-inch corrosion allowance applied to shell, heads, and attachment thicknesses.
 4. Seismic design: Design tank and support system for seismic design criteria per local design parameters.
 5. Wind design: Design tank to meet the wind design criteria per local design parameters.
 6. The equipment to be provided under this Section shall be suitable for installation and operation under the following conditions:
 - a. Project site elevation: Between 450 and 550 feet above sea level.
 - b. Outdoor temperature and humidity:
 - 1) Outside ambient air temperatures range between 45 and 110 degrees Fahrenheit, with relative humidity ranging between 10 and 100 percent (noncondensing).
 7. The tank shall contain 20 percent air under steady state conditions.
 8. The system and anchorage of the tank shall conform to the UBC.
- C. Existing pump station is the Mulberry Effluent Pump Station.

1.05 SUBMITTALS

- A. Pressure tank:
1. Product data: List of materials and coatings used.
 2. Shop drawings and calculations:
 - a. Detail drawings or manufacturer's literature to indicate compliance with the specified requirements.
 - b. Dimensional drawings indicating vessel dimensions, wall thickness, mounting, and anchorage requirements.
 - c. ASME code calculations.
 3. Owner's Manual: Provide with delivery of the system.
 - a. Certification and ASME Code data reports in accordance with the ASME Code and other similar codes.
 - 1) The certification shall include certification of post weld heat treatment, joint radiography, and hydrostatic testing.
 - b. Fabrication drawings.
 - c. Copy of structural, seismic, and wind loading calculations for the support system signed by a Structural Engineer registered in Arizona.
 - d. Complete electrical diagrams.
 - e. Shop testing: Tank ASME Form U-1A.
- B. Air compressor and receiver:
1. General:
 - a. Furnish submittals as specified by the City's Standard Specifications.
 - b. All of the material required for submittal under this Section shall be furnished in one complete package.
 2. Product data and shop drawings.

13206G-2

Water Conservation Program Implementation, Package No. 2

August 2016
Project SS2970

3. Certifications: A manufacturer's certificate of satisfactory installation is required for work under this Section.

1.06 QUALITY ASSURANCE

- A. Regulatory requirements:
 1. All plumbing codes shall be met.
 2. The system and anchorage of the tank shall be in accordance with UBC.
 3. Vendor control panel (VCP) shall be built in accordance with UL 508.
- B. Unit responsibility:
 1. The entire pressure control system, including the air compressor and all controls, shall be designed and supplied by a single manufacturer.
 - a. However, this shall not relieve the General Contractor's responsibility for coordinating, installing, and performing their complete portion of the work.
- C. The supplier must have a minimum of 5 years experience.
- D. An operation and maintenance manual must be provided and personnel representing the hydropneumatic pressure system manufacturer are required to check the installation and instruct the Owner's personnel in the operation of the surge control system.
 1. A field test of the equipment will be performed in conjunction with this site visit.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Package sight glass assembly, safety relief valves, pressure gauge and similar breakable components separately from tank for shipment.
 1. Suitably store these components at the project site and install after hydropneumatic tank has been anchored on the concrete foundation.
- B. Suitably seal tank openings to prevent entry of dust, dirt, and other contaminants until connections are made in the field.

1.08 WARRANTY

- A. The tank, compressor, and instrumentation shall carry a warranty of 1 year from initial operation or 18 months from delivery whichever comes first.

1.09 MAINTENANCE

- A. Spare parts:
 1. Supply to the Owner recommended spare parts, any specialized tools required in the manufacturer's maintenance procedures, and 3 air filters for the air compressor.

PART 2 PRODUCTS

2.01 PRESSURE TANK

- A. Manufacturers:
 - 1. Pressure tank: One of the following or equal:
 - a. Pulsco.
 - b. Pressure Vessel Technologies/Wagner Plat Works West.
 - c. Crump Engineering.

- B. Materials:
 - 1. Construct tank using ASTM A 516 steel.

- C. Components:
 - 1. Lifting lugs: Provide lifting lugs.
 - 2. Anchor bolts:
 - a. Anchor bolts shall have a nominal diameter of at least 1 inch and shall be anchored to concrete foundations using methods designed to transfer the full ultimate strength of the anchor bolt to the concrete foundation.
 - b. Attach anchor bolts to the tank by use of anchor bolt chairs or rings, as required.
 - c. Chairs or rings shall be designed to transfer 125 percent of the ultimate strength of the bolt, or 150 percent of the calculated load; whichever is less, to the tank shell.
 - 3. Nameplate and code stamp:
 - a. Design, fabricate, and test tank in accordance with the ASME Code.
 - b. Tank shall bear a stainless steel ASME nameplate.
 - c. Nameplate shall bear the applicable code symbol.
 - d. Manufacturer shall be authorized by ASME to apply the applicable code symbols.
 - 4. Fittings and attachments:
 - a. Fittings shall be as indicated on the Drawings.
 - b. Fittings larger than 1 inch shall be flanged.
 - c. Fittings 1 inch and smaller shall be National Pipe Thread.
 - d. Reinforce openings in accordance with the ASME Code.
 - 5. Attachments: Weld shell attachments for pipe supports, tank gages, instruments, and other items as indicated on the Drawings or as listed in this Specification before application of the tank lining.

- D. Inspection openings:
 - 1. Provide 24-inch diameter inspection opening on the tank.
 - 2. In accordance with ASME requirements.
 - 3. Provide bolted cover with neoprene or EPDM flange gasket.
 - 4. Weld lifting lugs to cover and to tank above centerline of opening to aid in cover removal.
 - 5. Provide a 1-inch ball valve at the bottom of the cover to fully drain inspection opening port prior to removal of cover.

- E. Ground lug:
 - 1. Provide lug sized for 2/0 size electrical cable.
 - 2. Locate at bottom of tank.

F. Appurtenances:

1. In addition to mounting flanges, drain valves, and lifting lugs, provide the following appurtenances.
2. Liquid sight gauge for the tank: As specified in 15120.
3. Solenoid valves for air service:
 - a. 2-way solenoid valves:
 - 1) Manufacturers: One of the following or equal:
 - a) Automatic Switch Company, Series 8210.
 - b) Skinner Electric Valve Division, Series C.
 - 2) Design:
 - a) Valves: Suitable for service under the following conditions:
 - b) Fluid: Air.
 - (1) Temperature of fluid: 150 degrees Fahrenheit.
 - (2) Piping test pressure: 200 pounds per square inch gauge.
 - c) Unless otherwise indicated on the Drawings, provide valves that:
 - (1) Minimum NEMA Type 4 enclosure.
 - (2) 120 VAC operation.
 - (3) Suitable for use as indicated on the Drawings.
 - (4) Minimum Class F coil insulation.
 - d) 2-way valves: Furnish with openings of size equal to or larger than the nominal size designation of the valve.
 - e) Furnish with manual/bypass operators.
 - 3) Materials:
 - a) Body: Brass or bronze.
 - b) Seats: Resilient material.
4. Liquid level measurement:
 - a. Level control system:
 - 1) Capacitance level switch or differential pressure transmitter, as recommended by Manufacturer.
 - b. Capacitance level switch:
 - 1) Manufacturers: One of the following or equal:
 - a) Conductivity level switch:
 - (1) Gems Sensors and Controls/Warrick.
 - (2) Ametek B/W Controls 6013 electrode.
 - 2) General: Capacitance type level switches shall be made up of a control relay, mechanically rigid and rugged non-metallic probe and probe housing.
 - 3) Switch:
 - a) Provide a rigid, non-metallic element.
 - b) The control relay senses the liquid level by capacitance measurement between the electrode probe, the process liquid, and the equipment ground:
 - 4) Power supply:
 - a) 120 VAC.
 - b) Power consumption: 10 VA maximum.
 - 5) Outputs:
 - a) Relay outputs:
 - (1) 1 Form C contact.
 - (2) Rated at 6 amperes at 120 VAC.
 - (3) Programmable.

- b) Electrical connection: One 1/2-inch NPT conduit entry.
 - c) Enclosure: NEMA Type 4X.
 - 6) Provide and integrate with VCP for proper operation of the hydropneumatic tank system.
 - 5. Pressure measurement:
 - a. Differential pressure transmitter:
 - 1) Manufacturers: One of the following no equal:
 - a) Rosemount Series.
 - b) Yokogawa EJA Series.
 - c) ABB 264 Series.
 - d) Endress + Hauser Deltabar S Series.
 - e) SMAR LD300 Series.
 - 2) General:
 - a) Differential pressure transmitter assembly shall include a diaphragm-type pressure transducer and microprocessor-based transmitter for measurement of differential pressure.
 - b) Provide and integrate with VCP for proper operation of the hydropneumatic tank system.
 - 3) Provide a similar pressure transmitter for the tank pressure transmitter required herein.
- G. Fabrication:
 - 1. Welding:
 - a. Weld reinforcement shall be in accordance with ASME Code.
 - b. Excessive reinforcement shall be ground down to within the ASME Code requirements, and as required to install the lining systems.
 - c. All internal corners and edges shall be ground to a 1/8-inch radius, or a greater radius if required by the lining system.
 - 2. Protective coating:
 - a. Interior surfaces of the tank shall be factory-coated with High Solids Epoxy Coating in accordance with NSF 61 at a minimum dry film thickness of 10 to 12 mils.
 - b. Coat exterior with High Solids Epoxy Coating, PPG Amercoat, Amerlock 2, or equal.
- H. Pressure controls:
 - 1. The tank pressure controls shall valve open/close and add/vent air solenoid valves.
 - 2. The components shall consist of a pressure transmitter with 4 to 20 milliamperes output.
 - 3. The pressure connection for the pressure transmitter shall be at the probe well or on the top of the tank.
- I. Vendor control panel (VCP):
 - 1. The NEMA Type 4 VCP shall include all the components necessary for operation of the hydropneumatic system. The system integrator shall configure the system to operate in conjunction with the existing PLC at the pump station.
 - a. The VCP shall operate on 480 volt, 60 Hertz, 40-amp electrical service.
 - 1) Provide control power transformers for all other voltages required for the system to operate.

- 2) Provide a 30-amp, 3-pole breaker to distribute 480 volt, 3-phase power to the compressor.
- b. It shall be factory wired and tested and UL listed.
- c. Components shall be labeled and include the following:
 - 1) Door mounted:
 - a) Power on light (white).
 - b) High and low pressure alarm lights (red).
 - c) High and low level alarm lights (red).
 - 2) Internally mounted:
 - a) Control relays.
 - b) Current switch.
 - c) Main circuit breaker.
 - d) Time delay relays.
 - e) Wire and terminal strips.
 - 3) Provide the following 120 VAC rated dry contacts:
 - a) Low Level (to existing PLC).
 - b) High Level (to existing PLC).
 - c) Low Pressure (to existing PLC).
 - d) High Pressure (to existing PLC).
 - e) Motorized Tank Feed Valve Open Command (to Valve).
 - f) Motorized Tank Feed Valve Close Command (to Valve).
 - g) Existing Pump Station Run Command (to existing PLC).
 - 4) VCP shall accept the following 120VAC rated dry contacts:
 - a) Motorized Tank Feed Valve Opened Status (from valve).
 - b) Motorized Tank Feed Valve Closed Status (from valve).
 - c) East Pond Valve Status (from existing PLC).
 - d) West Pond Valve Status (from existing PLC).
 - e) Existing Pump Station Running Status (from existing PLC).
2. The VCP shall start and stop the compressor indirectly via the add air solenoid valve and open/close the motorized tank valve via dry contact closure.
3. The control system shall include adjustable water level set point relays and adjustable pressure set point relays.
 - a. The levels shall be adjusted to 3 different set points within the tank.
 - b. Pressure set point relays shall be set to 5 pressures over the entire range of control.
 - c. Adjustments shall be made within plus or minus 0.5 percent of full range.
4. The 5 pressure set points are specified as being open when the pressure is less than the pressure setting and closed when the pressure is equal to or greater than the pressure setting.
 - a. PS-1: High Pressure alarm: 185 psig.
 - b. PS-2: Energize vent air solenoid valve: 175 psig.
 - c. PS-3: Energize add air solenoid valve: 145 psig.
 - d. PS-4: Open tank feed valve: 110 psig.
 - e. PS-5: Low pressure alarm: 64 psig.
5. The 3 level set points are specified as being open when the level is greater than the level setting and closed when the level is equal to or less than the level setting and corresponding pressures. The settings are as follows:
 - a. LHH: High-High Level (alarm): 90%.
 - b. LH: High Level (valve close): 78%.

c. LLL: Low-Low Level (alarm): 30%.

J. System control description:

1. General:
 - a. The compressor will turn on to maintain minimum 20% air volume in the hydropneumatic tank.
 - b. Upon low level (read by low pressure) in the hydropneumatic tank, a command shall be initiated from the VCP to the existing pump station PLC for the pumps to start to fill the tank.
2. The system shall be designed to maintain a discharged water pressure of 106 to 150 psig.
 - a. The compressor shall maintain pressure in the hydropneumatic tank via the level and pressure control relays.
 - b. Pressure set points energize and de-energize the tank feed valve.
 - c. As the water level falls (drops in pressure), the tank feed valve is energized at a pre-set pressure PS-4.
 - d. If the demand falls, pressure rises and the tank water level rises to the LH set point, the tank feed valve shall be closed.
3. A low-pressure alarm (PS-5) and high-pressure alarm (PS-1) are provided to activate indicating lights and close dry contacts for remote signals at the VCP.
4. Whenever the water level reaches the LH switch, tank feed valve is closed.
 - a. If the pressure is below PS-3, then the add air solenoid valve will open until the pressure is increased to PS-3 reset point.
 - b. If the water level is at LH switch and the pressure is above PS-2 then the vent air solenoid valve will open until the pressure is decreased to PS-2 reset point.

K. Source quality control:

1. Hydrostatic test the hydropneumatic tank in accordance with ASME Code for Unfired Pressure Vessels.
2. Submissions shall include Form U-1A "Manufacturers' Data Report for Unfired Pressure Vessels" prepared by the tank manufacturer to certify that the tank was built in accordance with ASME Code Rules for the Construction of Unfired Pressure Vessels and inspected by a certified inspector.
 - a. Copies of this form shall be included in the Operation and Maintenance Manual.

L. Performance guarantee:

1. The manufacturer shall provide a guarantee of performance and workmanship certifying that the system will meet all provisions of these specifications.
2. Such performance shall be verified by operational field tests.

2.02 AIR COMPRESSOR

A. Manufacturers: One of the following or equal:

1. Ingersoll-Rand.
2. Rix.
3. Corken.
4. Hycomp.

13206G-8

Water Conservation Program Implementation, Package No. 2

August 2016
Project SS2970

- B. Type:
 - 1. Supplier shall size the compressor.
 - 2. The horsepower shall be maximum 15 HP.
 - 3. Supplier is responsible for a complete working system.
 - 4. Submit design calculations, schematics, and sketches that include compressor size/type, horsepower, the displacement, receiver volumes, and motor speeds for the compressor.

- C. Compressor unit, including crankshaft, cylinders, flywheel, and motor shall be air cooled, and completely sealed against dirt.
 - 1. Compressor shall be oil free and suitable for potable water.
 - 2. A finned, multi-tube intercooler shall be provided between stages and shall include a safety valve to prevent over pressurization.
 - a. A dry-type 10-micron filter silencer shall be provided on the air inlet.
 - 3. An air-cooled aftercooler shall lower the discharge air temperature to within 25 degrees Fahrenheit of the ambient air temperature.
 - 4. Compressor shall be driven by an electric motor integral with the compressor.

- D. Motor:
 - 1. Compressor motor: 460 volt, 3 phase, 60 hertz, TEFC, 1.15 service factor, severe duty, energy efficient, with self-lubricated ball bearings.
 - 2. Designed, manufactured, and tested in accordance with NEMA MG-1.

- E. Equipment identification plates:
 - 1. A 16-gauge stainless steel identification plate shall be securely mounted on the compressor and receiver in a readily visible location.
 - 2. The plate shall bear the 1/4-inch die-stamped equipment number indicated in this Section.

- F. Piping:
 - 1. General:
 - a. All interconnecting piping and tubing between components of the equipment package shall be shop installed, except as indicated on the Drawings.
 - b. Piping from the compressor discharges to the tank shall be sized not less than the compressor discharge connection size.
 - 1) Close nipples will not be acceptable.
 - 2. Pneumatic control and instrument tubing:
 - a. Manufacturers: One of the following or equal:
 - 1) Parker-Hannifin.
 - 2) Ferulok.
 - 3) Crawford.
 - 4) Swagelock.
 - b. In accordance with ASTM A 269, Type 316, stainless steel tubing, Type 316 stainless steel flareless double ferrule compression fittings.
 - c. Tubing shall not be less than 1/4 inch OD with a wall thickness of 0.028 inch.
 - 3. All piping and tubing shall be run in vertical and horizontal planes.
 - a. Piping shall be arranged to ensure that undue stresses, from thermal expansion, are not transmitted to equipment components.
 - 4. All control and instrument tubing shall be continuously supported.

- G. Control equipment:
1. All control equipment for the compressor shall be furnished as required for a complete installation, requiring only field connection of the electrical power supply and alarm output signals.
 2. Equipment shall include the following:
 - a. All control switches, pressure switches, timing relays, auxiliary relays, elapsed time meters, circuit breaker combination magnetic motor starters, and other accessories required for control of the compressor.
 - b. Each starter shall include a thermal magnetic circuit breaker with external operating handle.
 - c. Starter overloads shall be matched to motor current and shall be provided with a reset pushbutton.
 3. All control equipment for the compressor package shall be housed in a control panel mounted on the compressor.
 - a. The compressor shall receive power from the hydropneumatic tank VCP.
 4. All system wiring shall be shop installed to terminal blocks in the control panel. Wiring from the panel to system components shall be completely enclosed in liquid-tight flexible conduit.
 5. All pneumatic tubing shall be shop installed to bulkhead fittings at the control panel.
 - a. All field connections shall be made to the fittings at the panel.
 6. Control panel enclosure:
 - a. The control panel shall be NEMA Type 4 construction, fabricated from 14 USS gauge or heavier steel and shall be equipped with a full size gasketed door with chromium-plated or stainless steel 3 point latch and hinges.
 - b. A screened vent shall be provided in the bottom of the control panel.
 - c. All control devices shall be rigidly mounted within the enclosure except for breaker handles, selector switches, pushbuttons, and indicating lights, which shall be mounted on the panel door.
 7. Internal panel tubing shall be run in horizontal and vertical planes and shall be rigidly supported to withstand handling and shipping without damage.
 - a. Compression type bulkhead fittings shall be provided through the panel for all connections.
 8. Panel wiring:
 - a. Internal panel wiring shall be neatly bundled and tied and identified with suitable wire markers.
 - b. Terminal blocks for external connections shall be furnished complete with marking strips, covers, and pressure connectors.
 - c. A terminal shall be provided for each conductor of external circuits.
 - d. All wiring shall be grouped or cabled and securely attached to the panel.
 - e. Clearance for field wiring shall be provided between the terminal strips and base.

9. Compressor control:
 - a. The control panel shall be provided with a power on light, Hand-Off-Automatic (HOA) switch, run light, motor thermal overload alarm light and low oil level alarm light.
 - 1) The panel shall contain combination magnetic motor starter and circuit breaker for the air compressor.
 - b. The air compressor shall start and stop based on pressure in the hydropneumatic tank.
 - 1) Dry contacts shall be provided in the panel for remote indication of running and failed conditions for the compressor.
 - 2) The compressor shall be shutdown by motor thermal overload, or low oil level.
 - 3) An alarm condition shall energize a local alarm light.
 - c. The compressor shall start automatically, provided its HOA hand switch is in the AUTO position.
 - 1) The compressor shall run continuously if its HOA hand switch is in the HAND position and shall shut down if its HOA hand switch is in the OFF position.
 - d. The hydropneumatic pressure control system supplier shall provide minimum 50 scfm @ 150 psig.
 - 1) The capacity and discharge pressure selected shall be sufficient for operation.

H. Accessories:

1. The compressed air equipment package shall be provided with the following accessory equipment:
 - a. Safety valves:
 - 1) Manufacturers: One of the following, or equal:
 - a) Kunkle: Series 6000.
 - b) Conbraco: 19-Series.
 - 2) Safety valves with manual lifting levers shall be installed in the compressor discharge piping.
 - 3) Valves in the compressor discharge piping shall be capable of protecting the compressor from damage when operating against a closed discharge valve and shall be suitable for the maximum compressor discharge air temperature.
 - 4) Relief pressure setting: 200 pounds per square inch.
 - b. Safety guard: Compressor cooling fan shall be provided with safety guards.
 - c. Intake filter muffler:
 - 1) Provide each compressor with a dry type intake filter muffler supported by the suction pipe and close coupled to the compressor intake connection.
 - 2) Intake filter muffler shall have an outer cover and replaceable filter element.
 - d. Discharge check valve:
 - 1) A line-mounted check valve shall be provided in the discharge piping leading from compressor.
 - 2) Check valve shall be sized in accordance with the manufacturer's recommendations and shall be suitable for service with reciprocating compressors at the maximum compressor discharge air temperature.

- e. Shutoff valves:
 - 1) Type: All shutoff valves shall be ball valves.
 - 2) Valves in steel piping shall have carbon steel bodies, chrome-plated or stainless steel balls, and reinforced Teflon seals and seats.
 - 3) Valves in the compressor discharge piping shall be suitable for the maximum compressor discharge air temperature.
- f. Air pressure regulating valve: As required.
- g. Pressure gauge:
 - 1) Pressure gauge shall have a phenol case, adjustable pointer, stainless steel rotary geared movement, and shall be accurate to within 2 percent of full scale.
 - 2) Gauge shall have a minimum dial size of 4-1/2 inches, and a range equal to approximately twice the normal operating pressure at the point of installation.
 - a) The units of measurement shall be indicated on the dial face.
- h. Gauge shall have a 1/4-inch NPT connection.
 - 1) All other gauges shall have 1/2-inch NPT connection.
 - 2) All gauges shall be provided with a shutoff valve.
- i. Pressure switch:
 - 1) Pressure switch shall have spdt contacts rated 10 amperes at 120 volts AC and shall be complete with shutoff valve.
 - 2) Pressure switch shall have NEMA Type 1 housings.
- j. Thermometers:
 - 1) Remote reading or gas actuated dial type.
 - 2) Does not contain mercury.
 - 3) Minimum dial size of 4-1/2 inches, adjustable pointer, and shall be accurate within 1 percent of full scale.
 - 4) Completely furnish with a uniformly graduated dial indicator, armored capillary tube, bulb or temperature sensor, and thermal well.
 - 5) Ranges shall be such that the normal operating reading will be near the midpoint of the range.
 - a) The units of measurement shall be indicated on the dial face.
 - b) Spare capillary length shall be neatly coiled and tied.
- k. Air piping shall be increased in size at the thermal well location so that the area between the well and pipe is not less than the cross-sectional area of the original size piping.
 - 1) The entire sensitive length of the temperature sensor shall be installed within the air flow stream.
- l. Temperature switches:
 - 1) Temperature switches shall be remote bulb type with spdt contacts rated 10 amperes at 120 volts AC.
 - 2) Temperature switches shall have NEMA Type 1 housings, stainless steel thermal well assemblies, and armored capillaries.
 - a) Capillary length shall be sufficient for mounting the switch inside the control panel.
 - b) Spare capillary length shall be neatly coiled and tied.

m. Finishes:

- 1) Shop and field painting of piping and equipment shall be as indicated on the Drawings.

PART 3 EXECUTION

3.01 INSTALLATION

- A. The supplier shall provide all components and assembly instructions to the Contractor for installation.
 1. Install equipment in accordance with the manufacturer's installation instructions and these Specifications.
- B. Air charging:
 1. Fully charge with air in accordance with the manufacturer's instructions prior to field-testing the system.
 2. Final adjustments in pressure shall be made after installation.
- C. Install piping in such a manner as to not place any strain on any part of the equipment.
- D. Coordinate installation with other work.

3.02 PERFORMANCE GUARANTEE

- A. The manufacturer shall provide a guarantee of performance and workmanship certifying that the system will meet all provisions of these specifications.
- B. Such performance shall be verified by operational field tests and by the surge analysis.

3.03 TESTING

- A. Testing shall be performed by the Contractor in the presence of the Engineer and a representative of the supplier.
 1. Testing shall consist of functional test of the level control system and a simulated power failure when pumps are running at maximum operating flow conditions.
- B. System supplier shall provide start up support (1 trip, 2 days) to test and instruct project personnel.
- C. Provide equipment and apparatus required for performing inspections and tests. Correct defects and repeat the respective inspections and tests.
- D. Pressure test gauges shall be currently certified as being accurate to within 1 percent of their full scale.
 1. Use gauges with maximum scale between 1-1/2 and 2 times the test pressure.
- E. Prior to initial operation, the piping system shall be inspected for conformance with the Contract Documents, and ASME B31.1.

F. Operational tests:

1. After installation of the equipment, the compressed air package shall be given an operating test in the presence of the Engineer
2. Operating tests shall demonstrate the equipment's ability to operate without excessive vibration or overheating, and to deliver its rated capacity under the specified conditions.
3. All defects or defective equipment revealed by or noted during the tests shall be corrected or replaced promptly at the expense of the Contractor.
 - a. The Contractor shall furnish all labor, piping, equipment, and materials necessary for conducting the tests.
4. All adjustments necessary to place the equipment in satisfactory working order shall be made at the time of the above tests.

END OF SECTION

SECTION 13447

ELECTRIC ACTUATORS

PART 1 GENERAL

1.01 SUMMARY

- A. Section includes: Electric motor-driven actuators for valves.

1.02 REFERENCES

- A. American Water Works Association (AWWA):
 1. C504 - AWWA Standard for Rubber-Seated Butterfly Valves.
 2. C540 - AWWA Standard for Power-Actuating Devices for Valves and Slide Gates.
- B. National Electrical Manufacturers Association (NEMA):
 1. 250 - Enclosures for Electrical Equipment (1000 V Maximum).

1.03 DEFINITIONS:

- A. NEMA:
 1. Type 4 enclosure in accordance with NEMA 250.

1.04 SUBMITTALS

- A. Provide a complete list/schedule of all actuators being provided with their associated tag names as indicated on the design drawings and/or specifications, service process area and the size of the valve they are actuating.
- B. Clearly identify any exceptions in terms of quantities and/or quality of actuator(s) being submitted.
- C. Product data:
 1. Electrical ratings:
 - a. Voltage and number of phases.
 - b. Starting and running current.
 - c. Voltage levels and source for control and status.
 2. Description of integral control interface.
 3. Environmental ratings, including NEMA enclosure rating and submergence capabilities.
 4. Gear ratios for both manual and motorized actuation.
 5. Opening and closing directions.
 6. Allowable starts per hour.
 7. List of all included options and accessories.
 8. Full travel times.
 9. Gearbox data including gear ratio, and gearbox efficiency.
 10. Affidavit in accordance with AWWA C540.

- D. Shop drawings:
 - 1. Wiring diagrams:
 - a. Include all options and expansion cards furnished with each actuator.
 - 2. Dimensioned drawings of each valve and actuator combination.
 - 3. Dimensioned drawings of each valve gearbox.
 - 4. Electric motor data.
- E. Calculations: Submit the following for each valve/gate size and class:
 - 1. Operating torque calculations.
 - 2. Maximum torque calculations for seating and unseating.
 - 3. Maximum operating torque at starting and normal operation.
- F. Test reports:
 - 1. Factory test report and certificate.
 - 2. Each actuator must be performance tested with a simulated load at the factory and individual test certificates and detailed test reports shall be provided.
 - a. The test equipment used should simulate a typical valve load.
- G. Manufacturer's instructions:
 - 1. Include manufacturer's instructions, description of system operation, start-up data, and troubleshooting checklist.
- H. Operations and maintenance data:
 - 1. Include manufacturer's literature; cleaning procedures, replacement part lists, wiring diagrams, and repair data.
 - 2. Include a list of all configurable parameters, and the final values for each.
 - 3. List of recommended spare parts.
 - 4. List of special tools necessary for proper operation and/or maintenance.
 - 5. Exploded view drawings that illustrate all assemblies, sub-assemblies, and components.
 - 6. Routine test procedures for all electronic and electrical circuits.
 - 7. Troubleshooting chart covering the complete valve and controls/electrical power systems, showing description of trouble, probable cause, and suggested remedy.
 - 8. Certified factory and field-test results.

1.05 QUALITY ASSURANCE

- A. Obtain required information from the valve/gate supplier, including but not limited to:
 - 1. Interface to gate or valve.
 - 2. Operating range (In degrees).
 - 3. Quarter turn or multi-turn.
 - 4. Required turns for full travel on multi-turn applications.
 - 5. Direction of rotation for opening and closing.
 - 6. Maximum and normal torque requirements.
- B. All motorized, intelligent actuators shall be the product of a single manufacturer for all valve and gate applications on this project, regardless of gate or valve type, manufacturer, or supplier.

1.06 SPARE PARTS

- A. Provide the following spare parts (minimum 10 percent of total number of actuators of each model type furnished, but not less than 1 for each model of actuator furnished):
 - 1. Stem nut.
 - 2. Worm shaft subassembly.
 - 3. Drive sleeve subassembly.
 - 4. Complete actuator seal kit.
 - 5. Actuator gearbox oil (sufficient quantity to fill 4 gearboxes).
 - 6. Encoder.
 - 7. Control module.

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Acceptable manufacturers for lines 4 inch and larger:
 - 1. Auma, or equal:
 - a. SA (multi-turn) with Aumatic AC controls.
 - b. SG (quarter-turn) with Aumatic AC controls.

2.02 CHARACTERISTICS FOR ACTUATORS ON LINES 4 INCHES AND LARGER

- A. Provide actuators complete and operable with all components and accessories required for operation.
- B. Power supply:
 - 1. As specified in the Schedule.
 - 2. Valve or gate motion independent of power supply phase rotation.
 - 3. Provide an internal backup power source to maintain settings and track valve position when main power is off.
 - 4. The actuators shall incorporate all major components such as the motor, starter, local controls, terminals etc. housed within a self-contained, sealed enclosure.
- C. Size actuator to move gates or valves from full open to closed position within the time indicated in the Schedule:
 - 1. If an operating time is not indicated on the Schedule, size the actuator to move gates or valves at minimum 12 inches per minute under maximum load. Measure rate of closure for valves at maximum diameter of disc, plug, or ball.
 - 2. Size actuators so that gear boxes are not required where possible.
- D. Control interface:
 - 1. Configuration:
 - a. Provide a non-intrusive, non-contacting interface for configuring all input and output settings, control values, ranges, torque switch settings, valve positions switch settings, and options.
 - 1) Configurable from a hand-held configuring tool or input devices on the actuator.
 - 2. Local interface, integral to actuator:
 - a. Non-intrusive, non-contacting selector switches:
 - 1) LOCAL-STOP-REMOTE:
 - a) Motor actuator operation is prevented with the switch in STOP.

- 2) OPEN-CLOSE:
 - a) Controls the valve when LOCAL-STOP-REMOTE is in LOCAL.
 - b) Spring return to center.
 - c) Configurable between maintained (actuator runs until end of travel, high torque, or a LOCAL-STOP-REMOTE is switched to STOP) and momentary (actuator stops when lever is released).
 - b. Local display:
 - 1) Valve fully open and fully closed indicators.
 - 2) Numerical display showing actual valve or gate position in percent of travel.
 3. Control inputs:
 - a. Capable of using 120 VAC or 24 VDC inputs.
 - b. Controls the valve when LOCAL-STOP-REMOTE is in REMOTE.
 - c. Isolated inputs capable of operating from external control voltage source or internal power supply:
 - 1) Furnish 120 VAC and 24 VDC control power supplies within the actuator.
 - d. Provide the following inputs:
 - 1) OPEN.
 - 2) CLOSE.
 - 3) STOP.
 - e. OPEN and CLOSE inputs configurable between maintained (actuator runs until end of travel, high torque, or a STOP input) and momentary (actuator stops when command is removed).
 4. Status outputs:
 - a. Monitor relay output: Dry contact, normally closed, opens when actuator is not in REMOTE or in the event of any internal fault or alarm condition.
 - b. Provide the following outputs for all actuators:
 - 1) Fully closed.
 - 2) Fully open.
 - 3) LOCAL-STOP-REMOTE in REMOTE position.
 - c. Capable of being configured for the following additional functions:
 - 1) Communications failure.
 - 2) Valve opening or closing.
 - d. All output contacts rated for 5 amps, 120 VAC and 24 VDC.
- E. Features:
1. Time delay on reversal: Incorporate time delay between stopping actuator and starting in opposite direction to limit excessive current, torque, and heating from instantaneous reversal.
 2. Data logging:
 - a. Store diagnostic data and reference data.
 - b. Historical operating data, including number of operations and most recent operations.
 - c. Starting torque, maximum running torque, and end of travel torque.
 - 1) Store reference data (recorded during commissioning) and data from last operation.
 3. Provide display of logged data on the actuator, or provisions to download to a personal computer.
- F. Materials:
1. Construct motorized actuators of materials suitable for the environment in which the valve or gate is to be installed.

G. Components:

1. Motors:
2. Specifically designed for valve actuator service with high starting torque, totally enclosed non-ventilated construction.
3. Torque ratings equal to or greater than that required for valve seating and dynamic torques with a 25 percent factor of safety.
 - a. Design requirements for rubber-seated AWWA butterfly valves:
 - 1) Design actuators for maximum gate or valve operating torque, in accordance with and using safety factors required in AWWA C504 and AWWA C540.
 - a) Valve actuator torque requirement for open-close service: Not less than the required valve-seating and dynamic torques under design operating conditions in accordance with AWWA C504.
 - b) Valve actuator torque requirement for modulating service: Not less than twice the required valve dynamic torque under design operating conditions in accordance with AWWA C504.
 - 2) Design actuators for maximum gate or valve operating torque, in accordance with and using safety factors required in AWWA C504 and AWWA C540.
 - 3) Design for the maximum torque and thrust running load over the full cycle.
 - 4) Maximum torque or thrust rating: The actuator stall torque or maximum thrust output shall not exceed the torque or thrust capability of the valve or gate, as determined by the valve or gate manufacturer.
 - b. Design requirements for slide gates, gate valves, knife gate valves, globe valves, and diaphragm valves:
 - 1) Design valves and actuators for maximum operating torque, in accordance with and using safety factors required in AWWA C504.
 - 2) Design for the maximum torque and thrust running load over the full cycle.
 - 3) Maximum torque or thrust rating: The actuator stall torque or maximum thrust output shall not exceed the torque or thrust capability of the valve or gate, as determined by the valve or gate manufacturer.
4. Capable of being removed and replaced without draining the actuator gear case.
5. Motor bearings shall be amply proportioned of the anti-friction type and permanently lubricated.
6. Rated for operating under the following conditions without exceeding temperature limits with ambient temperature of 40 degrees Celsius.
 - a. Continuous operation for 15 minutes or twice the open-to-close operating time (whichever is greater) at normal operating torque or 33 percent of maximum torque (whichever is greater).
 - b. 60 starts per hour for open/close service or 1,200 starts per hour for modulating service.
7. Provide the following motor protection features:
 - a. Jammed valve (no valve motion detected through a time delay).
 - b. High motor temperature (sensed by an embedded thermostats).
 - c. High torque.
 - d. Single phasing protection.

H. Enclosures:

1. Actuator housing ratings as indicated in the Schedule.
2. Stainless steel external fasteners.
3. Provide 'O' ring seals for each of the following areas:
 - a. Between the terminal compartment and the internal electrical elements.
 - b. Between the mechanical and electrical portions to protect from the ingress of oil, and to protect the mechanical components of oil from dust and moisture when the electrical terminal is open.

I. Position sensing:

1. Electronic and adjustable using a solid-state encoder wheel.
 - a. Mechanical limit switches and potentiometers are not acceptable.

13447-5

August 2016

Water Conservation Program Implementation, Package No. 2

Project SS2970

2. Capable of retaining position and monitoring valve or gate motion when valve is manually actuated and when main power is not present.
 3. Valve range and position switch outputs field adjustable.
- J. Torque sensing:
1. Torque shutdown setting: 40 percent to 100 percent rated torque.
 - a. Adjustable in 1 percent increments.
 2. Torque display: 0 to 100 percent-rated torque.
 3. Capable of interrupting control circuit during both opening and closing and when valve torque overload occurs.
 4. Electrical or electronic torque sensing.
 5. Independent of variations in frequency, voltage, or temperature.
 6. Provide a temporary inhibit of the torque sensing system during unseating or during starting in mid-travel against high inertia loads.
 7. Provide visible verification of torque switch status without any housing disassembly.
- K. Manual actuators:
1. Hand wheel for manual operation.
 - a. Maximum 80 pound pull on rim when operating gate or valve under maximum load.
 - b. Provide pull chain when motorized actuator is located more than 6 feet above floor surface.
 - 1) Chain shall be of sufficient length to reach approximately 4 feet above the operating level.
 - 2) Where the chain obstructs an aisle or walkway, provide holdback or other means to ensure chain does not create a nuisance or hazard to operating personnel.
 2. Declutch lever: Padlockable, capable of mechanically disengaging motor and related gearing and freeing hand wheel for manual operation.
- L. Gearing: Hardened alloy steel spur or helical gears and self-locking, alloy bronze worm gear set.
1. Accurately cut to assure minimum backlash.
- M. Bearings:
1. Anti-friction bearing with caged balls or rollers throughout.
 2. Sealed-for-life type thrust bearings housed in a separate thrust base.
- N. Drive bushing:
1. Easily detachable for machining to suit the valve stem or gearbox input shaft.
 2. Positioned in a detachable base of the actuator.
- O. Lubrication:
1. Provide totally enclosed actuator gearing with oil filled gear case suitable for operation at any angle.
 2. Suitable for standard SAE80EP gear oil.
 3. Actuators requiring special or exotic lubricants are not acceptable.

2.03 ACCESSORIES

- A. Software:

1. Furnish PC-based diagnostic and configuration software to display diagnostic data as required per the selected Manufacturer.
- B. Termination module cover:
1. For actuators on a valve network provide a means to keep the valve network in service, in the event where the actuator must be removed.
 2. Provide sunshades for all outdoor installations of remote control stations that use a LCD or similar screen. Regular pushbutton, sector switches, and pilot light control stations will not require a sunshade.

2.04 SOURCE QUALITY CONTROL

- A. Factory test:
1. Test each actuator in the factory, and submit an individual test certificate for each actuator.
 2. Perform a high potential test and record the following information:
 - a. Test voltage.
 3. Simulate a maximum and typical valve loads and record the following information:
 - a. Current and power factor at maximum and set torque values.
 - b. Torque as measured by the actuator.
 - c. Actuator output speed or operating time.
 4. Performance testing: Conduct performance test for each actuator simulating valve operating torque from full-open to full-close and from full-close to full-open. The following information shall be recorded during each performance test:
 - a. Torque at maximum torque setting.
 - b. Current at maximum torque setting.
 - c. Test voltage and frequency.
 - d. Actuator output speed and operating time for full-open to full-close.
 - e. Amperage draw on motors at breakaway and under normal operation.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install actuators in accordance with manufacturer's instructions.

3.02 MOTORIZED ACTUATOR SCHEDULE

- A. Provide all actuators indicated on the Drawings.
1. Major process actuators are listed in the Intelligent Actuator Schedule in this section.
- B. Abbreviations relating to type:
1. BFV = Butterfly Valve.
 2. BV = Ball Valve.
 3. PV = Plug Valve.
 4. SG = Slide Gate.
- C. Abbreviations relating to actuator type:
1. O/C = Open and Close Service.
 2. MOD = Modulating Service.

- D. Abbreviations relating to controls:
1. A = Analog (4-20mA) control, modulating duty.
 2. D = Discrete control, modulating duty.
 3. D-O/C = Discrete Open/Close.

END OF SECTION

INTELLIGENT ACTUATOR SCHEDULE

Item	Type	Size	Actuator Type	Rating	Voltage /Phase /Hz	Notes	Open Time	Controls
Tank Feed Valve (MOV-1)	BFV	12"	O/C	4	480/3/60	2	60 s	D-O/C
Oak Drive Line Valve from Mulberry WWTP	BFV	12"	O/C	NEMA 6P	480/3/60	3	60s	D-O/C
Smoketree/95 Line A Valve	BFV	18"	O/C	NEMA 6P	120/1/60		60 s	D-O/C
Smoketree/95 Line B Valve	BFV	18"	O/C	NEMA 6P	120/1/60		60 s	D-O/C
Notes: (1) Provide actuators with remote control station. (2) New motorized actuator to be installed on existing equipment. Field verify characteristics prior to sizing motor actuator. (3) New motorized valve and actuator.								

13447-9

THIS PAGE INTENTIONALLY LEFT BLANK

SECTION 15118

PRESSURE REDUCING AND PRESSURE RELIEF VALVES

PART 1 GENERAL

1.01 SUMMARY

- A. Section includes: Pressure reducing and pressure relief valves for water service.

1.02 REFERENCES

- A. American Society of Mechanical Engineers (ASME):
 - 1. B16.42 - Ductile Iron Pipe Flanges and Flanged Fittings: Classes 150 and 300.
- B. ASTM International (ASTM):
 - 1. A48 - Standard Specification for Gray Iron Castings.
 - 2. A536 - Standard Specification for Ductile Iron Castings.
- C. Underwriters Laboratories, Inc. (UL).

1.03 SUBMITTALS

- A. Furnish submittals as specified by the City's Standard Specifications.

PART 2 PRODUCTS

2.01 FIELD APPLIED COATING OF VALVE EXTERIOR

- A. Match color and be compatible with manufacturer's coating system and as specified in the Drawings.
 - 1. When shop applied finish coating matches field applied coating on adjacent piping, touch up shop coating in damaged areas in accordance with instructions recommended by the paint manufacturer.
 - 2. When shop applied coating does not match field coating on adjacent piping, or when damage has occurred to the shop applied coating that requires more than touchup, blast clean valve surfaces or utilize other surface preparation recommended by the manufacturer of the coating material and apply the coating system used for coating adjacent piping.

2.02 WATER PRESSURE REDUCING VALVES

- A. Water pressure reducing valves, 2 1/2 inches and smaller:
 - 1. Manufacturers: One of the following or equal:
 - a. Watts Regulator, Series LF223.
 - b. Wilkins, 500 Series.
 - 2. Direct operated, single seat type pressure reducing valve.
 - 3. Materials:
 - a. Body and spring cover: Bronze.
 - b. Valve seat: Series 300 stainless steel.

- c. Diaphragm: EPDM.
 - d. Disk: EPDM.
- B. Water pressure reducing valves, 3 inches and larger:
- 1. Manufacturers: One of the following, or equal:
 - a. Watts ACV Series 115.
 - b. Cla-Val Model 90-01.
 - 2. Design:
 - a. Pilot controlled, hydraulically operated, diaphragm actuated, globe patterned valve.
 - b. Rated for 125 pounds per square inch gauge.
 - c. Pilot line: Equipped with a strainer.
 - d. Flanges: 150 pound rating, in accordance with ASME B16.42.
 - 3. Materials:
 - a. Body and cover: Cast iron ASTM A48 or Ductile Iron ASTM A536.
 - b. Valve trim: Bronze.
 - c. Pilot control: Cast bronze with Series 303 stainless steel trim.
 - d. Diaphragm: EPDM.

2.03 WATER PRESSURE RELIEF VALVES

- A. Water pressure relief valves:
- 1. Manufacturers: One of the following, or equal:
 - a. Watts ACV Series 116.
 - b. Cla-Val Model 50-01.
 - 2. Design:
 - a. Pilot controlled, hydraulically operated, diaphragm actuated, globe patterned valve.
 - b. Rated for 125 pounds per square inch gauge.
 - c. Pilot line: Equipped with a strainer.
 - d. End connections:
 - 1) 2 1/2 inch and smaller: Screwed.
 - 2) 3 inch and larger: 150 pound rated flanges in accordance with ASME B16.42.
 - 3. Materials:
 - a. Body and cover: Cast iron ASTM A48 or Ductile Iron ASTM A536.
 - b. Valve trim: Bronze.
 - c. Pilot control: Cast bronze with Series 303 stainless steel trim.
 - d. Diaphragm: EPDM.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install as specified by City's Standard Specifications.

END OF SECTION

SECTION 15120
PIPING SPECIALTIES

PART 1 GENERAL

1.01 SUMMARY

- A. Section includes: Piping specialties including:
 - 1. Tapping sleeves.
 - 2. Sight glasses.

1.02 REFERENCES

- A. American Society of Mechanical Engineers (ASME):
 - 1. B16.5 - Pipe Flanges and Flanged Fittings: NPS 1/2 through NPS 24.
- B. American Water Works Association (AWWA):
 - 1. C110 - Standard for Ductile-Iron and Gray-Iron Fittings.
 - 2. C151 - Standard for Ductile-Iron Pipe, Centrifugally Cast.
- C. ASTM International (ASTM).
 - 1. A 148 - Standard Specification for Steel Castings, High-Strength, for Structural Purposes.
 - 2. A 536 - Standard Specification for Ductile Iron Castings.

1.03 SUBMITTALS

- A. Furnish submittals as specified by the City's Standard Specifications.
- B. Product data:
 - 1. Submit for each piping specialty:
 - a. Shop drawings detailing dimensions and materials.
 - b. Manufacturer's published installation instructions.
- C. Furnish operations and maintenance manual as specified by City's Standard Specifications.

PART 2 PRODUCTS

2.01 TAPPING SLEEVES

- A. Manufacturers: One of the following or equal:
 - 1. BTR, Inc./Smith-Blair, Inc., Style 622.
 - 2. Romac Industries, Inc., Style FTS 420.
- B. Materials:
 - 1. Tapping sleeves: Steel construction.
 - 2. Bolts and nuts: Type 304 stainless steel.
 - 3. Nuts: Teflon coated.

4. Gaskets: EPDM.
5. Size of tapped boss: As indicated on the Drawings.

2.02 SIGHT GLASSES

- A. Assembly: Body casting with ASME standard adapter flanges, borosilicate Pyrex™ glass section, cleaning assembly with scalloped neoprene wipers, operating rod and handle, packing gland with packing and suitable adapter, and cock with solvent hand pump.
- B. Suitable for a minimum pressure of 30 pounds per square inch gauge.
- C. Manufacturers: One of the following or equal:
 1. EIMCO Process Machinery Division of Envirotech Corporation.
 2. Ernst, Type K2 or K3 Cleanable Sight Glass.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Tapping sleeves:
 1. Verify existing pipe material and outer diameter prior to ordering materials.
 2. Coat threads on bolts with anti-gall coating prior to installation.

3.02 COMMISSIONING AND PROCESS START-UP REQUIREMENTS

- A. As specified in this Section.
- B. Manufacturer (each) services for each type of piping specialty:
 1. Provide Manufacturer's Certificate of Source Testing.
 2. Provide Manufacturer's Certificate of Installation and Functionality Compliance.

Source Testing (Witnessed or Non-witnessed)	Manufacturer Rep Onsite							
	Training Requirements		Installation Testing		Functional Testing		Process Operational Period	
	Maintenance (hrs per session)	Operation (hrs per session)	Trips	Days (each trip)	Trips	Days (each trip)	Trips	Days (each trip)
Non-Witnessed	4	2	1	1	0	0	Not Required	

- C. Functional Testing:
 1. Pressure test as specified by City's Standard Specifications.

END OF SECTION