



LAKE HAVASU CITY

Community Investment Department

ENGINEERING ♦ PROCUREMENT ♦ BUILDING ♦ PLANNING & ZONING ♦ CODE ENFORCEMENT

**ROTARY PARK & LONDON BRIDGE BEACH
RESTROOM IMPROVEMENTS
PROJECT NO. PK 1010
ADDENDUM NO. 1
October 31, 2018**

Attention is called to the following changes, additions, clarifications and/or deletions to the original solicitation and they shall be taken into account in preparing submissions:

There is no change in the opening date. **Submissions are due no later than 3:00 p.m., Arizona Time, November 7, 2018**, at the City Clerk's Office, 2330 McCulloch Blvd. N., Lake Havasu City, AZ 86403.

QUESTION AND RESPONSE TO BID DOCUMENTS

Question 1:

What brand or model numbers are spec'd out for the new building bathroom accessories and how many of each accessory are required? Ex. Toilet paper dispensers, mirrors, soap dispensers etc.?

Response 1:

Refer to Keynotes and Plumbing Fixture List on Sheet RP-4-MP1.

Question 2:

We are working on a plumbing proposal for this project and wanted to get clarification on the lift stations to be replaced. We do not find a spec page for the lift stations, can you please provide a spec page if we are to provide them, or clarification if we are installing "owner provided" lift station or just hooking them up.

Response 2:

Contractor to "furnish all materials, labor, equipment and tools for the demolition of the existing pump station and construction of a new pump station in its place". Contractor to provide shop drawings for approval of City Engineer prior to ordering pump station. Refer to pages C9 and C10 of the plans and page 01210-5 of the Contract Documents and Technical Specifications.

Question 3:

There are no plans identifying the work at London Bridge Unit #1, but it is included in the bid form.

Response 3:


Correct. All the work at London Bridge #1 will be based on Bid Schedule. Contractor to verify dimensions in field.

Question 4:

On pg. LB 302 it shows eight skylight tubes on Unit # 3 at London Bridge Beach and on pg. LB 303 it shows only 6 what is the correct amount of skylight tubes are on Unit #3 at London Bridge Beach?

Response 4:

There are only 6 skylights shown on sheets LB302 and LB303.



DATE: 10/31/2018

BY: Arthur H. Beckwith, PE