

RESOLUTION 15-2927

A RESOLUTION OF THE MAYOR AND CITY COUNCIL OF LAKE HAVASU CITY, MOHAVE COUNTY, ARIZONA, DECLARING AS A PUBLIC RECORD THE "LAKE HAVASU CITY AMENDMENTS TO THE 2012 EDITION OF THE INTERNATIONAL MECHANICAL CODE" DATED MAY 12, 2015

IT IS RESOLVED by the Mayor and City Council of Lake Havasu City, Arizona, that the document entitled "Lake Havasu City Amendments to the 2012 Edition of the International Mechanical Code" is declared a public record and at least three copies are on file in the City Clerk's Office for public use and inspection.

PASSED AND ADOPTED by the City Council of Lake Havasu City, Arizona, on May 12, 2015.

APPROVED:



Mark S. Nexsen, Mayor

ATTEST:




Kelly Williams, City Clerk

APPROVED AS TO FORM:



Kelly Garry, City Attorney

REVIEWED BY:



Charlie Cassens, City Manager

**LAKE HAVASU CITY AMENDMENTS TO THE 2012 EDITION OF THE
INTERNATIONAL MECHANICAL CODE**

May 12, 2015

Section 106.4.4 Amend to delete last sentence

Section 106.5.2 Amend entire section to read:

The fees for mechanical work shall be paid as required, in accordance with the schedule as established by the applicable governing authority.

Section 106.5.3 (2) Amend to insert 80 into brackets

Section 106.5.3 (3) Amend to insert 80 into brackets

Section 108.4 Amend first sentence to read:

Persons who shall violate a provision of this code or shall fail to comply with any requirements thereof or who shall erect, install, alter or repair mechanical work in violation of the approved construction documents or directive of the code official, or of a permit or certificate issued under the provisions of this code, shall be subject to penalties as prescribed by law.

Section 108.5 Amend last sentence to read:

Any person who shall continue any work on the system after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Section 312 Amend to delete entire section

Section 401.2 Amend to delete last sentence

Section 504.6.5 Amend entire section to read:

Where the exhaust duct is concealed within the building construction, the equivalent length of the exhaust duct shall be identified on a permanent label or tag. The label or tag shall be located within 6 feet (1829 mm) of the exhaust duct connection. The label or tag shall indicate the total length and total number of 90 degree and 45 degree turns of the dryer exhaust system. The owner and/or the supplier shall verify that any new or replacement dryer meets the exhaust specifications shown.

Section 1201.2.1

Amend to add new section 1201.2.1:

Flow Restriction device for water-cooled refrigerating systems:

Water-cooled refrigerating systems shall be equipped with one of the following devices:

1. Cooling tower
2. Evaporative condenser
3. Listed water-circulating device

Exceptions:

1. A system with an aggregate total of 2 tons or less or a rating of 2 horsepower or less and located or installed at 1 street address.
2. A system with an aggregate total of 2 tons or less or a rating of 2 horsepower or less and service multiple dwelling unit structures on the same lot. Such systems should be equipped with water regulation valves adjusted to use a minimum amount of water.